# Q Series CPU Direct Driver

1	System Configuration	3
2	External Devices Selection	7
3	Communication Settings	8
4	Setup Items	9
5	Cable Diagram	13
6	Supported Device	15
7	Device Code and Address Code	24
8	Error Messages	29

#### Introduction

This manual describes how to connect the Display and the External Device (target PLC). In this manual, the connection procedure is described in the sections identified below:

System Configuration 1 "1 System Configuration" (page 3) This section lists the types of External Devices and SIO that you can connect. **External Devices Selection** "2 External Devices Selection" (page 7) Select the model (series) of the External Device and its connection method. Communication Settings 3 "3 Communication Settings" (page 8) This section shows setting examples for communicating between the Display and the External Device. 4 Setup Items "4 Setup Items" (page 9) This section describes communication setup items on the Display. Set the Display's communication settings in GP-Pro EX or in offline mode. Cable Diagram 5 "5 Cable Diagram" (page 13) This section shows cables and adapters for connecting the Display and the External Device.

Operation

# 1 System Configuration

The system configuration in the case when the External Device of Mitsubishi Electric Corporation and the Display are connected is shown.

Series	CPU	Link I/F	SIO Type	Setting Example	Cable Diagram
	Q02CPU Q02HCPU Q06HCPU Q12HCPU Q25HCPU		- RS232C		
MELSEC Q	Q00UJCPU Q00UCPU Q01UCPU Q02UCPU Q03UDCPU Q04UDHCPU Q06UDHCPU Q10UDHCPU Q13UDHCPU Q20UDHCPU Q26UDHCPU	RS-232C port on CPU unit			
Series	Q03UDECPU Q04UDEHCPU Q06UDEHCPU Q10UDEHCPU Q13UDEHCPU Q20UDEHCPU Q26UDEHCPU	RS-232C port on High Performance Model QCPU or Universal Model QCPU *1*2			
	Q172HCPU	RS-232C port on High Performance Model QCPU*3			
	Q172DCPU Q173DCPU	RS-232C port on Universal Model QCPU*1*3			


<sup>\*1</sup> Except Q00UJCPU, Q00UCPU and Q01UCPU.

<sup>\*2</sup> Since the Built-in Ethernet port QCPU (Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU) cannot be directly connected to the Display, use it with a Multi CPU System.


<sup>\*3</sup> Since the motion CPU (Q172HCPU, Q172DCPU, Q173DCPU) cannot be directly connected to the Display, use it with a Multi CPU System.

## ■ Connection Configuration

· Single CPU System



Multi CPU System



NOTE

- For CPU's Unit No., No.1 is allocated to the CPU slot and No.2, 3, and 4 are allocated to the other slots from No.1 to right.
- With Multi CPU System, it's possible to access a CPU unit that is not directly connected.
   Regarding the external devices that can be used for Multi CPU System, please refer to the manual of the External Device.
- Use the motion CPU within the No. 2 to No. 4 range. The motion CPU cannot be used as No. 1.

#### ■ IPC COM Port

When connecting IPC with an External Device, the COM port used depends on the series and SIO type. Please refer to the IPC manual for details.

#### Usable port

Series	Usable Port			
Selles	RS-232C	RS-422/485(4 wire)	RS-422/485(2 wire)	
PS-2000B	COM1 <sup>*1</sup> , COM2, COM3 <sup>*1</sup> , COM4	-	-	
PS-3450A, PS-3451A, PS3000-BA, PS3001-BD	COM1, COM2*1*2	COM2*1*2	COM2*1*2	
PS-3650A (T41 model), PS-3651A (T41 model)	COM1*1	-	-	
PS-3650A (T42 model), PS-3651A (T42 model)	COM1*1*2, COM2	COM1*1*2	COM1*1*2	
PS-3700A (Pentium®4-M) PS-3710A	COM1*1, COM2*1, COM3*2, COM4	COM3*2	COM3*2	
PS-3711A	COM1*1, COM2*2	COM2*2	COM2*2	
PS4000*3	COM1, COM2	-	-	
PL3000	COM1 <sup>*1*2</sup> , COM2 <sup>*1</sup> , COM3, COM4	COM1*1*2	COM1*1*2	

<sup>\*1</sup> The RI/5V can be switched. Use the IPC's switch to change if necessary.

For connection with External Device, use user-created cables and disable Pin Nos. 1, 4, 6 and 9. Please refer to the IPC manual for details of pin layout.

#### DIP Switch setting: RS-232C

DIP Switch	Setting	Description	
1	OFF*1	Reserved (always OFF)	
2	OFF	SIO type: RS-232C	
3	OFF	510 type. R5-232c	
4	OFF	Output mode of SD (TXD) data: Always output	
5	OFF	Terminal resistance (220Ω) insertion to SD (TXD): None	
6	OFF	Terminal resistance (220Ω) insertion to RD (RXD): None	
7	OFF	Short-circuit of SDA (TXA) and RDA (RXA): Not available	
8	OFF	Short-circuit of SDB (TXB) and RDB (RXB): Not available	
9	OFF	RS (RTS) Auto control mode: Disabled	
10	OFF	K3 (K13) Auto Control mode. Disabled	

<sup>\*1</sup> When using PS-3450A, PS-3451A, PS3000-BA and PS3001-BD, turn ON the set value.

<sup>\*2</sup> Set up the SIO type with the DIP Switch. Please set up as follows according to SIO type to be used.

<sup>\*3</sup> When making communication between an External Device and COM port on the Expansion slot, only RS-232C is supported. However, ER (DTR/CTS) control cannot be executed because of the specification of COM port.


## DIP Switch setting: RS-422/485 (4 wire)


DIP Switch	Setting	Description	
1	OFF	Reserved (always OFF)	
2	ON	SIO type: RS-422/485	
3	ON	310 type. K3-422/463	
4	OFF	Output mode of SD (TXD) data: Always output	
5	OFF	Terminal resistance (220Ω) insertion to SD (TXD): None	
6	OFF	Terminal resistance (220Ω) insertion to RD (RXD): None	
7	OFF	Short-circuit of SDA (TXA) and RDA (RXA): Not available	
8	OFF	Short-circuit of SDB (TXB) and RDB (RXB): Not available	
9	OFF	RS (RTS) Auto control mode: Disabled	
10	OFF	K5 (K15) Auto control mode. Disabled	

## DIP Switch setting: RS-422/485 (2 wire)

DIP Switch	Setting	Description	
1	OFF	Reserved (always OFF)	
2	ON	SIO type: RS-422/485	
3	ON	510 type. R5-422/465	
4	OFF	Output mode of SD (TXD) data: Always output	
5	OFF	Terminal resistance (220Ω) insertion to SD (TXD): None	
6	OFF	Terminal resistance (220Ω) insertion to RD (RXD): None	
7	ON	Short-circuit of SDA (TXA) and RDA (RXA): Available	
8	ON	Short-circuit of SDB (TXB) and RDB (RXB): Available	
9	ON	RS (RTS) Auto control mode: Enabled	
10	ON	K3 (K13) Auto control mode. Enabled	

## 2 External Devices Selection





Setup Items	Setup Description		
Number of Devices/ PLCs	Enter an integer from 1 to 4 to define the number of Devices/PLCs to connect to the display.		
Manufacturer	Select the manufacturer of the External Device to connect. Select "Mitsubishi Electric Corporation".		
Series	Select the External Device model (series) and the connection method. Select "Q Series CPU Direct".  In System configuration, make sure the External Device you are connecting is supported by "Q Series CPU Direct".  "1 System Configuration" (page 3)		
Port	Select the Display port to connect to the External Device.		
Use System Area	Check this option to synchronize the system data area of the Display and the device (memory) of the External Device. When synchronized, you can use the External Device's ladder program to switch the display or display the window on the Display.  Cf. GP-Pro EX Reference Manual "LS Area (Direct Access Method Area)"  This feature can also be set in GP-Pro EX or in the Display's offline mode.  Cf. GP-Pro EX Reference Manual "System Settings [Display Unit] - [System Area] Settings Guide"  Cf. Maintenance/Troubleshooting Guide "Main Unit - System Area Settings"		


# 3 Communication Settings

Examples of communication settings of the Display and the External Device, recommended by Pro-face, are shown.

#### 3.1 Setting Example 1

- Settings of GP-Pro EX
- Communication Settings

To display the setup screen, from the [Project] menu, point to [System Settings] and select [Device/PLC].



#### ■ Settings of External Device

There is no setting on the External Device. The speed automatically switches according to the Display setting.

## 4 Setup Items

Set communication settings of the Display with GP-Pro EX or in offline mode of the Display.


The setting of each parameter must be identical to that of External Device.

"3 Communication Settings" (page 8)

### 4.1 Setup Items in GP-Pro EX

#### ■ Communication Settings

To display the setup screen, from the [Project] menu, point to [System Settings] and select [Device/PLC].



Setup Items	Setup Description
SIO Type	Select the SIO type to communicate with the External Device.
Speed	Select speed between the External Device and the Display.
Data Length	Data length is displayed.
Parity	The parity check method is displayed.
Stop Bit	Stop bit length is displayed.
Flow Control	The communication control method to prevent overflow of transmission and reception data is displayed.
Timeout	Use an integer from 1 to 127 to enter the time (s) for which the Display waits for the response from the External Device.
Retry	In case of no response from the External Device, use an integer from 0 to 255 to enter how many times the Display retransmits the command.
Wait To Send	Use an integer from 0 to 255 to enter standby time (ms) for the Display from receiving packets to transmitting next commands.

Setup Items	Setup Description
RI/VCC	Switches RI/VCC of the 9th pin.  It is necessary to change RI/5V by changeover switch of IPC when connect with IPC.  Please refer to the manual of the IPC for more detail.

NOTE	<ul> <li>Refer to the GP-Pro EX Reference Manual for Indirect Device.</li> </ul>
	Cf. GP-Pro EX Reference Manual "Changing the Device/PLC at Runtime (Indirect Device)"


#### 4.2 Setup Items in OffLine Mode



- Please refer to Maintenance/Troubleshooting Guide for more information on how to enter offline mode or about operation.
  - Cf. Maintenance/Troubleshooting Guide "Offline Mode"
- The number of the setup items to be displayed for 1 page in the offline mode depends on the Display in use. Please refer to the Reference manual for details.

#### ■ Communication Settings

To display the setting screen, touch [Device/PLC Settings] from [Peripheral Settings] in offline mode. Touch the External Device you want to set from the displayed list.




Setup Items	Setup Description
	SIO type to communicate with the External Device is displayed.
SIO Type	To make the communication settings correctly, confirm the serial interface specifications of Display unit for [SIO Type].  We cannot guarantee the operation if a communication type that the serial interface does not support is specified.  For details concerning the serial interface specifications, refer to the manual for Display unit.
Speed	Select speed between the External Device and the Display.
Data Length	Data length is displayed.
Parity	The parity check method is displayed.
Stop Bit	Stop bit length is displayed.
Flow Control	The communication control method to prevent overflow of transmission and reception data is displayed.
Timeout	Use an integer from 1 to 127 to enter the time (s) for which the Display waits for the response from the External Device.

Setup Items	Setup Description	
Retry	In case of no response from the External Device, use an integer from 0 to 255 to enter how many times the Display retransmits the command.	
Wait To Send	Use an integer from 0 to 255 to enter standby time (ms) for the Display from receiving packets to transmitting next commands.	

## ■ Option

To display the setting screen, touch [Device/PLC Settings] from [Peripheral Settings]. Touch the External Device you want to set from the displayed list, and touch [Option].



Setup Items	Setup Description		
RI/VCC	Switches RI/VCC of the 9th pin.  It is necessary to change RI/5V by changeover switch of IPC when connect with IPC.  Please refer to the manual of the IPC for more detail.		

NOTE

• GP-4100 series and GP-4\*01TM do not have the [Option] setting in the offline mode.

## 5 Cable Diagram

The following cable diagrams may be different from cable diagrams recommended by Mitsubishi Electric Corporation.

Please be assured there is no operational problem in applying the cable diagram shown in this manual.

- The FG pin of the External Device body must be grounded according to your country's applicable standard. Refer to your External Device manual for details.
- SG and FG are connected inside the Display. When connecting the External Device to SG, design your system
  to avoid short-circuit loops.
- Connect an isolation unit if the communication is not stable due to noise or other factors.

#### Cable Diagram 1

Display (Connection Port)		Cable	Notes
GP3000 (COM1) GP4000*1 (COM1) ST (COM1) LT3000 (COM1) IPC*2 PC/AT	1A	Mitsubishi Q connection cable by Pro-face CA3-CBLQ-01(5m) or RS-232C cable by Mitsubishi Electric Corp. QC30R2 (3m) or RS-232C cable for MELSEC-Q CPU connection by Diatrend Corp. DQCABR2V-H	Available to order the length of DQCABR2V-H by Diatrend Corp. up to 15m.
GP-4105 (COM1)	1B	Mitsubishi PLC Q Series CPU I/F Cable (3m) ZC9CBQ31	

<sup>\*1</sup> All GP4000 models except GP-4100 series and GP-4203T

<sup>\*2</sup> Only the COM port which can communicate by RS-232C can be used.

<sup>■</sup> IPC COM Port (page 5)


CA3-CBLQ-01
or
QC30R2
or
External Device
DQCABR2V-H

1B) Display side Terminal block Signal name Cable color RD(RXD) Green **External Device** Display Brown SD(TXD) ZC9CBQ31 Yellow ER(DTR) Red SG Orange Blue DR(DSR) Blue CS(CTS) Blue

# 6 Supported Device

Range of supported device address is shown in the table below. Please note that the actually supported range of the devices varies depending on the External Device to be used. Please check the actual range in the manual of your External Device.

Input address of external device in the dialog below.



1. Unit Number Select the number of a CPU unit to communicate with from 1 to 4.

Select "0" to access a CPU unit that is directly connected like the Single CPU System.

Device Specify a device.
 Address Specify an address.

#### 6.1 Q02CPU/Q02HCPU/Q06HCPU/Q12HCPU/Q25HCPU

This address can be specified as system data area.

Device	Bit Address	Bit Address Word Address		Notes
Input Relay	X0000 - X1FFF	X0000 - X1FF0		*** 0]
Output Relay	Y0000 - Y1FFF	Y0000 - Y1FF0		*** 0]
Internal Relay	M00000 - M32767	M00000 - M32752		<u>÷16</u> ]
Special Relay	SM0000 - SM2047	SM0000 - SM2032		<u>÷</u> 16)
Latch Relay	L00000 - L32767	L00000 - L32752		<u>÷</u> 16j
Annunciator	F00000 - F32767	F00000 - F32752		<u>÷ 16</u> ]
Edge Relay	V00000 - V32767	V00000 - V32752		÷16j
Step Relay	S0000 - S8191	S0000 - S8176	[L/H]	<u>÷</u> 16j
Link Relay	B0000 - B7FFF	B0000 - B7FF0		*** 0]
Special Link Relay	SB000 - SB7FF	SB000 - SB7F0		*** 0]
Timer (Contact)	TS00000 - TS23087			
Timer (Coil)	TC00000 - TC23087			
Retentive Timer (Contact)	SS00000 - SS23087			
Retentive Timer (Coil)	SC00000 - SC23087			

Device	Bit Address	Word Address	32 bits	Notes
Counter (Contact)	CS00000 - CS23087			
Counter (Coil)	CC00000 - CC23087			
Timer (Current Value)		TN00000 - TN23087		
Retentive Timer (Current Value)		SN00000 - SN23087		
Counter (Current Value)		CN00000 - CN23087		
Data Register		D00000 - D25983		*1 B i t F)
Special Register		SD0000 - SD2047	-	BitF)
Link Register		W0000 - W657F		B i t F)
Special Link Register		SW000 - SW7FF		B i t F)
File Register (Normal)		R00000 - R32767	[L/H]	Bit F)
File Register (Block switching is not necessary)		ZR0000000 - ZR1042431		Bit F
		0R00000 - 0R32767		BitF)
		1R00000 - 1R32767		Bit F)
		2R00000 - 2R32767		B : + F)
File Register (0R-31R)*2	:	:		:
,		30R00000 - 30R32767		Bit F)
		31R00000 - 31R26623		Bit F

<sup>\*1</sup> The setting of the Multi CPU System is possible also in the system data area.

<sup>\*2</sup> Set the block No. on the head of device name. This is the device name for conversion with GP-Pro/PB III for Windows. When you newly specify the device, we recommend that you should use the file register (Block switching is not necessary).


NOTE

• The notation of addresses differs depending on a selected Unit No.

<Ex.>When 0 is selected for Unit No.,



<Ex.>When 1 is selected for Unit No.,



- Please refer to the GP-Pro EX Reference Manual for system data area.
  - Cf. GP-Pro EX Reference Manual "LS Area (Direct Access Method Area)"
- Please refer to the precautions on manual notation for icons in the table.
  - "Manual Symbols and Terminology"

6.2 Q00UJCPU/Q00UCPU/Q01UCPU/Q02UCPU/Q03UDCPU/Q04UDHCPU/Q06UDHCPU/Q10UDHCPU/Q13UDHCPU/Q20UDHCPU/Q26UDHCPU/Q03UDECPU/Q04UDEHCPU/Q06UDEHCPU/Q10UDEHCPU/Q13UDEHCPU/Q20UDEHCPU/Q26UDEHCPU

This address can be specified as system data area.

Device	Bit Address	Word Address	32 bits	Notes
Input Relay	X0000-X1FFF	X0000-X1FF0		*** 0
Output Relay	Y0000-Y1FFF	Y0000-Y1FF0		* * * 0
Internal Dalay	M00000-M32767	M00000-M32752		÷16) *1
Internal Relay	M00000-M61439	M0000-M61424		÷ <b>16</b> ) *2
Special Relay	SM0000-SM2047	SM0000-SM2032		÷16)
Latch Relay	L00000-L32767	L00000-L32752		÷16)
Annunciator	F00000-F32767	F00000-F32752		÷16)
Edge Relay	V00000-V32767	V00000-V32752		÷16)
Step Relay	S0000-S8191	S0000-S8176		÷16)
Link Dolov	B0000-B7FFF	B0000-B7FF0		*** 0   *1
Link Relay	B0000-BEFFF	B0000-BEFF0		*** 0 *2
Special Link Relay	SB0000-SB7FFF	SB0000-SB7FF0		* * * 0
Timer (Centent)	TS00000-TS25023			*1
Timer (Contact)	TS00000-TS25471			*2
Timer (Cail)	TC00000-TC25023		[L/H]	*1
Timer (Coil)	TC00000-TC25471	C00000-TC25471		*2
Detentive Timer (Centeet)	SS00000-SS25023			*1
Retentive Timer (Contact)	SS00000-SS25471			*2
Detective Time on (Oeil)	SC00000-SC25023			*1
Retentive Timer (Coil)	SC00000-SC25471			*2
0	CS00000-CS25023			*1
Counter (Contact)	CS00000-CS25471			*2
O-111	CC00000-CC25023			*1
Counter (Coil)	CC00000-CC25471			*2
T(O		TN00000-TN25023		*1
Timer (Current Value)		TN00000-TN25471		*2
Retentive Timer (Current		SN00000-SN25023		*1
Value)		SN00000-SN25471		*2

Device	Bit Address	Word Address	32 bits	Notes
Country (Current Value)		CN00000-CN25023		*1
Counter (Current Value)		CN00000-CN25471		*2
		D0000000-D0028159		B : + F) *1 *3
		D0000000-D4212223		*1 *3 *4 *8
Data Register		D0000000-D0093695		*1 *3 *4 *5 *8
Data Negistei		D0000000-D0028671		Bit F *2 *3
		D0000000-D4212735		*2 *3 *4 *8
		D0000000-D0094207		*2 *3 *4 *5 *8
Special Register		SD0000-SD2047		Bit F
		W000000-W006DFF		Bit F) *1
		W000000-W4045FF	_ [L/H]	Bit F *1 *6 *8
Link Register		W000000-W016DFF		*1 *5 *6 *8
LITIK Negister		W000000-W006FFF		Bit F) *2
		W000000-W4047FF		Bit F *2 *6 *8
		W000000-W016FFF		*2 *5 *6 *8
Special Link Beginter		SW0000-SW6DFF		B i + F) *1
Special Link Register		SW0000-SW6FFF		B i + F] *2
		U3E0-10000 - U3E0-24335		<u> </u>
Common device for Multiple		U3E1-10000 - U3E1-24335		<u> </u>
CPU <sup>*7</sup>		U3E2-10000 - U3E2-24335		<u> </u>
		U3E3-10000 - U3E3-24335		<u> </u>
File Register (Normal)*8		R00000-R32767		Bit F
File Register (Block switching is not necessary) <sup>*8</sup>		ZR0000000- ZR4184063		<u> </u>

Device	Bit Address	Word Address	32 bits	Notes
		0R00000-0R32767		Bit F
		1R00000-1R32767		<sub>B i t</sub> F)
File Register		2R00000-2R32767		B i t F
File Register (0R-31R)**8 *9	:	:	L/H	:
		30R00000-30R32767		Bit F
		31R00000-31R32767		<sub>B i +</sub> F)

- \*1 For the universal model QCPU with a serial number whose first 5 digits is less than "10042".
- \*2 For the universal model QCPU with a serial number whose first 5 digits is "10042" or more.
- \*3 The setting of the Multi CPU System is possible also in the system data area.
- \*4 For the use of Extended Data Register.
- \*5 For the Q00UCPU or Q01UCPU.
- \*6 For the use of Extended Link Register.
- \*7 For the Multi CPU System configuration, the available points should be as follows:

2 CPUs: 14k points or less 3 CPUs: 13k points or less 4 CPUs: 12k points or less


- \*8 File Register, Extended Data Register and Extended Link Register cannot be used in the Q00UJCPU.
- \*9 Set the block No. on the head of device name. This is the device name for conversion with GP-Pro/PB III for Windows. When you newly specify the device, we recommend that you should use the file register (Block switching is not necessary).

NOTE

- The notation of addresses differs depending on a selected Unit No.
  - <Ex.>When 0 is selected for Unit No.,



<Ex.>When 1 is selected for Unit No.,



- Please refer to the GP-Pro EX Reference Manual for system data area.
  - Cf. GP-Pro EX Reference Manual "LS Area (Direct Access Method Area)"
- Please refer to the precautions on manual notation for icons in the table.
  - "Manual Symbols and Terminology"

#### 6.3 Q172HCPU

This address can be specified as system data area.

Device	Bit Address	Bit Address Word Address		Notes
Input Relay	X0000-X1FFF	X0000-X1FF0		* * * 0
Output Relay	Y0000-Y1FFF	Y0000-Y1FF0		* * * 0
Internal Relay	M00000-M08191	M00000-M08176		÷16ì
Special Relay	SM0000-SM0255	SM0000-SM0240		÷16)
Latch Relay	L00000-L08191	L00000-L08176		÷16ì
Annunciator	F00000-F02047	F00000-F02032	-1 / 1 1 5	÷16ì
Link Relay	B0000-B1FFF	B0000-B1FF0	[L/H]	* * * 0
Data Register		D0000000-D0008191		Bit F
Special Register		SD0000-SD0255		Bit F
Link Register		W0000-W1FFF		Bit F
Motion Register (#)*1		%MR0000- %MR8191 <sup>*2</sup>		Bit F

<sup>\*1</sup> No. 2 to No. 4 can be allocated to the motion CPU.

<sup>\*2</sup> Device name with motion CPU is #.




The notation of addresses differs depending on a selected Unit No.

<Ex.>When 0 is selected for Unit No.,



<Ex.>When 1 is selected for Unit No.,



- Please refer to the GP-Pro EX Reference Manual for system data area.
  - Cf. GP-Pro EX Reference Manual "LS Area (Direct Access Method Area)"
- Please refer to the precautions on manual notation for icons in the table.
  - "Manual Symbols and Terminology"

## 6.4 Q172DCPU / Q173DCPU

This address can be specified as system data area.

Device	Bit Address Word Address		32 bits	Notes
Input Relay	X0000-X1FFF	X0000-X1FF0		* * * 0
Output Relay	Y0000-Y1FFF	Y0000-Y1FF0		*** 0
Internal Relay	M00000-M12287	M00000-M12272		<u>÷16</u> )
Special Relay	SM0000-SM2255	SM0000-SM2240		<u>÷16</u> )
Annunciator	F00000-F02047	F00000-F02032		<u>÷16</u> )
Link Relay	B0000-B1FFF	B0000-B1FF0		* * * 0
Data Register		D0000000-D0008191		B i + F)
Special Register		SD0000-SD2255		B i + F)
Link Register		W0000-W1FFF	ΓL / H)	B i + F)
		U3E0-10000 - U3E0-24335		<sub>Bit</sub> F)
Common device for Multiple		U3E1-10000 - U3E1-24335		Bit F)
CPU <sup>*1</sup>		U3E2-10000 - U3E2-24335		Bit F
		U3E3-10000 - U3E3-24335		Bit F)
Motion Register (#) <sup>*2</sup>		%MR00000- %MR12287 <sup>*3</sup>		Bit F)

<sup>\*1</sup> For the Multi CPU System configuration, the available points should be as follows:

2 CPUs: 14k points or less3 CPUs: 13k points or less

4 CPUs: 12k points or less

<sup>\*2</sup> No. 2 to No. 4 can be allocated to the motion CPU.

<sup>\*3</sup> Device name with motion CPU is #.


NOTE

• The notation of addresses differs depending on a selected Unit No.

<Ex.>When 0 is selected for Unit No.,



<Ex.>When 1 is selected for Unit No.,



- Please refer to the GP-Pro EX Reference Manual for system data area.
  - Cf. GP-Pro EX Reference Manual "LS Area (Direct Access Method Area)"
- Please refer to the precautions on manual notation for icons in the table.
  - "Manual Symbols and Terminology"

# 7 Device Code and Address Code

Use device code and address code when you select "Device Type & Address" for the address type in data displays.

Device	Device Name	Device Code (HEX)	Address Code
	X	0080	
	1/X	0180	
Input Relay	2/X	0280	Value of word address divided by 0x10
	3/X	0380	
	4/X	0480	
	Y	0081	
	1/Y	0181	
Output Relay	2/Y	0281	Value of word address divided by 0x10
	3/Y	0381	
	4/Y	0481	
	M	0082	
	1/M	0182	
Internal Relay	2/M	0282	Value of word address divided by 16
	3/M	0382	
	4/M	0482	
	SM	0083	
	1/SM	0183	
Special Relay	2/SM	0283	Value of word address divided by 16
	3/SM	0383	
	4/SM	0483	
	L	0084	
	1/L	0184	
Latch Relay	2/L	0284	Value of word address divided by 16
	3/L	0384	
	4/L	0484	

Device	Device Name	Device Code (HEX)	Address Code
	F	0085	
	1/F	0185	
Annunciator	2/F	0285	Value of word address divided by 16
	3/F	0385	
	4/F	0485	
	V	0086	
	1/V	0186	
Edge Relay	2/V	0286	Value of word address divided by 16
	3/V	0386	
	4/V	0486	
	S	0087	
	1/S	0187	
Step Relay	2/S	0287	Value of word address divided by 16
	3/S	0387	
	4/S	0487	
	В	0088	
	1/B	0188	
Link Relay	2/B	0288	Value of word address divided by 0x10
	3/B	0388	
	4/B	0488	
	SB	0089	
	1/SB	0189	
Special Link Relay	2/SB	0289	Value of word address divided by 0x10
	3/SB	0389	
	4/SB	0489	
	TN	0060	
	1/TN	0160	
Timer (Current Value)	2/TN	0260	Word Address
	3/TN	0360	
	4/TN	0460	

Device	Device Name	Device Code (HEX)	Address Code
	SN	0062	
	1/SN	0162	
Retentive Timer (Current Value)	2/SN	0262	Word Address
,	3/SN	0362	
	4/SN	0462	
	CN	0061	
	1/CN	0161	
Counter (Current Value)	2/CN	0261	Word Address
	3/CN	0361	
	4/CN	0461	
	D	0000	
	1/D	0100	
Data Register	2/D	0200	Word Address
	3/D	0300	
	4/D	0400	
	SD	0001	
	1/SD	0101	
Special Register	2/SD	0201	Word Address
	3/SD	0301	
	4/SD	0401	
	W	0002	
	1/W	0102	
Link Register	2/W	0202	Word Address
	3/W	0302	
	4/W	0402	
	SW	0003	
	1/SW	0103	
Special Link Register	2/SW	0203	Word Address
	3/SW	0303	
	4/SW	0403	

Device	Device Name	Device Code (HEX)	Address Code
Common device for Multi-	U3E0-	0035	
	1/U3E0-	0135	
	2/U3E0-	0235	Word Address
	3/U3E0-	0335	
	4/U3E0-	0435	
	U3E1-	0036	
	1/U3E1-	0136	Word Address
	2/U3E1-	0236	
	3/U3E1-	0336	
	4/U3E1-	0436	
ple CPU	U3E2-	0037	
	1/U3E2-	0137	
	2/U3E2-	0237	Word Address
	3/U3E2-	0337	
	4/U3E2-	0437	
	U3E3-	0038	
	1/U3E3-	0138	
	2/U3E3-	0238	Word Address
	3/U3E3-	0338	
	4/U3E3-	0438	
File Register (Normal)	R	000F	
	1/R	010F	
	2/R	020F	Word Address
	3/R	030F	
	4/R	040F	
File Register (Block switching is not necessary)	ZR	000E	
	1/ZR	010E	
	2/ZR	020E	Word Address
	3/ZR	030E	
	4/ZR	040E	

Device	Device Name	Device Code (HEX)	Address Code
	0R	0010	
	1/0R	0110	
	2/0R	0210	Word Address
	3/0R	0310	
	4/0R	0410	
	1R	0011	
	1/1R	0111	
	2/1R	0211	Word Address
	3/1R	0311	
	4/1R	0411	
	2R	0012	
	1/2R	0112	
File Register	2/2R	0212	Word Address
(0R-31R)	3/2R	0312	
	4/2R	0412	
	:	:	:
	30R	002E	
	1/30R	012E	
	2/30R	022E	Word Address
	3/30R	032E	
	4/30R	042E	
	31R	002F	
	1/31R	012F	
	2/31R	022F	Word Address
	3/31R	032F	
	4/31R	042F	
Motion Register (#)	2/%MR	0234	
	3/%MR	0334	Word Address
	4/%MR	0434	

# 8 Error Messages

Error messages are displayed on the screen of Display as follows: "No.: Device Name: Error Message (Error Occurrence Area)". Each description is shown below.

Item	Description		
No.	Error No.		
Device Name	Name of External Device where error occurs. Device name is a title of External Device set with GP-Pro EX.(Initial value [PLC1])		
Error Message	Displays messages related to the error which occurs.		
Error Occurrence Area	Displays IP address or device address of External Device where error occurs, or error codes received from External Device.		
	<ul> <li>NOTE</li> <li>IP address is displayed such as "IP address (Decimal): MAC address (Hex)".</li> <li>Device address is displayed such as "Address: Device address".</li> <li>Received error codes are displayed such as "Decimal [Hex]".</li> </ul>		

Display Examples of Error Messages

"RHAA035: PLC1: Error has been responded for device write command (Error Code: 2 [02H])"



- Refer to your External Device manual for details on received error codes.
- Refer to "Display-related errors" in "Maintenance/Troubleshooting Guide" for details on the error messages common to the driver.