

32



Symbol Registration

32.1	Symbol and Symbol Sheet.....	32-2
32.2	Registering Symbols on a Symbol Sheet.....	32-5
32.3	Sharing Symbols on the Entire Network	32-26
32.4	Copying to a Symbol Sheet in Another Network Project File	32-28
32.5	Checking Registered Symbols	32-32
32.6	Setting Guide	32-34
32.7	Restrictions	32-41

32.1 Symbol and Symbol Sheet

32.1.1 What is a Symbol?

You can collectively register each device data used inside the display unit and Device/PLC, or variable information used in the logic program as "Symbol".


A symbol is a "Variable" to control all data at once such as device address and data type, etc. and 'Pro-Server EX' reads and writes each device data through the registered symbol.

Since you can set the device address directly on 'Pro-Studio EX', symbol registration is not essential. When you wish to change all device data at once, however, it is recommended to use symbols as much as possible for easier maintenance.

The data included in a symbol are: Symbol name, Device address, Data type, Number of data etc.

NOTE

- The contents can be confirmed easily if a symbol has a concrete symbol name ("Maximum number of rotation", "Minimum number of rotation", etc.)



- You can use the system variables (HMI system variables and logic system variables) that is predefined in 'GP-Pro EX'. For details, refer to the GP-Pro EX Reference Manual.

■ 'GP-Pro EX' Variables

◆ Variables created with a logic program

- Variable format

Variables registered by a user with optional names. To use these variables, import a screen project file (*.PRX) created with 'GP-Pro EX'.

For details on importing, refer to "31.3 Getting Data from a Screen Project File (PRX)".

- Address format

Variables automatically assigned to a device in the 'GP-Pro EX'. You do not need to import a screen project file (*.PRX) of 'GP-Pro EX', because 'Pro-Server EX' prepares these variables in advance.

NOTE


- When defining logic addresses, in 'GP-Pro EX' you would set [Device/PLC] to [#LOGIC], however, in 'Pro-Server EX' you set [Device Name] to [#INTERNAL].

For restrictions of the variables created with the logic program, refer to "32.7 Restrictions".

◆ System variables

Variables having the predefined functions on the 'GP-Pro EX'. You do not need to import a screen project file (*.PRX) of 'GP-Pro EX', because 'Pro-Server EX' prepared these variables in advance.

When setting up ACTION or trigger condition, system variables on 'GP-Pro EX' are displayed when you select "#INTERNAL", which is the internal device of a display unit, in [Device Name] and click the list button of [Device Address].




NOTE

- For details about variables on the 'GP-Pro EX', refer to the "GP-Pro EX Reference Manual".
- In Pro-Server EX, you cannot use 'GP-Pro EX' system variables with names that begin with "[PLC*]H#_".

32.1.2 What is a Symbol Sheet?

Symbols are controlled collectively on each Device/PLC. This control unit is called a "Symbol Sheet".

You can create more than one symbol sheet, and symbol control is possible per sheet in accordance with the intended use.



NOTE

- You can register 1500 symbols at maximum, in one symbol sheet. When the number of symbols exceed 1500, add a new symbol sheet to register.

☞ "32.2.5 Adding Symbol Sheets"


- When editing symbols, you can set up to always check the entered address range.

☞ "34.3 Option Settings"

32.2 Registering Symbols on a Symbol Sheet


32.2.1 Registering Symbols



Company A's Device/PLC




This section describes how to register symbols taking the above case as an example.

- 1 Click the [Symbol] icon on the status bar.







- 3 Enter "Temperature 1" as a symbol name in the [Symbol] field on the symbol sheet.



- 4 Click the [Data Type] field and select the data type from the displayed list.




- Click the button that appears by clicking the [Device Address] field, and enter "D50" as a device address to be registered as a symbol. Then click the [Ent] button.



NOTE

- You can also enter the device address directly.
- When the variable created with a logic program (#I_****, #Q_****) it inputs, after selecting "#internal" sheet of Device/PLC which uses variable in tree indication on the right screen input.

- Repeat the above steps (Step 1 to 5) to register the symbol "Valve 1" in the same way.



This is the end of the symbol registration to the symbol sheet.

NOTE

- You can edit the contents of the registered symbols.
Click [Symbol], [Consecutive] or [Device Address] and edit the contents on the "Edit Symbol" screen.




"32.6.2 "Edit Symbol" Screen"

32.2.2 Registering Sequential Devices

■ Registering sequential addresses individually as symbols

To perform symbol registration continuously for sequential device addresses, you can register these addresses together without specifying each address individually.



This section describes how to register the symbols of sequential addresses taking the above case as an example.

- 1 Register the device address "D50" with the symbol name "Temperature 1".

ng Help

Symbol Feature Save Transfer Monitor Status

Node Name: AGP1 Device Name: PLC1

Sheet Name: Sheet3 ☐ Set it as a global symbol sheet.

Symbol	Data Type	Consecutive	Device Address	No. of Data	Comment
Temperature1	16Bit(Signed)		D0050	1	
				1	
				1	
				1	
				1	

For the detailed procedure, please refer to Step 1 to 5 in "32.2.1 Registering Symbols".

2 Then, register the device address "D51" as a symbol.

Click the [Symbol] field in the next row of "Temperature 1", and enter "Temperature 2" as a symbol name.

Symbol	Data Type	Consecutive	Device Address	No. of Data	Comment
Temperature1	16Bit(Signed)		D0050	1	
Temperature2				1	
				1	
				1	
				1	
				1	

3 Click the [Consecutive] field.

A panel to specify the continuous attribute appears.

The next device address "D0051" to the symbol "Temperature 1" is indicated on the left of this panel.

Symbol	Data Type	Consecutive	Device Address	No. of Data	Comment
Temperature1	16Bit(Signed)		D0050	1	
Temperature2				1	
				1	
				1	
				1	
				1	

Consecutive

Release

+ D0051

Cancel

0 D0050.00

1 D0050.01

2 D0050.02


3 D0050.03

4 D0050.04


5 D0050.05

6 D0050.06

4 Select [+ D0051] as a sequential device address.




"+", indicating the device continuance, appears in the [Consecutive] field and the device address "D51" is displayed in gray.



NOTE • When symbols are continuously registered, the symbol data type specified at the first setting is automatically input in the [Data Type] field.

5 Repeat Step 2 to 4 to set the next symbol.



ng Help

Symbol >> Feature >> Save >> Transfer Monitor Status

Node Name: AGP1 Device Name: PLC1


Sheet Name: Sheet3 ☒ Set it as a global symbol sheet.

Symbol	Data Type	Consecutive	Device Address	No. of Data	Comment
Temperature1	16Bit(Signed)		D0050	1	
Temperature2	16Bit(Signed)	+	D0051	1	
Temperature3	16Bit(Signed)	+	D0052	1	
				1	
				1	
				1	
				1	

Now, the sequential devices addressed "D50", "D51" and "D52" have been registered individually as symbols.

■ Registering sequential addresses collectively as a symbol

You can register sequential device addresses as one symbol by specifying the number of devices.



This section describes how to register the symbols of sequential addresses taking the above case as an example.

- 1 Enter "Temperature Data" as a symbol name in the [Symbol] field on the symbol sheet.

ng Help


Symbol Feature Save Transfer Monitor Status

Node Name AGP1 Device Name PLC1


Sheet Name Sheet3 ☒ Set it as a global symbol sheet.

Symbol	Data Type	Consecutive	Device Address	No. of Data	Comment
TemperatureData				1	
				1	
				1	
				1	
				1	
				1	

- Click the [Data Type] field and select the data type from the displayed list.



- Click the button that appears by clicking the [Device Address] field, and enter "D50" as a start device address to be registered as a symbol. Then click the [Ent] button.



4 Enter the number of sequential device addresses "3" in [No. of Data].

Help

Symbol >> Feature >> Save >> Transfer

Node Name: AGP1 Device Name: PLC1

Sheet Name: Sheet3 ☒ Set it as a global symbol sheet.

Symbol	Data Type	Consecutive	Device Address	No. of Data	Comment
TemperatureData	16Bit(Signed)		D0050	3	
				1	
				1	
				1	
				1	
				1	

Now, the sequential devices addressed "D50", "D51" and "D52" have been registered collectively as one symbol.

When you register the next symbol, the address following the last address input in Step 4 (in this case, "+D0053") is displayed on the continuous attribute panel that is displayed by clicking the [Consecutive] field.

Help

Symbol >> Feature >> Save >> Transfer

Node Name: AGP1 Device Name: PLC1

Sheet Name: Sheet3 ☐ Set it as a global symbol sheet.

Symbol	Data Type	Consecutive	Device Address	No. of Data	Comment
TemperatureData	16Bit(Signed)		D0050	1	

Consecutive

Release

+ D0051


Cancel

- 0 D0050.00
- 1 D0050.01
- 2 D0050.02
- 3 D0050.03
- 4 D0050.04
- 5 D0050.05
- 6 D0050.06

32.2.3 Registering Bit Offset Symbols

When "Word type" is specified as a symbol data type, you may find a symbol of which word device is specified as a word-type symbol first, and the bit of the particular position among such word devices is specified with the offset number beginning with 0. This symbol is called "Bit offset symbol".

For instance, the device address "D50" in the figure below has the error information of Line A. (This device address is the "Parent device".) When the first bit has the "Speed Error" information and the 11th bit has the "Abnormal Temperature" information as further information, you can symbolize particular bits by specifying the bit offset.


NOTE

- When you specify the bit offset, the symbol data type is "Bit" type.
- 32-bit device (Integer_Variables) can be accessed in bit unit.
Add "single space + Xm" following the variable to allow you to access it in bit unit.
Example) When accessing the 7th bit of Integer_Variables
Integer_Variables.X6
- When the data type of the parent device is BCD or String type, bit offset symbols cannot be used.

This section describes how to register bit offset symbols taking the above case as an example.

- 1 Specify "Line A_Error Information" as a device address of "Parent Device".

Help | Symbol | Feature | Save | Transfer | Monitor Status

Node Name: AGP1 Device Name: PLC1

Sheet Name: Sheet3 ☐ Set it as a global symbol sheet.

Symbol	Data Type	Consecutive	Device Address	No. of Data	Comment
LineAErrorInformation	16Bit(Signed)		D0050	1	
				1	
				1	
				1	
				1	
				1	
				1	

For the detailed procedure, please refer to Step 1 to 5 in "32.2.1 Registering Symbols".

- 2 Enter the bit offset symbol name "Speed Error" in the [Symbol] field.

Help | Symbol | Feature | Save | Transfer | Monitor Status


Node Name: AGP1 Device Name: PLC1

Sheet Name: Sheet3 ☐ Set it as a global symbol sheet.


Symbol	Data Type	Consecutive	Device Address	No. of Data	Comment
LineAErrorInformation	16Bit(Signed)		D0050	1	
SpeedError				1	
				1	
				1	
				1	
				1	
				1	

3 Click the [Consecutive] field.

A panel to specify the continuous attribute appears.



4 Double-click the target offset (in this case "D0050.01") from the list on the right of the continuous attribute panel.



"01" indicating "Offset" is entered in the [Consecutive] field.

The screenshot shows a software window titled "Symbol Sheet" with a menu bar (Help, Symbol, Feature, Save, Transfer) and a toolbar. Below the menu bar, there are input fields for "Node Name" (AGP1), "Device Name" (PLC1), and "Sheet Name" (Sheet3). A checkbox "Set it as a global symbol sheet." is present. The main area contains a table with the following columns: Symbol, Data Type, Consecutive, Device Address, No. of Data, and Comment.

Symbol	Data Type	Consecutive	Device Address	No. of Data	Comment
LineAErrorInformation	16Bit(Signed)		D0050	1	
SpeedError	Bit	01	D0050.01	1	
				1	
				1	
				1	
				1	
				1	

5 Repeat the above steps (Step 2 to 4) to register the symbol "Abnormal Temperature" in the same way.

The screenshot shows the same software window as the previous one, but with an additional entry in the table. The "Consecutive" field for the new entry is circled in red.


Symbol	Data Type	Consecutive	Device Address	No. of Data	Comment
LineAErrorInformation	16Bit(Signed)		D0050	1	
SpeedError	Bit	01	D0050.01	1	
AbnormalTemperature	Bit	11	D0050.11	1	
				1	
				1	
				1	
				1	

This is the end of the registration of bit offset symbols into the symbol sheet.

32.2.4 Inserting and Deleting Rows on a Symbol Sheet


■ Row Insertion

- 1 Select the row just below the place where you want the new one inserted.




NOTE • To insert more than one row, select the number of rows you want to insert by dragging the mouse.

- 2 Click [Insert] button in [Symbol].




The selected row(s) is displaced by the newly inserted row(s) and shifted down.




■ Deleting Specified Rows on a Symbol Sheet


- 1 Select the row you wish to delete.




- 2 Click [Delete] button in [Symbol].



- 3 The "Delete Symbol" screen appears. Click [Yes] button.



The specified row is deleted.



32.2.5 Adding Symbol Sheets


You can create multiple symbol sheets for one entry node.

Registering symbols for purposes allows you to smooth the handling of symbol information.


This section describes addition of symbol sheets.

NOTE • You can add 140 sheets at maximum, for one entry node.


- 1 Click [Add] button in [Symbol Sheet].



- 2 The "Add Symbol Sheet" screen appears. Click the list button of [Node Name] or [Device Name] to select the node or device where you want to add a symbol sheet.



- 3 Enter a symbol sheet name to be added in [Sheet Name]. (By default, the sheet name is "Sheet [No.]").




32-24


[illegible]

■ Deleting Symbol Sheets

- 1 Select the symbol sheet you wish to delete from the list on the left of the screen.



- 2 Click [Delete] button in [Symbol Sheet].



The selected symbol sheet is now deleted.


32.3 Sharing Symbols on the Entire Network

32.3.1 What is a Global Symbol?

'Pro-Server EX' allows the same type of Device/PLC to share a symbol. This symbol is called a "Global symbol". Also, a symbol sheet consisting of such global symbols is called a "Global symbol sheet". You can commonly use a same global symbol sheet in all the registered Device/PLCs.

When you register the symbol sheet "Error Information" of "Manufacturer A_Device/PLC 1" as a global symbol sheet, for instance, this "Error Information" symbol is also registered for multiple same Device/PLCs.

Thus, even if many entry nodes are registered on the network, preparing one global symbol sheet saves you creating new symbol sheets as long as the contents are the same.



NOTE

- Global symbols should be registered per symbol sheet.
- You can use global symbols commonly between different entry nodes, but the Device/PLCs should be of the same type.


32.3.2 Registering as a Global Symbol

This section describes how to register a global symbol.

- 1 Register a symbol on the symbol sheet.
- 2 Check [Set it as a global symbol sheet] on the right of the screen.




The created symbol sheet is now registered as a global symbol sheet, with the name displayed in "Global symbol" in the tree display on the left of the screen.



NOTE


- To cancel the registration of the global symbol sheet, uncheck [Set it as a global symbol sheet].

- 1 Move the mouse pointer on the symbol sheet, and press the [Ctrl] and [A] keys to select the copy-source symbol sheet.




Pro-Server EX Reference Manual

2 Click the [Copy] button in [Symbol].




NOTE • You can also select it from the menu list displayed by right-clicking the mouse.


3 Select [Open] from [File] menu.



The "Open File" screen appears.




- 4 Select a copy-destination network project file, and click the [Open] button.




The selected network project file opens.

- 5 Click [Symbol] on the status bar.



- 6 Select the copy-destination symbol sheet.



NOTE • You can also select it from the menu list displayed by right-clicking the mouse.



NOTE • When the Device/PLCs are not of the same type, error may occur due to the difference of their

In this case, the following lemma follows:


32.5 Checking Registered Symbols

When many symbols are registered in a symbol sheet, you might register the symbol names or device addresses mistakenly in duplication. In this case, 'Pro-Server EX' does not operate properly.


Thus 'Pro-Studio EX' has a function to check the registration duplication in advance. This function also displays/outputs the results of duplication check in a CSV file.

This section describes how to check duplication of symbol names or device addresses.


- 1 Display the symbol sheet you wish to check.
- 2 Click [Check Duplication/List Used Addresses] button.




The "Check Duplication/List Used Addresses" screen appears.



3 Specify the storage location and enter the file name to which the results are output. Then click [Save] button.



The check results are now displayed and saved as a CSV file into the specified storage location.



The check results are output in the following format:

[Node Name] and [Device/PLC]

Displays the names of the entry node and Device/PLC having the symbol sheet that has been checked.

[Symbol Duplication Check]

Displays the overlapped symbol names.


Will be blank if there is no name overlapped.

[Duplication Mark], [Start Address], [End Address], [Symbol Sheet Name], [Data Type] and [Symbol Name]

Symbol check data is displayed in the order above. The symbols are sorted by [Start Address]. The overlapped symbols are indicated in [Duplication Mark] as "ERR".

32.6 Setting Guide

32.6.1 Symbol Registration Screen



Setting item		Setting content
Symbol	Group	Group registered symbols. Refer to "29.3 Grouping Symbols" for more details.
	Ungroup	Ungroup grouped symbols.
	Insert	Insert a row directly above a selected row on a symbol sheet.
	Delete	Delete selected rows on a symbol sheet.
	Copy	Copy selected rows on a symbol sheet.
	Cut	Cut selected rows on a symbol sheet.
	Paste	Paste to a symbol sheet the contents being copied or cut. When one row is selected, the copied or cut contents are inserted in the row directly above the specified row. When multiple rows are selected, the copied or cut contents are displaced with the selected cells deleted.
Symbol Sheet	Add	Add symbol sheets to the registered Device/PLCs. Clicking this button displays the "Add symbol sheet" dialog box. Specify [Node Name], [Device Name] and [Sheet Name].
	Delete	Delete a specified symbol sheet.
Check Duplication/List Used Addresses		Check duplication of symbol names and device addresses. Refer to "32.5 Checking Registered Symbols" for more details.
Global Constant Setting Screen		Displays the "Global Constant Setting" screen. Refer to "32.6.3 Global Constant Setting" for more details.

Setting item	Setting content																																								
Node Name	Displays the node name holding the symbol sheet currently displayed.																																								
Device Name	Displays the device name holding the symbol sheet currently displayed.																																								
Sheet Name	Displays the name of the symbol sheet currently displayed. You can change the sheet name.																																								
Set it as a global symbol sheet	Regard the symbol sheet currently displayed as a global symbol sheet. Refer to "32.3 Sharing Symbols on the Entire Network" for more details.																																								
Symbol	Enter the symbol you wish to register. NOTE • Must be entered at maximum 32 Unicode characters. • Cannot begin with a number.																																								
Data Type	Select the type of the symbol to be registered. Clicking the [Data Type] field displays a data type list. The following data types are available. • Bit • 8 bits (Signed decimal, unsigned decimal, hexadecimal, BCD) • 16 bits (Signed decimal, unsigned decimal, hexadecimal, BCD) • 32 bits (Signed decimal, unsigned decimal, hexadecimal, BCD) • Single-precision floating point • Double-precision floating point • Character string • TIME • TIME_OF_DAY • DATE • DATE_AND_TIME NOTE • You can set 8 bits, TIME, TIME_OF_DAY, or DATE when using tags. • When using a tag, when you select a [Device Address], the [Data Type] is automatically set. • When using a tag, you cannot specify the data type. • You cannot register text string tags as a symbol.																																								
Consecutive	Displays a continuous attribute panel if symbols have been already set. Select a sequential device address or offset of bit type. When a sequential device address is selected, "+" appears indicating the device continuance; when the offset is selected, offset value appears. • Sequential specification <table><tr><th>Symbol</th><th>Data Type</th><th>Consecutive</th><th>Device Address</th><th>No. of Data</th></tr><tr><td>Temperature1</td><td>16Bit(Signed)</td><td></td><td>D0050</td><td>1</td></tr><tr><td>Temperature2</td><td>16Bit(Signed)</td><td>+</td><td>D0051</td><td>1</td></tr><tr><td></td><td></td><td></td><td></td><td>1</td></tr></table> • Offset specification <table><tr><th>Symbol</th><th>Data Type</th><th>Consecutive</th><th>Device Address</th><th>No. of Data</th></tr><tr><td>LineA_Error</td><td>16Bit(Signed)</td><td></td><td>D0050</td><td>1</td></tr><tr><td>SpeedError</td><td>Bit</td><td>01</td><td>D0050.01</td><td>1</td></tr><tr><td></td><td></td><td></td><td></td><td>1</td></tr></table>	Symbol	Data Type	Consecutive	Device Address	No. of Data	Temperature1	16Bit(Signed)		D0050	1	Temperature2	16Bit(Signed)	+	D0051	1					1	Symbol	Data Type	Consecutive	Device Address	No. of Data	LineA_Error	16Bit(Signed)		D0050	1	SpeedError	Bit	01	D0050.01	1					1
Symbol	Data Type	Consecutive	Device Address	No. of Data																																					
Temperature1	16Bit(Signed)		D0050	1																																					
Temperature2	16Bit(Signed)	+	D0051	1																																					
				1																																					
Symbol	Data Type	Consecutive	Device Address	No. of Data																																					
LineA_Error	16Bit(Signed)		D0050	1																																					
SpeedError	Bit	01	D0050.01	1																																					
				1																																					

Setting item	Setting content
Device Address	Specify the start address of the device to be specified as a symbol. When [Consecutive] is selected, the address is automatically displayed.
No. of Data	Specify the number of devices to be specified as symbols. (The default value is "1".) You can enter the preset global constant by clicking the list button. Refer to "32.6.3 Global Constant Setting" about global constants. NOTE You can set the number of data up to 2040.
Comment	You can enter necessary information like the meanings of symbols as comments, if any.


32.6.2 "Edit Symbol" Screen

Setting item	Setting content
Symbol Name	Enter the symbol name you wish to register. NOTE • Must be entered at maximum 32 Unicode characters. • Cannot begin with a number.
Symbolize Address	Input a symbol name automatically from the device address and data type. A symbol name is to be input as follows: Ex.) In the case of the device address "D50" and the data type "Word": _D50_WORD
Address	Enter the (start) device address.
Data Type	Select the data type of device: If [8 bits],[16 bits] or [32 bits] is selected, specify the attribute: [Signed Decimal], [Unsigned Decimal], [Hexadecimal], [BCD]. NOTE • You can set 8 bits, TIME, TIME_OF_DAY, or DATE when using tags. • When using a tag, when you select a [Device Address], the [Data Type] is automatically set. • When using a tag, you cannot specify the data type. • You cannot register text string tags as a symbol.
Consecutive	Check this if the device addresses are sequential.
Offset	Select an offset value by clicking the list button. 16 bits: from 0 to 15 32 bits: from 0 to 31
No.	Specify the number of devices to be specified as symbols. (The default value is "1".) You can enter the preset global constant by clicking the list button. Refer to "32.6.3 Global Constant Setting" about global constants. NOTE • You can set the number up to 2040.


Setting item	Setting content
<	Displays the symbol setting of the upper row.
>	Displays the symbol setting of the lower row.
Continuous Insertion	Set the sequential device address or offset address-added symbol in the next row of the symbol sheet with the current set contents. NOTE • When the symbol name is specified in [Symbolization of Address], the values following the device address and data type are automatically changed. • "+" appears in the [Consecutive] field on the symbol sheet.

32.6.3 Global Constant Setting

By registering the data number of symbols as a "Global constant", you can change all the data numbers at once by changing the constant when such a change has been made to the system as changing a symbol data number.



To set a global constant, click the [Global Constant Setting Screen] button on the symbol registration screen.



Setting item	Setting content
Constant Name	Enter the name of the constant to be set.
Value	Enter a constant. NOTE The valid values range from 1 to 4096.
Comment	You can enter necessary information like the meanings of constants as comments, if any.
Copy	Copy the global constant in a selected row.
Cut	Cut the global constant in a selected row.
Paste	Insert a copied or cut global constant to the row directly above a selected one.
Insert	Insert a row directly above a selected row on a symbol sheet.
Delete	Delete a selected row.

32.7 Restrictions

■ Symbol whose data type is undefined

When you import a screen project file of 'GP-Pro EX' or 'GP-PRO/PBIII for Windows', the word symbols in the project file are to be imported as an undefined data type of symbol.

- Use with 'Pro-Studio EX'

To use an undefined data type of symbol with 'Pro-Studio EX', you are requested to input the data type. (When you use a defined symbol, data type entry is not available.)

- Use with Pro-Server API

There are 2 types of Pro-Server API: API requiring separate specification of data type and that requiring no specification.

API type	Description
With separate specification	This API prioritizes the data type separately specified over the symbol data type.
Without specification	When the specified symbol is a 16-bit device, the symbol becomes 16-bit signed; when the specified symbol is a 32-bit device, it becomes 32-bit signed.

- When MES ACTION is specified

If you select a symbol where the data type is undefined when MES ACTION is specified, the data type and the number of data are fixed to [16Bit(Signed)] and [No.: 1], respectively.

■ Maximum number of data

The following table shows the maximum number of data settable according to the symbol type.

Symbol type	No. of data
Bit symbol	255
Bit offset symbol	1
8-bit signed symbol	1020
8-bit unsigned symbol	1020
8-bit BCD symbol	1020
8-bit HEX symbol	1020
16-bit signed symbol	1020
16-bit unsigned symbol	1020
16-bit BCD symbol	1020
16-bit HEX symbol	1020
32-bit signed symbol	510
32-bit unsigned symbol	510
32-bit BCD symbol	510
32-bit HEX symbol	510
Single-precision floating point symbol	510
Double-precision floating point symbol	255
Character string symbol	255
TIME	510
TIME_OF_DAY	510
DATE	510
DATE_AND_TIME	255
(Data type is "Undefined")	1

■ Symbol whose data number is undefined

The data number of the following symbols is regarded as "Undefined".

- Symbols created by importing a screen project file of 'GP-Pro EX' or 'GP-PRO/PBIII for Windows'.
- Symbols created by converting a network project file made by the old version of 'Pro-Server'.
- Symbols whose data number has not been specified in the symbol setting.

- Use with 'Pro-Studio EX'

To use an undefined data type of symbol with 'Pro-Studio EX', you are requested to input the data type. (When you use a defined symbol, data type entry is not available.)

- Use with Pro-Server EX API

Such symbols are regarded as a symbol of which data number is "1".

■ About the system variables of "GP-Pro EX"

The device quantity of one system variable of 'GP-Pro EX' basically as 1 is handled even with 'Pro-Server EX', but "#L_IOInfo" and "#L_IOStatus" is handled as 4.

■ Global Symbol Sheets Settings

If you specify any of the following protocol devices in a global symbol sheet, the project file specified on the entry nodes setting screen for the node must meet the requirements below:

- Manufacture: Rockwell Automation, Inc
- Device Type: EtherNet/IP
- Device Setting: ControlLogix/CompactLogix Series Native

*Requirements

The same IOI file (Data tag definition file) must be set for both the node where the global symbol sheet is specified and the node that references that global symbol sheet. You specify the IOI file in the 'GP-Pro EX' Device/PLC setting.