

33




Trigger Conditions

| | | |
|------|---|-------|
| 33.1 | What is a Trigger Condition?..... | 33-2 |
| 33.2 | Editing Trigger Conditions..... | 33-38 |
| 33.3 | Deleting Trigger Conditions..... | 33-40 |
| 33.4 | Sequential Execution of Multiple Data Transfers and ACTIONS with One Trigger Condition..... | 33-41 |
| 33.5 | Executing ACTION under Multiple Trigger Conditions..... | 33-51 |

33.1 What is a Trigger Condition?


'Pro-Server EX' performs many operations such as data transfer and ACTION at various timings and cycles. This timing or cycle is called as a "Trigger condition".

You can set multiple trigger conditions at one time, set new conditions and use them in combination with the existing ones.




The set contents of "Trigger conditions" to be specified on 'Pro-Server EX' are as follows:

< For data transfer >




< For ACTION >



■ Types of trigger conditions

Specify the timing or cycle for data transfer and ACTION execution.

Trigger conditions are available of 12 types for 'Pro-Server EX' (8 types for GP Series).

 "33.1.1 Types of Trigger Conditions"

■ Data received by ACTION (ACTION)

Specify the device data or fixed number received from the transfer source when the trigger conditions become effective.

 "33.1.2 Data Received by ACTION"


■ Action operating node/Implementation notice (ACTION)

Specify the entry node operating the specified ACTION (normally a personal computer). When the ACTION is implemented, moreover, it is possible to notify the ACTION implementation by setting the notified destination (Bit on).

 "33.1.3 ACTION Nodes"

■ Device of Transfer source/Transfer destination (Data transfer)

Specify the device of the data transfer source and destination when the trigger conditions become effective.


 "19.1.1 Distributing Data"

 "19.1.2 Collecting Data"


Normally, trigger conditions are to be set in the process of setting data transfer and ACTION, but you can set the trigger conditions separately for the ACTION and data transfer setting. In addition, it is possible to register multiple trigger conditions, change these conditions (See the next step.) and use them in combination with other conditions.

As a result, one trigger condition allows multiple data transfer and multiple ACTION execution, and multiple trigger conditions perform one ACTION execution easily.

Execute Multiple Data Transfer by One Trigger Condition/ACTION



Execute One ACTION by Multiple Trigger Conditions



NOTE • As for the data transfer, specification of multiple trigger conditions is not available.

33.1.1 Types of Trigger Conditions

On 'Pro-Studio EX', you can specify the following trigger conditions:


| Trigger condition | Description |
|---|--|
| Power ON | Provides only once when the power of provider node is turned ON. |
| ON Time | Provides only once at the specified time. |
| Constant Cycle | Provides at the specified cycle. |
| At Device Change | Provides when the device data of the specified symbol is changed. |
| While Device On/Off | Provides while the device of the specified symbol is On or Off. You can also specify the execution timing and check cycle. |
| At Device On/Off | Provides when the device of the specified symbol turns On or Off. You can also specify the execution timing and check cycle. |
| While/When conditional expression satisfied (Excluding the case that the node is GP Series) | Provides while the conditional expression that has been specified is satisfied between 2 devices. (Ex.: Device A and B have the same data value.) You can also specify the execution timing and check cycle. |
| When partner node turned On/Off (Excluding the case that the node is GP Series) | Provides only once when the specified partner node is turned On or Off. |

■ Power ON

Provides only once when the power of provider node is turned ON.

NOTE

- Provides also when:
 - 'Pro-Server EX' is executed and loaded;
 - A network project file is reloaded; and
 - The provider is changed to online mode from offline mode.



| Setting item | Setting content |
|---------------------------|---|
| No items to be specified. | |
| Detail Settings | The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details. |

■ ON Time

Provides only once at the specified time.

Condition 1

Specify the Trigger Condition.

| | | | | | |
|--|---------------------|--|---------------------|--|---------------------------|
| | When Turned ON | | While Device is ON | | While Condition Satisfied |
| | Specified Time | | While Device is OFF | | When Condition Satisfied |
| | Constant Cycle | | When Device ON | | When Partner Node ON |
| | When Device Changes | | When Device OFF | | When Partner Node OFF |

Specified Time hour min


Detail Settings OK Cancel

| Setting item | Setting content |
|-----------------|--|
| Specified Time | Specify the executing timing. |
| Detail Settings | The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details. |

■ Constant Cycle

Provides at the specified cycle.

You can also specify the period for execution.



| Setting item | Setting content |
|--------------------|--|
| Cycle | Enter the providing cycle (ms). You can specify the cycle in the range from 0 to 86400000 (24 hours). |
| Limited Time Offer | If you wish to limit the period, check this and specify the period (hr/min). |
| Detail Settings | The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details. |

■ At Device Change

Provides when the device data of the specified symbol is changed.

You can also specify the execution timing and check cycle.

Condition 1

Specify the Trigger Condition.

When Turned ON While Device is ON While Condition Satisfied

Specified Time While Device is OFF When Condition Satisfied

Constant Cycle When Device ON When Partner Node ON

When Device Changes When Device OFF When Partner Node OFF

Device Name: #INTERNAL

Device Address: [Calculator icon]

Data Type: 16Bit(Signed)



Limited Time Offer


hour min hour min

Check Cycle Always

500 ms

Detail Settings OK Cancel


| Setting item | Setting content |
|----------------|--|
| Device Name | Select the device name having the subjected device. |
| Device Address | <p>Sets the device address or symbol to be used.</p> <ul style="list-style-type: none"> When specifying a device address: Enter directly from the Calculator icon. <p>Calculator icon</p>  <ul style="list-style-type: none"> When specifying a symbol: Select the symbol by clicking the list button. <p>List button</p>  |



| Setting item | Setting content |
|---------------------------|---|
| <p>Data Type</p> | <ul style="list-style-type: none"> When specifying a device address: Specify the data type.  <ul style="list-style-type: none"> When specifying a symbol or tag: Data type automatically appears. <p>NOTE</p> <ul style="list-style-type: none"> You can set up 8 bit, TIME, TIME_OF_DAY, or DATE when using tag. Set up is not possible when the trigger condition is set up with a DATE_AND_TIME device. |
| <p>Limited Time Offer</p> | <p>If you wish to limit the period, check this and specify the period (hr/min).</p> |
| <p>Check Cycle</p> | <p>Specify the cycle to check change of the device data (ms). You can specify the cycle in the range from 0 to 86400000 (24 hours). For constant check, check [Always].</p> <p>NOTE</p> <ul style="list-style-type: none"> When there are many trigger conditions, of which check cycle is specified as [Always], in one node, entire system performance may drop down. |
| <p>Detail Settings</p> | <p>The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details.</p> |


■ While Device On

Provides while the device of the specified symbol is On.

You can also specify the execution timing and check cycle.



| Setting item | Setting content |
|----------------|---|
| Device Name | Select the device name having the subjected device. |
| Device Address | <p>Sets the device address or symbol to be used.</p> <ul style="list-style-type: none"> When specifying a device address: Enter directly from the Calculator icon. <p style="text-align: center;">Calculator icon</p>  <ul style="list-style-type: none"> When specifying a symbol: Select the symbol by clicking the list button. <p style="text-align: right;">List button</p>  |


| Setting item | Setting content |
|---------------------------|---|
| <p>Data Type</p> | <ul style="list-style-type: none"> When specifying a device address: Specify the data type.  <ul style="list-style-type: none"> When specifying a symbol or tag: Data type automatically appears. <p>NOTE</p> <ul style="list-style-type: none"> You can set up 8 bit, TIME, TIME_OF_DAY, or DATE when using tag. Set up is not possible when the trigger condition is set up with a DATE_AND_TIME device. |
| <p>Limited Time Offer</p> | <p>If you wish to limit the period, check this and specify the period (hr/min).</p> |
| <p>Check Cycle</p> | <p>Specify the cycle to check change of the device data (ms). You can specify the cycle in the range from 0 to 86400000 (24 hours). For constant check, check [Always].</p> <p>NOTE</p> <ul style="list-style-type: none"> When there are many trigger conditions, of which check cycle is specified as [Always], in one node, entire system performance may drop down. |
| <p>Detail Settings</p> | <p>The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details.</p> |

■ While Device OFF

Provides while the device of the specified symbol is Off.

You can also specify the execution timing and check cycle.

| Setting item | Setting content |
|----------------|--|
| Device Name | Select the device name having the subjected device. |
| Device Address | <p>Sets the device address or symbol to be used.</p> <ul style="list-style-type: none"> When specifying a device address: Enter directly from the Calculator icon. <div style="text-align: center;"> </div> <ul style="list-style-type: none"> When specifying a symbol: Select the symbol by clicking the list button. <div style="text-align: center;"> </div> |


| Setting item | Setting content |
|---------------------------|---|
| <p>Data Type</p> | <ul style="list-style-type: none"> When specifying a device address: Specify the data type.  <ul style="list-style-type: none"> When specifying a symbol or tag: Data type automatically appears. <p>NOTE</p> <ul style="list-style-type: none"> You can set up 8 bit, TIME, TIME_OF_DAY, or DATE when using tag. Set up is not possible when the trigger condition is set up with a DATE_AND_TIME device. |
| <p>Limited Time Offer</p> | <p>If you wish to limit the period, check this and specify the period (hr/min).</p> |
| <p>Check Cycle</p> | <p>Specify the cycle to check change of the device data (ms). You can specify the cycle in the range from 0 to 86400000 (24 hours). For constant check, check [Always].</p> <p>NOTE</p> <ul style="list-style-type: none"> When there are many trigger conditions, of which check cycle is specified as [Always], in one node, entire system performance may drop down. |
| <p>Detail Settings</p> | <p>The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details.</p> |

■ At Device On

Provides when the device of the specified symbol turns On.

You can also specify the execution timing and check cycle.


| Setting item | Setting content |
|----------------|--|
| Device Name | Select the device name having the subjected device. |
| Device Address | <p>Specify the subjected device address or symbol.</p> <ul style="list-style-type: none"> When specifying a device address: Enter directly from the Calculator icon. <div style="text-align: center;"> </div> <ul style="list-style-type: none"> When specifying a symbol: Select the symbol by clicking the list button. <div style="text-align: center;"> </div> |



| Setting item | Setting content |
|---|---|
| Data Type | <ul style="list-style-type: none"> When specifying a device address: Specify the data type.  <ul style="list-style-type: none"> When specifying a symbol or tag: Data type automatically appears. <p>NOTE</p> <ul style="list-style-type: none"> You can set up 8 bit, TIME, TIME_OF_DAY, or DATE when using tag. Set up is not possible when the trigger condition is set up with a DATE_AND_TIME device. |
| Turn OFF the Specified Device Address after Processing. | Check this to turn off the subjected device or symbol after processing. |
| Limited Time Offer | Check this and specify the period (hr/min) to limit the period. |
| Check Cycle | <p>Specify the cycle to check change of the device data (ms). You can specify the cycle in the range from 0 to 86400000 (24 hours). For constant check, check [Always].</p> <p>NOTE</p> <ul style="list-style-type: none"> When there are many trigger conditions, of which check cycle is specified as [Always], in one node, entire system performance may drop down. |
| Detail Settings | <p>The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details.</p> |


■ At Device OFF

Provides when the device of the specified symbol turns Off.

You can also specify the execution timing and check cycle.




| Setting item | Setting content |
|----------------|--|
| Device Name | Select the device name having the subjected device. |
| Device Address | <p>Specify the subjected device address or symbol.</p> <ul style="list-style-type: none"> When specifying a device address: Enter directly from the Calculator icon. <div style="text-align: center;">  <p>Calculator icon</p> </div> <ul style="list-style-type: none"> When specifying a symbol: Select the symbol by clicking the list button. <div style="text-align: center;">  <p>List button</p> </div> |



| Setting item | Setting content |
|--|---|
| Data Type | <ul style="list-style-type: none"> When specifying a device address: Specify the data type.  <ul style="list-style-type: none"> When specifying a symbol or tag: Data type automatically appears. <p>NOTE</p> <ul style="list-style-type: none"> You can set up 8 bit, TIME, TIME_OF_DAY, or DATE when using tag. Set up is not possible when the trigger condition is set up with a DATE_AND_TIME device. |
| Turn ON the Specified Device Address after Processing. | Check this to turn on the subjected device or symbol after processing. |
| Limited Time Offer | To limit the period, check this and specify the period (hr/min.). |
| Check Cycle | <p>Specify the cycle to check change of the device data (ms). You can specify the cycle in the range from 0 to 86400000 (24 hours). For constant check, check [Always].</p> <p>NOTE</p> <ul style="list-style-type: none"> When there are many trigger conditions, of which check cycle is specified as [Always], in one node, entire system performance may drop down. |
| Detail Settings | <p>The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details.</p> |


■ While conditional expression satisfied (excluding the case that the node is GP Series)

Provides while the conditional expression that has been specified is satisfied between 2 devices. (Ex.: Device A and B have the same data value.)

You can also specify the execution timing and check cycle.




| Setting item | | Setting content |
|----------------------|----------------|--|
| Condition Expression | Device Name | Select the device name having the subjected device. |
| | Device Address | <p>Specify the subjected device address or symbol.</p> <ul style="list-style-type: none"> When specifying a device address: Enter directly from the Calculator icon. <div style="text-align: center;">  <p>Calculator icon</p> </div> <ul style="list-style-type: none"> When specifying a symbol: Select the symbol by clicking the list button. <div style="text-align: center;">  <p>List button</p> </div> |



| Setting item | | Setting content |
|----------------------|---|--|
| Condition Expression | Data Type | <ul style="list-style-type: none"> When specifying a device address: Specify the data type.  <ul style="list-style-type: none"> When specifying a symbol or tag: Data type automatically appears. <p>NOTE</p> <ul style="list-style-type: none"> When the data type is "Character String", the character string to be compared is 1 character. You can set up 8 bit, TIME_OF_DAY, or DATE when using tag. Set up is not possible when the trigger condition is set up with a DATE_AND_TIME device. |
| | Constant | To set a constant in the trigger condition, check this and specify the value. |
| | Expression Symbol | Select the symbols of the specified conditional expression. You can select "=", "<=", ">=", "<", ">" or "<>". |
| Limited Time Offer | To limit the period, check this and specify the period (hr/min.). | |
| Check Cycle | <p>Specify the cycle to check change of the device data (ms). You can specify the cycle in the range from 0 to 86400000 (24 hours). For constant check, check [Always].</p> <p>NOTE</p> <ul style="list-style-type: none"> When there are many trigger conditions, of which check cycle is specified as [Always], in one node, entire system performance may drop down. | |
| Detail Settings | The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details. | |


■ When conditional expression satisfied (excluding the case that the node is GP Series)

Provides when the conditional expression that has been specified is satisfied between 2 devices.

You can also specify the execution timing and check cycle.



| Setting item | | Setting content |
|----------------------|----------------|--|
| Condition Expression | Device Name | Select the device name having the subjected device. |
| | Device Address | <p>Specify the subjected device address or symbol.</p> <ul style="list-style-type: none"> When specifying a device address: Enter directly from the Calculator icon. <p style="text-align: center;">Calculator icon</p>  <ul style="list-style-type: none"> When specifying a symbol: Select the symbol by clicking the list button. <p style="text-align: center;">List button</p>  |

| Setting item | | Setting content |
|----------------------|-------------------|--|
| Condition Expression | Data Type | <ul style="list-style-type: none"> When specifying a device address: Specify the data type.  <ul style="list-style-type: none"> When specifying a symbol or tag: Data type automatically appears. <p>NOTE</p> <ul style="list-style-type: none"> When the data type is "Character String", the character string to be compared is 1 character. You can set up 8 bit, TIME, TIME_OF_DAY, or DATE when using tag. Set up is not possible when the trigger condition is set up with a DATE_AND_TIME device. |
| | Constant | To set a constant in the trigger condition, check this and specify the value. |
| | Expression Symbol | Select the symbols of the specified conditional expression. You can select "=", "<=", ">=", "<", ">" or "<>". |
| Limited Time Offer | | To limit the period, check this and specify the period (hr/min.). |
| Check Cycle | | Specify the cycle to check change of the device data (ms). You can specify the cycle in the range from 0 to 86400000 (24 hours). For constant check, check [Always]. |
| Detail Settings | | The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details. |

■ When partner node turned On (excluding the case that the node is GP Series)

Runs one time after the specified partner node turns on and communication is established. Also, runs one time after the provider restarts, or when communication is re-established after being disconnected.

NOTE • When the partner node turns on, a time lag may cause a slight delay in operations.


The screenshot shows a dialog box titled "Condition 1" with the instruction "Specify the Trigger Condition." Below this, there are nine buttons arranged in a 3x3 grid, each with a small icon and a text label. The buttons are: "When Turned ON", "While Device is ON", "While Condition Satisfied", "Specified Time", "While Device is OFF", "When Condition Satisfied", "Constant Cycle", "When Device ON", "When Partner Node ON", "When Device Changes", "When Device OFF", and "When Partner Node OFF". The "When Partner Node ON" button is highlighted with a red circle. Below the grid is a "Node" dropdown menu currently showing "PC1". At the bottom of the dialog are three buttons: "Detail Settings", "OK", and "Cancel".

| Setting item | Setting content |
|-----------------|--|
| Node | Select the name of the subjected node. |
| Detail Settings | The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details. |

■ When partner node turned Off (excluding the case that the node is GP Series)

Runs one time when the specified partner node turns off, or when communication with the partner node is disconnected.

NOTE • When the partner node turns off, a time lag may cause a slight delay in operations.



| Setting item | Setting content |
|-----------------|---|
| Node | Select the name of the subjected node. |
| Detail Settings | The "Set Trigger Condition Details" screen appears. Specify the methods of completion notification and communication. Refer to "◆ "Set Trigger Condition Details" Screen" for more details. |

◆ "Set Trigger Condition Details" Screen

Specify the method handling the processing results of specific ACTION executed by trigger conditions satisfied and communication method if the ACTION should be made.

You can specify the trigger condition individually.

Set Trigger Condition Details

Completion Notification

If the processing results of the specified action/data copies are required in the case the trigger condition is satisfied, specify the notification destination.

Bit Showing Completion of the Process Device Name: PLC1 Bit

Set 1 Set 0 Auto Reset after Trigger Condition Reset.

Bit Showing Processing Result (Success/Failure) Device Name: PLC1 Bit

Error Code Storage Location Device Name: PLC1 32Bit

Abnormal Device IP Address Storage Location Device Name: PLC1 32Bit

Communication Method

General Broadcast Individual Communication

Retry Timeout Setting

Response Check No. of Retry Times: 2

If you give preference to performance over reliability, disable the response check feature.

Enabled to use Data Transfer Timeout Span in the Network Settings.

Inter-node communication Timeout Span during Data Transfer: 20000 ms

These setting are enabled only when the communication method is "General Broadcast" or the communication partner is a GP NODE. Otherwise, configure the "Node settings other than GP series node settings" in the Network Settings.

Data Transfer Timeout Setting

Enabled to use Data Transfer Timeout Setting

Data Transfer Timeout Span: 3000 ms

OK Cancel

| Setting item | | Setting content |
|-------------------------|---|---|
| Completion Notification | Bit Showing Completion of the Process | <p>Sets "0" or "1" to the specified device when data transfer or ACTION has completed. Select the device name, device and symbol, and check either [Set "1"] or [Set "0"].</p> <pre> graph LR subgraph Display_Unit [Display Unit] D1["(1) Trigger condition obtained!"] D5["(5) Bit Showing Completion of the Process"] end subgraph PC [PC] P3["(3) Execute Data Transfer/ACTION"] P4["(4) Receive Notification"] end D1 -- (2) --> P3 P3 --> P4 P4 --> D5 </pre> <p>NOTE</p> <ul style="list-style-type: none"> This setting should be effective under the conditions that: [At Device On] or [AT Device Off] is included in Condition 1 or Condition 2, and [Turn OFF (or ON) the Specified Symbol after Processing] is unchecked. You cannot specify the grouped symbol. Refer to "29.3 Grouping Symbols" for details about group symbols. |
| | Auto Reset after Trigger Condition Reset | <p>Check this to reset the device indicating the process completion when the trigger condition is reset.</p> <p>NOTE</p> <ul style="list-style-type: none"> This setting is available when the [Trigger Condition] is set to either [Device ON] or [Device OFF]. |
| | Bit Showing Processing Result (Success/Failure) | <p>Check this to indicate the processing results on the device. Specify the device name, device and symbol. Sets "0" if processing result is normal, and "1" if not.</p> <p>NOTE</p> <ul style="list-style-type: none"> This setting is available only for device (or symbols) with "Bit" format. You cannot specify the grouped symbol. Processing is made for 1 address (data type) when the symbol is specified. |
| | Error Code Storage Location | <p>Specify the error code storage location when the network related error code is stored in the device in the case that error is found in the processing results.</p> <p>NOTE</p> <ul style="list-style-type: none"> You can set only devices (symbols) with the "16 bits" or the "32 bits" format. You cannot specify the grouped symbol. Processing is made for 1 address (data type) when the symbol is specified. When you use a symbol imported from 'GP-Pro EX', enter the symbol name directly into the text box. |

| Setting item | | Setting content | | | | | | | | | | | | | |
|----------------------------|---|--|--|--|--|--|----------------------------|---------------------|------------------|----------|---|--|---------|---|--|
| Completion Notification | Abnormal Device IP Address Storage Location | <p>Stores the IP address of the provider destination when a provider error occurs.</p> <p>NOTE</p> <ul style="list-style-type: none"> This setting is available only for devices (symbols) with the "32 bits" format. You cannot specify the grouped symbol. Processing is made for 1 address (data type) when the symbol is specified. When you use a symbol imported from 'GP-Pro EX', enter the symbol name directly into the text box. | | | | | | | | | | | | | |
| Communication Method | General Broadcast/ Individual Communication | Select general broadcast or individual communication for data transfer and ACTION data transfer. | | | | | | | | | | | | | |
| Communication Method | Response Check | <p>Select this check box to confirm the remote station received the transmission.</p> <p>When this check box is selected, in the [No. of Retry Times] field specify the number of retries if the transmission fails.</p> <p>NOTE</p> <ul style="list-style-type: none"> This setting is available for the communication with GP Series nodes, and for broadcast communication. For other types of communication, define the retry times in the [Network Settings] screen's "Node settings other than GP series node settings" field. The relationship between the [General Broadcast/Individual Communication] and [Response Check] settings with the transmission and acknowledgement of other nodes is as follows: <table border="1" data-bbox="587 1045 1249 1450"> <thead> <tr> <th colspan="2" rowspan="2"></th> <th colspan="2">[General Broadcast/Individual Communication]</th> </tr> <tr> <th>[Individual Communication]</th> <th>[General Broadcast]</th> </tr> </thead> <tbody> <tr> <th rowspan="2">[Response Check]</th> <th>Selected</th> <td colspan="2">After sending to the remote station, if there is no response, retry the defined number of times</td> </tr> <tr> <th>Cleared</th> <td>Send to the remote station just once (do not retry)</td> <td>After the data transfer timeout interval elapses, retry the defined number of times.</td> </tr> </tbody> </table> | | | [General Broadcast/Individual Communication] | | [Individual Communication] | [General Broadcast] | [Response Check] | Selected | After sending to the remote station, if there is no response, retry the defined number of times | | Cleared | Send to the remote station just once (do not retry) | After the data transfer timeout interval elapses, retry the defined number of times. |
| | | | | | [General Broadcast/Individual Communication] | | | | | | | | | | |
| [Individual Communication] | | | [General Broadcast] | | | | | | | | | | | | |
| [Response Check] | Selected | After sending to the remote station, if there is no response, retry the defined number of times | | | | | | | | | | | | | |
| | Cleared | Send to the remote station just once (do not retry) | After the data transfer timeout interval elapses, retry the defined number of times. | | | | | | | | | | | | |
| | Enable Timeout in the Network Settings | <p>Check this to adopt the timeout span specified on the "Network setup" screen.</p> <p>If not adopted, specify the timeout span (ms) in [Data Transfer Timeout Span] that is to be used.</p> <p>NOTE</p> <ul style="list-style-type: none"> This setting is available for communication with GP Series nodes, and for broadcast communication. For other types of communication, define the retry times in the [Network Settings] screen's "Node settings other than GP series node settings" field. | | | | | | | | | | | | | |

| Setting item | | Setting content |
|--------------------------------|-------------------------------|--|
| Data Transfer Timeout Settings | Enable Data Transfer Timeout. | <p>Set up the timeout time in the [Data Transfer Timeout] field for one trigger condition used to run multiple data transfers/actions.</p> <p>NOTE</p> <ul style="list-style-type: none">• Even if a timeout occurs, the data transfer/action may still successfully run. If it fails, an error message will appear. For information about error messages, refer to 36.3 'Pro-Server EX' Error. |


◆ About Communication and Confirmation

The relationship between the [General Broadcast/Individual Communication] and [Response Check] settings, and the transmission to remote stations and confirmation, is as shown below.

| | | [General Broadcast/Individual Communication] | |
|------------------|----------|--|--|
| | | [Individual Communication] | [General Broadcast] |
| [Response Check] | Selected | After sending to the remote station, if there is no response retry the defined number of times | |
| | Cleared | Send to the remote station just once (do not retry) | After the data transfer timeout interval elapses, retry the defined number of times. |

◆ Combining two trigger conditions

You can combine 2 trigger conditions at maximum by using "And" / "Or" when specifying the trigger condition. First, specify a trigger condition. Then click the list button of [Trigger Condition] to select [AND] or [OR], and specify the second trigger condition in the [Condition 2] tab.




◆ Operation timing with the trigger conditions given below

There are 4 types of trigger conditions that you can specify by using "At Device On" and "At Device Off", and the examples of timing chart with each condition are as follows:


<Example 1: When you set "While Device is ON" or "While Device is OFF" as follows:>

| | | |
|---------------------|---|---------|
| While Device is ON | Turn OFF the specified device address after processing. | Checked |
| While Device is OFF | Turn ON the specified device address after processing. | Checked |




<Example 2: When you set "While Device is ON" or "While Device is OFF" as follows:>

| | | |
|---------------------|---|-----------|
| While Device is ON | Turn OFF the specified device address after processing. | Unchecked |
| While Device is OFF | Turn ON the specified device address after processing. | Unchecked |




<Example 3: When you set "While Device is ON" or "While Device is OFF" as follows:>

| | | |
|---------------------|--|-----------|
| While Device is ON | Bit Showing Completion of the Process | With |
| | Auto-Reset after Resetting Trigger Condition | Unchecked |
| While Device is OFF | Bit Showing Completion of the Process | With |
| | Auto-Reset after Resetting Trigger Condition | Unchecked |




<Example 4: When you set "While Device is ON" or "While Device is OFF" as follows:>

| | | |
|---------------------|--|---------|
| While Device is ON | Bit Showing Completion of the Process | With |
| | Auto-Reset after Resetting Trigger Condition | Checked |
| While Device is OFF | Bit Showing Completion of the Process | With |
| | Auto-Reset after Resetting Trigger Condition | Checked |



The following chart describes the summary of the trigger condition device, [Bit Showing Completion of the Process], [Bit Showing Processing Result (Success/Failure)], [Error Code Storage Location], [Abnormal Device IP Address Storage Location] and the timing to set the receipt notification device described later.




33.1.2 Data Received by ACTION

- NOTE** • This section describes the setting procedures when the ACTION is performed.
This setting is not effective for the case of data transfer.

When the trigger conditions become effective, the device data and constant number specified here are transferred to ACTION node (Normally PC) from the transfer source node.



ACTION node receives such data, displays them on application software and controls these data.

ACTION data is specified on the "Data settings to be received by ACTION" screen.



- NOTE** • Some ACTIONS use the data specified in the above screen for start notification, and optional symbol or constant value need to be specified.
You may find that "1" is specified in the setting procedures in the corresponding chapter.

| Setting item | Setting content |
|------------------------------------|---|
| ACTION Type | Displays the ACTION type selected on the "Set ACTION Name/Parameter" screen. |
| ACTION Name | Displays the ACTION name selected on the "Set ACTION Name/Parameter" screen. |
| From the trigger node, this ACTION | Displays the argument name received from the transfer source during the ACTION operation. |

| Setting item | | Setting content |
|-----------------|--|--|
| Transfer Source | Node | Displays the node name specified on the "Trigger Condition Settings" screen. |
| | Device Name | Select Device/PLC as a transfer source of ACTION data. |
| | Device Address | <p>Click this to specify the device address (or symbol) when the device is set as a transfer source of ACTION data.</p> <ul style="list-style-type: none"> When specifying a device address: Enter directly from the Calculator icon. <div style="text-align: center;">  </div> <ul style="list-style-type: none"> When specifying a symbol: Select the symbol by clicking the list button. <div style="text-align: center;">  </div> <p>NOTE</p> <ul style="list-style-type: none"> When the next item [Constant Value] is specified, this device address setting is not effective. |
| | Constant Value | <p>Click this to enter the number when the constant value is to be set as ACTION data.</p> <p>NOTE</p> <ul style="list-style-type: none"> When the above item [Device Address] is specified, this setting is not effective. |
| | Data Type | Displays automatically the data type of the device specified as a transfer source. |
| No. | Specifies the number of device when such a device is set as a transfer source. | |

33.1.3 ACTION Nodes


NOTE • This section describes the setting procedures when the ACTION is performed.
This setting is not effective for the case of data transfer.

The entry node where the ACTION works practically is called an "ACTION node".



Since ACTION utilizes application software like Excel, a personal computer (Pro-Server EX) is normally set as an ACTION node.

Specify the ACTION node on the "Set ACTION Node/Process Completion Notification" screen when multiple PCs are registered as entry nodes on the network.

You can also set the ACTION completion notification on this screen.




| Setting item | | Setting content |
|--------------|-----------------------------|--|
| ACTION Type | | Displays the ACTION type selected on the [Set ACTION Name/Parameter] screen. |
| ACTION Name | | Displays the ACTION name selected on the [Set ACTION Name/Parameter] screen. |
| ACTION Node | Node | Select the node name to be specified as an ACTION node. |
| | Receive Notification Exists | Check this to receive a notification indicating the ACTION completion. |
| | Device Name | Select the name of device having address to be a notification destination of ACTION execution. |

| Setting item | | Setting content |
|--------------|-----------------|---|
| ACTION Node | Notified Device | <p>Specify the device address (or symbol) that is set to be a notification destination of ACTION execution.</p> <ul style="list-style-type: none"> When specifying a device address: Enter directly from the Calculator icon. <p style="text-align: center;">Calculator icon</p>  <ul style="list-style-type: none"> When specifying a symbol: Select the symbol by clicking the list button. <p style="text-align: center;">List button</p>  |
| | Data Type | Displays automatically the data type of the device specified as a notification destination of ACTION execution. |

33.2 Editing Trigger Conditions

Edit the contents of trigger conditions already specified.

- 1 Select the trigger condition to edit, and click the [Edit] button on the "ACTION-Specific Trigger Condition/ Process List" screen.



The trigger condition settings screen appears.

2 Edit the contents and click the [OK] button.


NOTE • You can also edit the trigger condition from the [Edit] button on the "Sequence Diagram by Trigger Condition" screen.

👉 "33.4.3 Setting Guide"


33.3 Deleting Trigger Conditions

Delete the contents of trigger conditions already specified.

- 1 Select the trigger condition you wish to delete, and click the [Delete] button on the "ACTION-Specific Trigger Condition/Process List" screen.



- 2 The "Trigger1 will be deleted. Is that OK?" message appears. Click the [Yes] button.



The selected trigger condition is deleted.

33.4 Sequential Execution of Multiple Data Transfers and ACTIONS with One Trigger Condition

You can perform multiple data transfers and ACTIONS sequentially by registering them in one trigger condition. Register the first data transfer/ACTION, and add the second data transfer/ACTION with assigning the same trigger conditions.


33.4.1 Registering Multiple Data Transfers and ACTIONS in One Trigger Condition

Ex.

Detect the rising of PLC1 device (Bit device: Address "M01");

(1) Collect the data of PLC2 device (Word device: Address "DM50" to "DM54") and then write them to PLC1 device (Word device: Address "D50" to "D54") (Data Transfer);

(2) Write the PLC1 device data that is transferred (Word device: Address "D50" to "D54") to a CSV file (ACTION).




[Set contents of (1) Data Transfer]

| Setting item | | Setting content |
|------------------------|-------------|---|
| Data Transfer Type | | Collection type |
| Data Transfer Name | | Data transfer |
| Trigger Condition Name | | Turn on operation start bit |
| Trigger Condition | | When "Operation start" (M01) is ON |
| Transfer Source | Node | AGP2 |
| | Device Name | PLC2 |
| | Device | PLC2 symbol "Transfer source" (DM50 to DM54) |
| Transfer Destination | Node | AGP1 |
| | Device Name | PLC1 |
| | Device | PLC1 symbol "Transfer destination" (D50 to D54) |

[Set contents of (2) ACTION]


| Setting item | Setting content |
|----------------------------------|--------------------------------------|
| ACTION Name | CSV upload |
| Trigger Condition Name | Turn on operation start bit |
| Trigger Condition | When "Operation start" (M01) is ON |
| Transfer Destination Device Name | PLC1 |
| Transfer Destination Device | PLC1 symbol "PLC1 Data" (D50 to D54) |
| ACTION Node | PC1 |
| Receive Notification | OFF |

1 First, register the setting contents of (1) Data Transfer in "TurnOnOperationStartBit" of the trigger condition.




NOTE • For the data transfer setting, please refer to "19 Sending Data between Devices".


2 Click [Complete] button.




- 3 Select [ACTION] from the tree display on the left of the screen, and click [Add].




The "Set ACTION Name/Parameter" screen appears.



- 4 Click the list button of [ACTION Type] and select the contents of (2) "Create form using Excel.". Then, enter "CSV Upload" in [ACTION Name] and click the [Click here to set the ACTION parameter] button.




- Set the parameter of the ACTION "CSV Upload" and click the [OK] button. Then click the [Next] button on the "Set ACTION Name/Parameter" screen.




NOTE • For the setting procedures of the ACTION "CSV Upload", please refer to "7 Writing Device/PLC Data in CSV File".


- Click the list button of [Trigger Condition] and select "TurnOnOperationStartBit" that is to be assigned. Then click the [Next] button.



7 Specify the ACTION data of "CSV Upload", and click the [Next] button.




8 Specify ACTION Node and Completion Notification of the additional trigger condition, then click the [Complete] button.




One data transfer and one ACTION have been now assigned to one trigger condition.

- Click the trigger condition name to which data transfer and ACTION have been assigned from the list on the left of the screen.



Specified data transfer and ACTION are now displayed on the "Sequence Diagram by Trigger Condition" screen.




NOTE • To register additional data transfers and ACTIONS, repeat the above steps.


33.4.2 Changing Operation Order of Data Transfer and ACTION

You can change the operation order of data transfer and ACTION specified collectively.

- 1 Click the name of data transfer and ACTION whose operation order you wish to change on the "Sequence Diagram by Trigger Condition" screen.




- 2 Click the [▲] or [▼] button.
 [▲]: Move the operation upward by one row.
 [▼]: Move the operation downward by one row.



33.4.3 Setting Guide

This section describes the contents on the "Sequence Diagram by Trigger Condition" screen.



| Setting item | | Setting content |
|---------------------------|------------------------------------|--|
| Trigger Condition Display | Trigger Condition Name | Displays the name of the trigger condition. Select the name by clicking the list button when you wish to change the trigger condition. |
| | Edit | Edits the displayed trigger condition. Edit the set contents on the trigger condition settings screen to be displayed. |
| | Node | Displays the node name having device (or symbol) to be a trigger condition. |
| | Trigger Condition | Displays the contents of the trigger conditions. |
| Sequence Diagram | ▲ / ▼ | Moves the operation order of the specified ACTION upward (or downward) by one row. |
| | Reduced Display / Expanded Display | Change the display format of ACTION. <ul style="list-style-type: none"> • Reduced display Displays only [Feature Name]. • Expanded display Displays all information of ACTION processing in details. |
| | Feature Name | Displays the ACTION name. |
| | Source | Displays the node name, device name and data-transferring device of the data transfer source. |
| | Destination | Displays the node name, device name and data-receiving device of the data transfer destination. |

| Setting item | | Setting content |
|--------------------|---|---|
| Sequence Diagram | Receive/Process Completion Notification | Displays the node name, device name and device notifying the receipt and process completion. |
| Processing Results | Process Completed | Displays the device notifying process completion. |
| | Processing Results | Displays the device notifying the processing results. |
| | Error Code | Displays the device where error code is stored in the case of error occurrence. |
| | IP Address | Displays the device where IP address of processing destination is stored in the case of error occurrence. |

33.5 Executing ACTION under Multiple Trigger Conditions

Specified contents of ACTION are displayed on the "ACTION-Specific Trigger Condition/Process List" screen. Though this screen displays the contents of the existing ACTION, you can add trigger conditions on this screen when you wish to execute one ACTION under multiple trigger conditions.

It is also possible to edit and delete the set contents of trigger condition and ACTION.


Refer to "33.5.2 Setting Guide" for more details about the screen.

NOTE • As for the data transfer, specification of multiple trigger conditions is not available.

33.5.1 Adding Trigger Conditions

Ex.

Add a new trigger condition "Turn on write start bit" to "At 17:00 Everyday" already registered to the ACTION "Write data in CSV file".




[Set contents already specified]

| Setting item | Setting content |
|----------------------------------|--------------------------------------|
| ACTION Name | CSV upload |
| Trigger Condition Name | 17:00 everyday |
| Trigger Condition | Specified time: 17:00 |
| Transfer Destination Device Name | PLC1 |
| Transfer Destination Device | PLC1 symbol "PLC1 Data" (D50 to D54) |
| ACTION Node | PC1 |
| Receive Notification | OFF |


[Set contents to be newly added]

| Setting item | Setting content |
|----------------------------------|--------------------------------------|
| Trigger Condition Name | Turn on write start bit |
| Trigger Condition | When "Start writing" (M01) is ON |
| Transfer Destination Device Name | PLC1 |
| Transfer Destination Device | PLC1 symbol "PLC1 Data" (D50 to D54) |
| ACTION Node | PC1 |
| Receive Notification | OFF |


1 Click the [Add] button on the "ACTION-Specific Trigger Condition/Process List" screen.




2 Click [New Trigger Condition] button.




3 Enter "TurnOnWriteStartBit" in [Trigger Condition Name] as the name of newly added trigger condition and select "AGP1" in [Node Name].




- Click the [When Device On] button in the [Condition 1] tab, and select "PLC1" as a device name and then "Start Write" as a device symbol name to be a trigger. Then click the [OK] button.




- On the "Set ACTION Trigger Condition" screen, click the [Next] button.




6 Click the list button of [Device Name] and select "PLC1" as a Device/PLC to read data from.




7 Click [Device Address] and then the list button to select "PLC1 Data" as a symbol name of the Device/PLC "PLC1" to read data from.




8 Click the [Next] button.




- 9 Click the list button of [ACTION Node] on the "Set ACTION Node/Process Completion Notification" screen, and select "PC1" as a node name where ACTION works.




- 10 Turn off the check box of [Receive Notification Exists], if checked.




- 11 Click the [Complete] button.



12 Click the ACTION name where the trigger conditions are added, from the list on the left of the screen.




Added trigger conditions are now displayed on the "ACTION-Specific Trigger Condition/Process List" screen.



33.5.2 Setting Guide

This section describes the contents on the "ACTION-Specific Trigger Condition/Process List" screen.



| Setting item | | Setting content |
|--|-------------------------|--|
| ACTION-Specific Trigger Condition/Process List | Add | The "Set ACTION Trigger Condition" screen appears. Specifies trigger conditions to be added on the following screens. |
| | Edit | The "Set ACTION" screen appears. Edits the contents of trigger conditions on this screen. |
| | Delete | Deletes the specified trigger conditions. |
| Trigger Condition Display | Data Source Node | Displays the name of the node and device to be the data source node of ACTION. |
| | Trigger Condition | Displays the contents of the trigger conditions. |
| | Data | Displays the contents of ACTION data. |
| | Completion Notification | Displays the device (or symbol) notifying the processing completion. |
| ACTION Display | Delete ACTION | Deletes the displayed ACTION. |
| | Trigger Condition Name | Selects an ACTION to change the displayed ACTION. |
| | Rename | Changes the displayed ACTION name. Change the name on the "Edit ACTION Name" screen. |
| | Set Parameter | Edits the parameter of ACTION. Displays the parameter setting screen corresponding to each ACTION. Edit the set contents on this screen. |
| | ACTION Node | Displays the ACTION nodes. |