Saia-Burgess Controls Ltd.

Saia S-Bus SIO Driver

1	System Configuration	
2	Selection of External Device	9
3	Example of Communication Setting	10
4	Setup Items	20
5	Cable Diagram	25
6	Supported Device	
7	Device Code and Address Code	45
8	Error Messages	

Introduction

This manual describes how to connect the Display (GP3000 series) and the External Device (target PLC).

In this manual, the connection procedure will be described by following the below sections:

1	System Configuration This section shows the types of External Devices which can be connected and SIO type.	"1 System Configuration" (page 3)
2	Selection of External Device Select a model (series) of the External Device to be connected and connection method.	"2 Selection of External Device" (page 9)
3	Example of Communication Settings This section shows setting examples for communicating between the Display and the External Device.	"3 Example of Communication Setting" (page 10)
4	Setup Items This section describes communication setup items on the Display. Set communication settings of the Display with GP-Pro Ex or in off-line mode.	^{ভেল} "4 Setup Items" (page 20)
5	Cable Diagram This section shows cables and adapters for connecting the Display and the External Device.	^{ক্লে} "5 Cable Diagram" (page 25)
	Operation	

1 System Configuration

The system configuration in the case when the External Device of Saia-Burgess Controls Ltd. and the Display are connected is shown.

Series	CPU	Link I/F	SIO Type	Setting Example	Cable Diagram
	PCD1.M110	PGU (Port 0)	RS232C	Setting Example 1 (page 10)	Cable Diagram 1 (page 25)
		PORT1	RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
		PGU	RS232C	Setting Example 1 (page 10)	Cable Diagram 1 (page 25)
PCD		PCD7 E110	RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
	PCD1.M120 PCD1.M130		RS422/485 (4 wire)	Setting Example 5 (page 18)	Cable Diagram 5 (page 30)
		PCD7.F120	RS232C	Setting Example 2 (page 12)	Cable Diagram 2 (page 26)
		PCD7.F150	RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)

Series	CPU	Link I/F	SIO Type	Setting Example	Cable Diagram
		PGU (Port 0)	RS232C	Setting Example 1 (page 10)	Cable Diagram 1 (page 25)
			RS422/485 (2 wire)	Setting Example 3 (page 14)	Cable Diagram 4 (page 28)
	PCD2.M110 PCD2.M120 PCD2 M150	PCD7.F110	RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
	PCD2.M130 PCD2.M170 PCD2.M480		RS422/485 (4 wire)	Setting Example 5 (page 18)	Cable Diagram 5 (page 30)
		PCD7.F120	RS232C	Setting Example 2 (page 12)	Cable Diagram 2 (page 26)
PCD		PCD7.F150	RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
	PCD2.M120 PCD2.M150 PCD2.M170 PCD2.M480	PCD2.F520	RS232C	Setting Example 2 (page 12)	Cable Diagram 3 (page 27)
			RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
			RS422/485 (4 wire)	Setting Example 5 (page 18)	Cable Diagram 6 (page 33)
		PCD2.F522	RS232C	Setting Example 2 (page 12)	Cable Diagram 3 (page 27)
	PCD2.M480	Port 6	RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)

Series	CPU	Lin	k I/F	SIO Type	Setting Example	Cable Diagram
		PCD3.F110		RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
				RS422/485 (4 wire)	Setting Example 5 (page 18)	Cable Diagram 5 (page 30)
	PCD3.M3230 PCD3.M3330 PCD3.M5440	PCD3.F150		RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
	PCD3.M5540	PCD3.F121		RS232C	Setting Example 2 (page 12)	Cable Diagram 2 (page 26)
		Port 2		RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
	PCD3.M5440 PCD3.M5540	PGU (Port 0)		RS232C	Setting Example 1 (page 10)	Cable Diagram 1 (page 25)
PCD	PCD4.M110 PCD4.M125 PCD4.M145 PCD4.M170 PCD4.M445	PGU		RS232C	Setting Example 1 (page 10)	Cable Diagram 1 (page 25)
	PCD4.M125 PCD4.M145		PCD7 E110	RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
			PCD7.F110	RS422/485 (4 wire)	Setting Example 5 (page 18)	Cable Diagram 5 (page 30)
	PCD4.M170 PCD4.M445	1004.0340	PCD7.F120	RS232C	Setting Example 2 (page 12)	Cable Diagram 2 (page 26)
			PCD7.F150	RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
	PCD4.M145 PCD4.M445	PCD4.C120 Port 1		RS232C	Setting Example 2 (page 12)	Cable Diagram 2 (page 26)

Series	CPU	Link I/F	SIO Type	Setting Example	Cable Diagram
	PCD4.M170	PCD2.F520	RS232C	Setting Example 2 (page 12)	Cable Diagram 3 (page 27)
			RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
			RS422/485 (4 wire)	Setting Example 5 (page 18)	Cable Diagram 6 (page 33)
		PCD2.F522	RS232C	Setting Example 2 (page 12)	Cable Diagram 3 (page 27)
PCD	PCD6.M540	PGU (channel 0)	RS232C	Setting Example 1 (page 10)	Cable Diagram 1 (page 25)
		Channel 1	RS422/485 (4 wire)	Setting Example 5 (page 18)	Cable Diagram 5 (page 30)
		Channel 2	RS232C	Setting Example 2 (page 12)	Cable Diagram 2 (page 26)
	PCD6.M210 Channel 0 - 3	Channel 0 - 3	RS232C	Setting Example 2 (page 12)	Cable Diagram 2 (page 26)
	PCD6.M230	Channel 2, 3	RS232C	Setting Example 2 (page 12)	Cable Diagram 2 (page 26)

Series	CPU	Link I/F		SIO Type	Setting Example	Cable Diagram
	PCD6.M220	Channel 2, 3		RS232C	Setting Example 2 (page 12)	Cable Diagram 2 (page 26)
		Channel 0, 1		RS422/485 (4 wire)	Setting Example 5 (page 18)	Cable Diagram 5 (page 30)
	PCD6.M260	Channel 0 - 3		RS422/485 (4 wire)	Setting Example 5 (page 18)	Cable Diagram 5 (page 30)
BCD	PCD6.M300	PGU		RS232C	Setting Example 1 (page 10)	Cable Diagram 1 (page 25)
		F Interface no.0-3A F	DCD7 E110	RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)
			red/.r110	RS422/485 (4 wire)	Setting Example 5 (page 18)	Cable Diagram 5 (page 30)
			PCD7.F120	RS232C	Setting Example 2 (page 12)	Cable Diagram 2 (page 26)
			PCD7.F150	RS422/485 (2 wire)	Setting Example 4 (page 16)	Cable Diagram 4 (page 28)

Connection Configuration

• 1:1 Connection



• 1:n Connection



2 Selection of External Device

Select the External Device to be connected to the Display.

💰 New Pr	oject File 🗙
Device/PL	C
Maker	Saia-Burgess Controls Ltd.
Driver	Saia S-Bus SIO
🗖 Use S	ystem Area Refer to the manual of this Device/PLC
Connection Port	Method COM1
	Go to Device/PLC Manual
Back	Communication Detail Settings New Screen Cancel

Setup Items	Setup Description
Maker	Select the maker of the External Device to be connected. Select "Saia-Burgess Controls Ltd.".
Driver	Select a model (series) of the External Device to be connected and connection method. Select "Saia S-Bus SIO". Check the External Device which can be connected in "Saia S-Bus SIO" in system configuration. "" "1 System Configuration" (page 3)
Use System Area	 Check this option when you synchronize the system data area of Display and the device (memory) of External Device. When synchronized, you can use the ladder program of External Device to switch the display or display the window on the display. Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)" This can be also set with GP-Pro EX or in off-line mode of Display. Cf. GP-Pro EX Reference Manual " 6.13.6 Setting Guide of [System Setting Window]■[Main Unit Settings] Settings Guide ♦ System Area Setting" Cf. GP3000 Series User Manual "4.3.6 System Area Setting"
Port	Select the Display port to be connected to the External Device.

3 Example of Communication Setting

Examples of communication settings of the Display and the External Device, recommended by Pro-face, are shown.

3.1 Setting Example 1

Settings of GP-Pro EX

Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.

Device/PLC1					
Summary		Change Device/PLC			
Maker Saia-Burgess Controls Ltd.	Driver Saia S-Bus SID	Port COM1			
Text Data Mode 1 <u>Change</u>					
Communication Settings					
SIO Type 📀 RS232C	O RS422/485(2wire) O RS422/485(4wire)				
Speed 19200	•				
Data Length C 7	• 8				
Parity NONE	C EVEN C ODD				
Stop Bit 📀 1	O 2				
Flow Control C NONE	ER(DTR/CTS) C XON/XOFF				
Timeout 3 📑	(sec)				
Retry 2					
Wait To Send 🛛 🗧	(ms)				
RI / VCC © RI	O VCC				
In the case of RS232C, you can sele or VCC (5V Power Supply). If you us Isolation Unit, please select it to VCC	et the 9th pin to RI (Input) ee the Digital's RS232C . Default	[
Device-Specific Settings					
Allowable No. of Device/PLCs 16 Unit(s)					
NO. Device Name	Settings				

Device Setting

To display the setting screen, click I ([Setting]) of External Device you want to set from [Device-Specific Settings] of [Device/PLC Settings].

When you connect multiple External Device, click if from [Device-Specific Settings] of [Device/PLC Settings] to add another External Device.

💰 Individual	Device Setti 🗙				
PLC1					
Station No.	0 📩 Default				
OK (<u>O</u>)	Cancel				

Settings of External Device

Communication setting of external device by ladder soft (Saia PG5 Project Manager). Please refer to the manual of external device for more detail.

- 1 External device is connected with the personal computer, and the power supply of external device is turned on. External device starts in the STOP mode.
- 2 The ladder software is started, and [Hardware Settings] is selected from [CPU] menu.
- **3** The [PCD] tab in the [Hardware Settings] dialog box is clicked. The series of external device is selected from PCD.
- 4 The [S-Bus] tab in the [Hardware Settings] dialog box is clicked. The check is applied to [S-Bus Support], and the station number of external device is input to [S-Bus Station Number].
- 5 The [Serial] tab in the [Hardware Settings] dialog box is clicked. The check on [Serial S-Bus Port] is removed.
- 6 The [Password] tab in the [Hardware Settings] dialog box is clicked. The check on [Password Protection] is removed.
- 7 [Download] of the [Hardware Settings] dialog box is clicked. The [Download] of the displayed dialog box is clicked.
- **8** The ladder program for the communication setting is made.

The [New] is selected from the menu that right-clicks in [Program Files] of the tree view and is displayed.

- Example of Ladder Program
- **9** The [Download Program] is selected from the [Online] menu.

The made ladder program is downloaded to external device.

10 External device is made RUN mode.



Example of Ladder Program

- 3.2 Setting Example 2
 - Settings of GP-Pro EX
 - Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.

Device/PLC 1					
Summary	Change Device/PLC				
Maker Saia-Burgess Controls	Ltd. Driver Saia S-Bus SIO Port COM1				
Text Data Mode 1	ange				
Communication Settings					
SIO Type 💿 RS	32C C RS422/485(2wire) C RS422/485(4wire)				
Speed 19200	•				
Data Length C 7	• 8				
Parity 💿 NO	IE O EVEN O ODD				
Stop Bit 💿 1	O 2				
Flow Control C NO	IE 💿 ER(DTR/CTS) 🔿 XON/XOFF				
Timeout 3					
Retry 2	-				
Wait To Send 0	* (ms)				
RI / VCC © RI	O VCC				
In the case of RS232C, you or VCC (5V Power Supply). Isolation Unit, please select	an select the 9th pin to RI (Input) you use the Digital's RS232C to VCC. Default				
Device-Specific Settings					
Allowable No. of Device/PLC:	16 Unit(s) 🔢				
No. Device Name	Settings				
👗 1 JPLC1	Istation No.=0				

Device Setting

To display the setting screen, click I ([Setting]) of External Device you want to set from [Device-Specific Settings] of [Device/PLC Settings].

When you connect multiple External Device, click if from [Device-Specific Settings] of [Device/PLC Settings] to add another External Device.

💣 Individua	l Device Setti 🗙
PLC1	
Station No.	0 📩 Default
OK (<u>O)</u>	Cancel

Settings of External Device

Communication setting of external device by ladder soft (Saia PG5 Project Manager). Please refer to the manual of external device for more detail.

- 1 External device is connected with the personal computer, and the power supply of external device is turned on. External device starts in the STOP mode.
- 2 The ladder software is started, and [Hardware Settings] is selected from [CPU] menu.
- **3** The [PCD] tab in the [Hardware Settings] dialog box is clicked. The series of external device is selected from PCD.
- 4 The [S-Bus] tab in the [Hardware Settings] dialog box is clicked. The check is applied to [S-Bus Support], and the station number of external device is input to [S-Bus Station Number].
- 5 The [Serial] tab in the [Hardware Settings] dialog box is clicked. The check on [Serial S-Bus Port] is removed.
- 6 The [Password] tab in the [Hardware Settings] dialog box is clicked. The check on [Password Protection] is removed.
- 7 [Download] of the [Hardware Settings] dialog box is clicked. The [Download] of the displayed dialog box is clicked.
- $\mathbf{8}$ The ladder program for the communication setting is made.

The [New] is selected from the menu that right-clicks in [Program Files] of the tree view and is displayed.

- Example of Ladder Program
- **9** The [Download Program] is selected from the [Online] menu.

The made ladder program is downloaded to external device.

- 10 External device is made RUN mode.
 - Example of Ladder Program



3.3 Setting Example 3

Settings of GP-Pro EX

Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.

Device/PLC 1	
Summary	Change Device/PLC
Maker Saia-Burgess Controls L	d. Driver Saia S-Bus SIO Port COM1
Text Data Mode 1 Cha	nge
Communication Settings	
SIO Type 🛛 🔿 RS23	2C 💿 RS422/485(2wire) 💿 RS422/485(4wire)
Speed 19200	•
Data Length 🛛 🔿 7	• 8
Parity 💿 NON	O EVEN O ODD
Stop Bit 💿 1	O 2
Flow Control C NON	• • ER(DTR/CTS) O XON/XOFF
Timeout 3	(sec)
Retry 2	
Wait To Send 0	- (ms)
RI / VCC 💿 BI	O VCC
In the case of RS232C, you ca or VCC (5V Power Supply). If Isolation Unit, please select it t	n select the 9th pin to RI (Input) rou use the Digital's RS232C 5 VCC. Default
Device-Specific Settings	
Allowable No. of Device/PLCs	l6Unit(s) 📷
No. Device Name	Settings
👗 1 JPLC1	Station No.=0

Device Setting

To display the setting screen, click I ([Setting]) of External Device you want to set from [Device-Specific Settings] of [Device/PLC Settings].

When you connect multiple External Device, click if from [Device-Specific Settings] of [Device/PLC Settings] to add another External Device.

💣 Individual	l Device Setti 🗙
PLC1	
Station No.	0 📩 Default
OK (<u>O)</u>	Cancel

Settings of External Device

Communication setting of external device by ladder soft (Saia PG5 Project Manager). Please refer to the manual of external device for more detail.

- 1 External device is connected with the personal computer, and the power supply of external device is turned on. External device starts in the STOP mode.
- 2 The ladder software is started, and [Hardware Settings] is selected from [CPU] menu.
- **3** The [PCD] tab in the [Hardware Settings] dialog box is clicked. The series of external device is selected from PCD.
- 4 The [S-Bus] tab in the [Hardware Settings] dialog box is clicked. The check is applied to [S-Bus Support], and the station number of external device is input to [S-Bus Station Number].
- 5 The [Serial] tab in the [Hardware Settings] dialog box is clicked. The check on [Serial S-Bus Port] is removed.
- 6 The [Password] tab in the [Hardware Settings] dialog box is clicked. The check on [Password Protection] is removed.
- 7 [Download] of the [Hardware Settings] dialog box is clicked. The [Download] of the displayed dialog box is clicked.
- $\mathbf{8}$ The ladder program for the communication setting is made.

The [New] is selected from the menu that right-clicks in [Program Files] of the tree view and is displayed.

- Example of Ladder Program
- **9** The [Download Program] is selected from the [Online] menu.

The made ladder program is downloaded to external device.

- 10 External device is made RUN mode.
 - Example of Ladder Program



3.4 Setting Example 4

Settings of GP-Pro EX

Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.

Device/PLC 1	
Summary	Change Device/PLC
Maker Saia-Burgess Controls Ltd.	Driver Saia S-Bus SIO Port COM1
Text Data Mode 1 Chang	<u>e</u>
Communication Settings	
SIO Type C RS232C	RS422/485(2wire) C RS422/485(4wire)
Speed 19200	•
Data Length O 7	• 8
Parity 💿 NONE	O EVEN O ODD
Stop Bit 💿 1	C 2
Flow Control C NONE	ER(DTR/CTS) O XON/XOFF
Timeout 3	÷ (sec)
Retry 2	÷
Wait To Send 0	* (ms)
RI / VCC C RI	O VCC
In the case of RS232C, you can a or VCC (5V Power Supply). If you Isolation Unit, please select it to V	select the 9th pin to RI (Input) r use the Digital's RS232C CC. Default
Device-Specific Settings	
Allowable No. of Device/PLCs 16	Unit(s) 📷
No. Device Name	Settings
	Jordin No.=0

Device Setting

To display the setting screen, click I ([Setting]) of External Device you want to set from [Device-Specific Settings] of [Device/PLC Settings].

When you connect multiple External Device, click if from [Device-Specific Settings] of [Device/PLC Settings] to add another External Device.

💣 Individua	l Device Setti 🗙
PLC1	
Station No.	
	Default
OK (<u>O)</u>	Cancel

Settings of External Device

Communication setting of external device by ladder soft (Saia PG5 Project Manager). Please refer to the manual of external device for more detail.

- 1 External device is connected with the personal computer, and the power supply of external device is turned on. External device starts in the STOP mode.
- 2 The ladder software is started, and [Hardware Settings] is selected from [CPU] menu.
- **3** The [PCD] tab in the [Hardware Settings] dialog box is clicked. The series of external device is selected from PCD.
- 4 The [S-Bus] tab in the [Hardware Settings] dialog box is clicked. The check is applied to [S-Bus Support], and the station number of external device is input to [S-Bus Station Number].
- 5 The [Serial] tab in the [Hardware Settings] dialog box is clicked. The check on [Serial S-Bus Port] is removed.
- 6 The [Password] tab in the [Hardware Settings] dialog box is clicked. The check on [Password Protection] is removed.
- 7 [Download] of the [Hardware Settings] dialog box is clicked. The [Download] of the displayed dialog box is clicked.
- $\mathbf{8}$ The ladder program for the communication setting is made.

The [New] is selected from the menu that right-clicks in [Program Files] of the tree view and is displayed.

- Example of Ladder Program
- **9** The [Download Program] is selected from the [Online] menu.

The made ladder program is downloaded to external device.

- 10 External device is made RUN mode.
 - Example of Ladder Program



3.5 Setting Example 5

Settings of GP-Pro EX

Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.

Device/PLC 1	
Summary	Change Device/PLC
Maker Saia-Burgess Controls Ltd.	Driver Saia S-Bus SIO Port COM1
Text Data Mode 1 Chang	<u>e</u>
Communication Settings	
SIO Type C RS232C	C RS422/485(2wire) C RS422/485(4wire)
Speed 19200	•
Data Length O 7	8 8
Parity © NONE	O EVEN O ODD
Stop Bit 💿 1	C 2
Flow Control C NONE	ER(DTR/CTS) O XON/XOFF
Timeout 3	÷ (sec)
Retry 2	÷
Wait To Send	* (ms)
RI / VCC C RI	O VCC
In the case of RS232C, you can s or VCC (5V Power Supply). If you Isolation Unit, please select it to V	select the 9th pin to RI (Input) use the Digital's RS232C CC. Default
Device-Specific Settings	
Allowable No. of Device/PLCs 16	Unit(s) 📷
No. Device Name	Settings
	Interior No.=0

Device Setting

To display the setting screen, click I ([Setting]) of External Device you want to set from [Device-Specific Settings] of [Device/PLC Settings].

When you connect multiple External Device, click if from [Device-Specific Settings] of [Device/PLC Settings] to add another External Device.

💣 Individua	l Device Setti 🗙
PLC1	
Station No.	
	Default
OK (<u>O)</u>	Cancel

Settings of External Device

Communication setting of external device by ladder soft (Saia PG5 Project Manager). Please refer to the manual of external device for more detail.

- 1 External device is connected with the personal computer, and the power supply of external device is turned on. External device starts in the STOP mode.
- 2 The ladder software is started, and [Hardware Settings] is selected from [CPU] menu.
- **3** The [PCD] tab in the [Hardware Settings] dialog box is clicked. The series of external device is selected from PCD.
- 4 The [S-Bus] tab in the [Hardware Settings] dialog box is clicked. The check is applied to [S-Bus Support], and the station number of external device is input to [S-Bus Station Number].
- 5 The [Serial] tab in the [Hardware Settings] dialog box is clicked. The check on [Serial S-Bus Port] is removed.
- 6 The [Password] tab in the [Hardware Settings] dialog box is clicked. The check on [Password Protection] is removed.
- 7 [Download] of the [Hardware Settings] dialog box is clicked. The [Download] of the displayed dialog box is clicked.
- $\mathbf{8}$ The ladder program for the communication setting is made.

The [New] is selected from the menu that right-clicks in [Program Files] of the tree view and is displayed.

- Example of Ladder Program
- **9** The [Download Program] is selected from the [Online] menu.

The made ladder program is downloaded to external device.

10 External device is made RUN mode.



Example of Ladder Program

4 Setup Items

Set communication settings of the Display with GP-Pro EX or in off-line mode of the Display. The setting of each parameter must be identical to that of External Device.

"3 Example of Communication Setting" (page 10)

4.1 Setup Items in GP-Pro EX

Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.

Device/PLC1				
Summary				Change Device/PLC
Maker Saia-Burgess Cor	ntrols Ltd. D	river Saia S-Bus	: SIO	Port COM1
Text Data Mode 1	<u>Change</u>			
Communication Settings				
SIO Type 💿	RS232C C RS42	2/485(2wire)	C RS422/485(4wire)	
Speed 19	3200 💌			
Data Length C	7 🖲 8			
Parity 📀	NONE C EVEN	0		
Stop Bit 📀	1 O 2			
Flow Control	NONE	(R/CTS) O S	XON/XOFF	
Timeout 3	÷ (sec)			
Retry 2	*			
Wait To Send 0				
RI/VCC •	RI O VCC			
In the case of RS232C, or VCC (5V Power Supp Isolation Unit, please set	you can select the 9th pir oly). If you use the Digital lect it to VCC.	n to RI (Input) 's RS232C	Default	
Device-Specific Settings				
Allowable No. of Device/F	PLCs 16 Unit(s) 📊			
1 PLC1	Sen	Station No.=0		

Setup Items	Setup Description			
SIO Type	Select the SIO type to communicate with the External Device.			
Speed	Select speed between the External Device and the Display.			
Data Length	Select data length.			
Parity	Select how to check parity.			
Stop Bit	Select stop bit length.			
Flow Control	Display the communication control method to prevent overflow of transmission and reception data.			
Timeout	Use an integer from 1 to 127 to enter the time (s) for which the Display waits for the response from the External Device.			
Retry	In case of no response from the External Device, use an integer from 0 to 255 to enter how many times the Display retransmits the command.			
Wait To Send	Use an integer from 0 to 255 to enter standby time (ms) for the Display from receiving packets to transmitting next commands.			
RI/VCC	You can switch RI/VCC of the 9th pin when you select RS232C for SIO type			

20

Device Setting

To display the setting screen, click I ([Setting]) of External Device you want to set from [Device-Specific Settings] of [Device/PLC Settings].

When you connect multiple External Device, click if from [Device-Specific Settings] of [Device/PLC Settings] to add another External Device

💰 Individual Device Setti 🗙				
PLC1				
Station No.	0 📩 Default			
OK (<u>O</u>)	Cancel			

Setup Items	Setup Description			
Station No.	Use an integer from 0 to 253 to enter the Station No. of the External Device. (Initial value [0])			

4.2 Setup Items in Off-Line Mode



• Please refer to GP3000 Series User Manual for more information on how to enter off-line mode or about operation.

Cf. GP3000 Series User Manual "Chapter 4 Settings"

Communication Settings

To display the setting screen, touch [Device/PLC Settings] from [Peripheral Settings] in off-line mode. Touch the External Device you want to set from the displayed list.

Comm.	Device	Option		
Saia S-Bus SIO	SIO Type Speed Data Length Parity	RS232C 19200 8 None	[COM1]	Page 1/1
	Stop Bit Flow Control	1 ER(DTR/C	TS) 💌]
	Timeout(s) Retry Wait To Send(ms)			
	Exit	-	Back	2006/06/30 22:13:17

Setup Items	Setup Description					
SIO Type	Select the SIO type to communicate with the External Device.					
Speed	Select speed between the External Device and the Display.					
Data Length	Select data length.					
Parity	Select how to check parity.					
Stop Bit	Select stop bit length.					
Flow Control	Display the communication control method to prevent overflow of transmission and reception data.					
Timeout	Use an integer from 1 to 127 to enter the time (s) for which the Display waits for the response from the External Device.					
Retry	In case of no response from the External Device, use an integer from 0 to 255 to enter how many times the Display retransmits the command.					
Wait To Send	Use an integer from 0 to 255 to enter standby time (ms) for the Display from receiving packets to transmitting next commands.					

Device Setting

To display the setting screen, touch [Device/PLC Settings] from [Peripheral Settings]. Touch the External Device you want to set from the displayed list, and touch [Device].

Comm.	Device	Option		
1				
Saia S-Bus SIO			[COM1]	Page 1/1
Devic	e/PLC Name PL	C1		-
St	ation No.		0 🔻	
	Exit		Back	2006/06/30 22:13:19

Setup Items	Setup Description
Device/PLC Name	Select the External Device for device setting. Device name is a title of External Device set with GP-Pro EX.(Initial value [PLC1])
Station No.	Use an integer from 0 to 253 to enter the Station No. of the External Device. (Initial value [0])

Option

To display the setting screen, touch [Device/PLC Settings] from [Peripheral Settings]. Touch the External Device you want to set from the displayed list, and touch [Option].

Comm.	Device	Option		-
				-
Saia S-Bus SIO			[COM1]	Page 1/1
	RI / VCC In the case the 9th pir Power Suppl RS232C Isol it to VCC.	• RI e of RS232C, you h to RI(Input) or y). If you use th ation Unit, plea	O VCC can select VCC(5V e Digital's se select	
	Exit		Back	2006/06/30 22:13:23

Setup Items	Setup Description
RI/VCC	You can switch RI/VCC of the 9th pin when you select RS232C for SIO type

The cable diagram shown below may be different from the cable diagram recommended by Saia-Burgess Controls Ltd.. Please be assured there is no operational problem in applying the cable diagram shown in this manual.

- The FG pin of the External Device body must be D-class grounded. Please refer to the manual of the External Device for more details.
- SG and FG are connected inside the Display. When connecting SG to the External Device, design the system not to form short-circuit loop.

Cable Diagram 1

Display (Connection Port)	Cable	Notes
GP (COM1)	Your own cable	

When using your own cable

Displa

	Display D-Sub 9p	oin (Socke	et)			6	External [D-Sub 9p	Device in (Plug)	
	Pin	Signal name		Shield	Shield			Pin	Signal name
y	2	RD(RXD)	•		-	3	ТΧ		
	3	SD(TXD)				-	2	RX	
	7	RS(RTS)				→	8	CTS	
	5	SG	•			-	5	SGN	
	8	CS(CTS)			-	7	RTS		
	Shell	FG			V	-	1	PGND	

Your own cable

Display (Connection Port)	Cable	Notes
GP (COM1)	Your own cable	When connecting PCD7.F120, PCD3.F121, PCD4.C120, PCD6.

The pin assign in the interface is different according to external device. The pin assign of each series is as follows. Please refer to the manual of the External Device for more details.

Series	PCD1 PCD2	PCD3	PCD4.Mxxx		PCD6.M540	PCD6.M2xx	PCD6.M300
Link I/F	PCD7.F120	PCD3.F121	C120	C340+ PCD7.F120			PCD7.F120
Interface	Port#1	Slot 0	Interface #1	Interface #1-3 ^{*1}	Interface #2 D-sub 9pin	Interface #0-3 ^{*2} D-sub 25pin	Interface #0-3a D-sub 9pin
TX	11	1	10	x0	3	2	3
RX	12	2	11	x1	2	3	2
CTS	14	4	15	x 3	8	5	8
SGN	15	5	GND	GND	5	7	5
RTS	13	3	14	x 2	7	4	7
DTR	16	6	12	x 4	4	20	4
DSR	17	7	13	x 5	6	6	6
PGND	10	0					

*1 The (x) has to be replaced by the interface number. Ex.) The CTS of interface 2 is "23".

*2 The interface number depends on the CPU type.

When using your own cable



Your own cable

Display (Connection Port)	Cable	Notes
GP (COM1)	Your own cable	When connecting it with series other than PCD7.F120, PCD3.F121, PCD4.C120, PCD6.

The pin assign in the interface is different according to external device. The pin assign of each series is as follows. Please refer to the manual of the External Device for more details.

Series	PCD2 (Port #4,5 are M170/480 only)						
Link I/F	PCD2.F5	520/522 ^{*1}		PCD2.F522 ^{*1}			
Interface	Port#2 (screw Port#4 (screw		Port #3 (screw	Port #3	Port#5 (screw	Port#5	
Internace	terminal)	terminal)	terminal)	(D-Sub 9 pin)	terminal)	(D-Sub 9 pin)	
TX	31	41	36	8	46	8	
RX	32	42	37	3	47	3	
CTS	34	44	39	5	49	5	
SGN	30	40	35	1	45	1	
RTS	33	43	38	6	48	6	

Series	PCD4.M170					
Link I/F	PCD2.F520/ 522 ^{*1}	PCD2.F522*1				
Interface	Port#4	Port#5	Port#3			
TX	41	46	8			
RX	42	47	3			
CTS	44	49	6			
SGN	40	45	1			
RTS	43	48	5			

*1 RS232c full mode should not be used.

When using your own cable



Display (Connection Port)	Cable	Notes
GP(COM2) ^{*1}	Online adapter by Pro-face CA4-ADPONL-01 + Your own cable	The cable length must be 1000m or less.

*1 All GP models except AGP-3302

NOTE • The use of RS485 isolation unit (CA3-ISO485-01) is recommended.

The pin assign in the interface is different according to external device. The pin assign of each series is as follows. Please refer to the manual of the External Device for more details.

Series	PCD1.M110	PCD2.M1x0	PCD2.M480	PCD1.MxxxPCD2.Mxxx	
Link I/F				PCD7.F110	PCD7.F150 ^{*3}
Interface	Port#1 ^{*1}	Port#0 *1	Port#6 ^{*1}	Port#1 ^{*1}	Port#1
RX-TX	11	29	29	11	11
/RX-/TX	12	28	28	12	12
PGND	10			10	Isolated

Series	PCD2.Mxxx					PCD3	
Link I/F	PCD2.F520 ^{*1} (Port#5 is M170/480 only)				PCD3.F110 ^{*1}	PCD3.F150+ PCD7.F150	
Interface	Port #3 (screw terminal)	Port #3 (D- Sub 9 pin)	Port#5 (screw terminal)	Port #5 (D- Sub 9 pin)	Port#1	Port#1	Port#2
RX-TX	36	8	46	8	1	1	1
/RX-/TX	37	3	47	3	2	2	2
PGND	35	1	45	1	0	Isolated	

Series	PCD4.Mxxx		PCD4.M170		PCD6.M300	
Link I/F	C340+PCD7. F110 ^{*1}	C340+PCD7. F150	PCD2.F520		PCD7.F110	PCD7.F150
Interface	Interface #1- 3 ^{*4}	Interface #1- 3 ^{*4}	Port#5 (screw terminal)	Port#5 D-sub 9pin	D-sub 9pin	D-sub 9pin
RX-TX	x0	x0	46	8	3	3
/RX-/TX	x1	x1	47	3	2	2
PGND	GND	Isolated	45	1	5	Isolated

*1 At the first and last stations, the jumper must be set to the "CLOSED" position. At all other stations, the jumper must be set to "OPEN" (factory setting).

*2 Except PCD1.M110.

*3 The (x) has to be replaced by the interface number. Ex.) The RX-TX of interface 3 is "30".

When using the online adapter (CA4-ADPONL-01) by Pro-face and your own cable

• 1:1 Connection



• 1:n Connection



Display (Connection Port)		Cable	Notes
GP (COM1) ^{*1} AGP-3302 (COM2)	А	COM port conversion adapter (for COM1) by Pro-face CA3-ADPCOM-01 + Connector terminal block conversion adapter by Pro-face CA3-ADPTRM-01 + Your own cable	
	В	Your own cable	
GP (COM2) ^{*1}	С	Online adapter by Pro-face CA4-ADPONL-01 + Connector terminal block conversion adapter by Pro-face CA3-ADPTRM-01 + Your own cable	
	D	Online adapter by Pro-face CA4-ADPONL-01 + Your own cable	

*1 All GP models except AGP-3302

The pin assign in the interface is different according to external device. The pin assign of each series is as follows. Please refer to the manual of the External Device for more details.

Series	PCD1PCD2	PCD3	PCD4	PCD6.M540	PCD6.M100/ M2x0	PCD6.M300
Link I/F	PCD7.F110	PCD3.F110	C340+ PCD7.F110 ^{*1}		PCD7.F110 ^{*1}	PCD7.F110 ^{*1}
Interface	Port#1 ^{*1}	Port#1 ^{*1}	Interface #1-3 ^{*2}	Interface #1	Interface #0-3	Interface #0-3a
interrace					D-sub 25 pin	D-sub 9 pin
Tx	11	1	x 0	3	2	3
/Tx	12	2	x 1	4	9	2
Rx	13	3	x 2	2	4	7
/Rx	14	4	x 3	1	11	8
SGND	15	5	GND	5	13	5
CTS	18	8	х б	8	5	9
RTS	16	6	x 4	7	3	4
/CTS	19	9	x 7	6	12	1
/RTS	17	7	x 5	9	10	6
PGND	Shell	0			1	

*1 For RS 422, each pair of receive lines is terminated with a 150 Ω line termination resistor. Jumper J1 must be left in the "OPEN" position (factory setting). The jumper is on the connection side of the module.

*2 The (x) has to be replaced by the interface number. Ex.) The Tx of interface 3 is "30".

A) When using the COM port conversion adapter (CA3-ADPCOM-01), the connector terminal block conversion adapter (CA3-ADPTRM-01) by Pro-face and your own cable



B) When using your own cable



C) When using the online adapter (CA4-ADPONL-01), the connector terminal block conversion adapter (CA3-ADPTRM-01) by Pro-face and your own cable



D) When using the online adapter (CA4-ADPONL-01) by Pro-face and your own cable



Display (Connection Port)		Cable	Notes
GP (COM1) ^{*1} AGP-3302 (COM2)	А	COM port conversion adapter (for COM1) by Pro-face CA3-ADPCOM-01 + Connector terminal block conversion adapter by Pro-face CA3-ADPTRM-01 + Your own cable	
	В	Your own cable	
GP (COM2) ^{*1}	С	Online adapter by Pro-face CA4-ADPONL-01 + Connector terminal block conversion adapter by Pro-face CA3-ADPTRM-01 + Your own cable	
	D	Online adapter by Pro-face CA4-ADPONL-01 + Your own cable	

*1 All GP models except AGP-3302

The pin assign in the interface is different according to external device. The pin assign of each series is as follows. Please refer to the manual of the External Device for more details.

Series		PC	PCD4	.M170		
Link I/F		PCD2	.F520		PCD2	.F520
Interface	rface Port#3 (screw Port#3		Port#5 (screw	Port#5	Port#5 (screw	Port#5
Internace	terminal)	D-Sub 9pin	terminal)	D-Sub 9pin	terminal)	D-sub 9pin
Tx	36	8	46	8	46	8
/Tx	37	3	47	3	47	3
Rx	38	6	48	6	48	6
/Rx	39	5	49	5	49	5
SGND	35	1	45	1	45	1

A) When using the COM port conversion adapter (CA3-ADPCOM-01), the connector terminal block conversion adapter (CA3-ADPTRM-01) by Pro-face and your own cable



B) When using your own cable

Display



C) When using the online adapter (CA4-ADPONL-01), the connector terminal block conversion adapter (CA3-ADPTRM-01) by Pro-face and your own cable



D) When using the online adapter (CA4-ADPONL-01) by Pro-face and your own cable



6 Supported Device

Range of supported device address is shown in the table below. Please note that the actually supported range of the devices varies depending on the External Device to be used. Please check the actual range in the manual of your connecting equipment.

6.1 PCD1 Series



Device	Bit Address	Word Address	32 bits	Notes
Internal Bit	F00000 ~ F08191	F00000 ~ F08176		÷16) *1
Input Bit	I00000 ~ I00063	I00000 ~ I00048	[L/H]	÷16) *2
Output Bit	O00000 ~O00063	O00000 ~O00048		÷16) *1
Register Dword	RDX00000.00 ~ RDX04095.31	RDW00000 ~ RDW04095		<mark>ві,31 *1</mark>
Timer Word		T00000 ~ T01599	Ĭ	
Counter Word		C00000 ~ C01599		
Data Block (0 ~ 3999)	DB00000.W00000.00~ DB03999.W00382.31	DB00000.W00000 ~ DB03999.W00382		<mark>ві,31 *1</mark>
Data Block (4000 ~ 4099)	DB04000.W00000.00~ DB04099.W16383.31	DB04000.W00000 ~ DB04099.W16383		<mark>ві , 31) *1</mark>

*1 This is a discrete device but it can be written by only word data. When it is used for bit set or reset, AGP will write the word data that is modified from the read data before write. It has a possibility to happen the confliction between AGP and the PLC ladder program.

*2 Write disable

NOTE

Please refer to the GP-Pro EX Reference Manual for system data area.

Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"

• Please refer to the precautions on manual notation for icons in the table.

6.2 PCD2 .M110

Device	Bit Address	Word Address	32 bits	Notes
Internal Bit	F00000 ~ F08191	F00000 ~ F08176		÷16) *1
Input Bit(*1)	I00000 ~ I00127	I00000 ~ I00112	[L / H]	÷16 *2
Output Bit(*1)	O00000 ~O00127	O00000 ~O00112		÷16) *1
Register Dword	RDX00000.00 ~ RDX04095.31	RDW00000 ~ RDW04095		<u>, 8 i , 31</u> *1
Timer Word		T00000 ~ T01599	- -	
Counter Word		C00000 ~ C01599		
Data Block (0 ~ 3999)	DB00000.W00000.00~ DB03999.W00382.31	DB00000.W00000 ~ DB03999.W00382		<u>ві,31</u> *1
Data Block (4000 ~ 5999)	DB04000.W00000.00~ DB05999.W16383.31	DB04000.W00000 ~ DB05999.W16383		<u>₿ i t31</u> *1

*1 This is a discrete device but it can be written by only word data. When it is used for bit set or reset, AGP will write the word data that is modified from the read data before write. It has a possibility to happen the confliction between AGP and the PLC ladder program.

*2 Write disable

NOTE • Please refer to the GP-Pro EX Reference Manual for system data area.

- Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.

6.3 PCD2 .M120/M150

Device	Bit Address	Word Address	32 bits	Notes
Internal Bit	F00000 ~ F08191	F00000 ~ F08176		÷16) *1
Input Bit(*1)	I00000 ~ I00255	I00000 ~ I00240	[L / H]	÷16 *2
Output Bit(*1)	O00000 ~O00255	O00000 ~O00240		÷16) *1
Register Dword	RDX00000.00 ~ RDX04095.31	RDW00000 ~ RDW04095		<u>₿ i t</u> 31 *1
Timer Word		T00000 ~ T01599	•	
Counter Word		C00000 ~ C01599		
Data Block (0 ~ 3999)	DB00000.W00000.00~ DB03999.W00382.31	DB00000.W00000 ~ DB03999.W00382		<u>₿ i t</u> 31 *1
Data Block (4000 ~ 5999)	DB04000.W00000.00~ DB05999.W16383.31	DB04000.W00000 ~ DB05999.W16383		<u>ві t</u> 31 *1

*1 This is a discrete device but it can be written by only word data. When it is used for bit set or reset, AGP will write the word data that is modified from the read data before write. It has a possibility to happen the confliction between AGP and the PLC ladder program.

*2 Write disable

NOTE

• Please refer to the GP-Pro EX Reference Manual for system data area.

- Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.

6.4 PCD2 .M170

Device	Bit Address	Word Address	32 bits	Notes
Internal Bit	F00000 ~ F08191	F00000 ~ F08176		<u>→ 16</u>) *1
Input Bit	I00000 ~ I00255	I00000 ~ I00240	[L / H]	÷16 *2
Output Bit	O00000 ~O00255	O00000 ~O00240	ļ	÷16) *1
Register Dword	RDX00000.00 ~ RDX04095.31	RDW00000 ~ RDW04095		<u>₿ i t</u> 31 *1
Timer Word		T00000 ~ T01599	ſ	
Counter Word		C00000 ~ C01599		
Data Block (0 ~ 3999)	DB00000.W00000.00~ DB03999.W00382.31	DB00000.W00000 ~ DB03999.W00382		<u>ві,31</u> *1
Data Block (4000 ~ 7999)	DB04000.W00000.00~ DB07999.W16383.31	DB04000.W00000 ~ DB07999.W16383		<mark>₿ ; ,31)</mark> *1

*1 This is a discrete device but it can be written by only word data. When it is used for bit set or reset, AGP will write the word data that is modified from the read data before write. It has a possibility to happen the confliction between AGP and the PLC ladder program.

*2 Write disable

NOTE • Please refer to the GP-Pro EX Reference Manual for system data area.

- Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.

6.5 PCD2 .M480

Device	Bit Address	Word Address	32 bits	Notes
Internal Bit	F00000 ~ F08191	F00000 ~ F08176		÷16) *1
Input Bit	I00000 ~ I00255	100000 ~ 100240		÷16 *2
Output Bit	O00000 ~O00255	O00000 ~O00240		÷16) *1
Register Dword	RDX00000.00 ~ RDX16383.31	RDW00000 ~ RDW16383		<u>ві,31</u> *1
Timer Word		T00000 ~ T01599		
Counter Word		C00000 ~ C01599		
Data Block (0 ~ 3999)	DB00000.W00000.00~ DB03999.W00382.31	DB00000.W00000 ~ DB03999.W00382		<mark>, ∎ ; , 31)</mark> *1
Data Block (4000 ~ 8190)	DB04000.W00000.00~ DB08190.W16383.31	DB04000.W00000 ~ DB08190.W16383		<u>₿;</u> ,31 *1

*1 This is a discrete device but it can be written by only word data. When it is used for bit set or reset, AGP will write the word data that is modified from the read data before write. It has a possibility to happen the confliction between AGP and the PLC ladder program.

*2 Write disable

NOTE

• Please refer to the GP-Pro EX Reference Manual for system data area.

- Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.

6.6 PCD3 .M3020

Device	Bit Address	Word Address	32 bits	Notes
Internal Bit	F00000 ~ F08191	F00000 ~ F08176		÷16 *1
Input Bit	I00000 ~ I00063	I00000 ~ I00048	[L / H]	÷16 *2
Output Bit	O00000 ~O00063	O00000 ~O00048		÷16) *1
Register Dword	RDX00000.00 ~ RDX16383.31	RDW00000 ~ RDW16383		<u>ві,31</u> *1
Timer Word		T00000 ~ T01599	- -	
Counter Word		C00000 ~ C01599		
Data Block (0 ~ 3999)	DB00000.W00000.00~ DB03999.W00382.31	DB00000.W00000 ~ DB03999.W00382		<u>ві,31</u> *1
Data Block (4000 ~ 8191)	DB04000.W00000.00~ DB08191.W16383.31	DB04000.W00000 ~ DB08191.W16383		<u>₿ i t31</u> *1

*1 This is a discrete device but it can be written by only word data. When it is used for bit set or reset, AGP will write the word data that is modified from the read data before write. It has a possibility to happen the confliction between AGP and the PLC ladder program.

*2 Write disable

NOTE

• Please refer to the GP-Pro EX Reference Manual for system data area.

- Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.

6.7 PCD3 .M3230/3330/5440/5540

Device	Bit Address	Word Address	32 bits	Notes
Internal Bit	F00000 ~ F08191	F00000 ~ F08176		
Input Bit	I00000 ~ I01023	I00000 ~ I01008	[L / H]	÷16) *2
Output Bit	O00000 ~O01023	O00000 ~O01008		÷16) *1
Register Dword	RDX00000.00 ~ RDX16383.31	RDW00000 ~ RDW16383		<mark>ві,31 *1</mark>
Timer Word		T00000 ~ T01599		
Counter Word		C00000 ~ C01599		
Data Block (0 ~ 3999)	DB00000.W00000.00~ DB03999.W00382.31	DB00000.W00000 ~ DB03999.W00382		<u>ві</u> , 31 *1
Data Block (4000 ~ 8191)	DB04000.W00000.00~ DB08191.W16383.31	DB04000.W00000 ~ DB08191.W16383		<mark>ві,31)</mark> *1

*1 This is a discrete device but it can be written by only word data. When it is used for bit set or reset, AGP will write the word data that is modified from the read data before write. It has a possibility to happen the confliction between AGP and the PLC ladder program.

*2 Write disable

NOTE

• Please refer to the GP-Pro EX Reference Manual for system data area.

- Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.

6.8 PCD4

Device	Bit Address	Word Address	32 bits	Notes
Internal Bit	F00000 ~ F08191	F00000 ~ F08176		÷16 *1
Input Bit	I00000 ~ I00511	I00000 ~ I00496	[L / H]	÷16 *2
Output Bit	O00000 ~O00511	O00000 ~O00496		÷16
Register Dword	RDX00000.00 ~ RDX04095.31	RDW00000 ~ RDW04095		<u>₿ i t</u> 31 *1
Timer Word		T00000 ~ T01599	ſ	
Counter Word		C00000 ~ C01599		
Data Block (0 ~ 3999)	DB00000.W00000.00~ DB03999.W00382.31	DB00000.W00000 ~ DB03999.W00382		<u>₿ i t</u> 31 *1
Data Block (4000 ~ 7999)	DB04000.W00000.00~ DB07999.W16383.31	DB04000.W00000 ~ DB07999.W16383		<mark>ві,31)</mark> *1

This address can be specified as system data area.

*1 This is a discrete device but it can be written by only word data. When it is used for bit set or reset, AGP will write the word data that is modified from the read data before write. It has a possibility to happen the confliction between AGP and the PLC ladder program.

*2 Write disable

NOTE • Please refer to the GP-Pro EX Reference Manual for system data area.

- Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.

6.9 PCD6

Device	Bit Address	Word Address	32 bits	Notes
Internal Bit	F00000 ~ F08191	F00000 ~ F08176		÷16 *1
Input Bit	I00000 ~ I005119	I00000 ~ I005104	[L / H]	÷16 *2
Output Bit	O00000 ~O005119	O00000 ~O005104		÷16
Register Dword	RDX00000.00 ~ RDX04095.31	RDW00000 ~ RDW04095		<u>₿ i t</u> 31 *1
Timer Word		T00000 ~ T01599	ſ	
Counter Word		C00000 ~ C01599		
Data Block (0 ~ 3999)	DB00000.W00000.00~ DB03999.W00382.31	DB00000.W00000 ~ DB03999.W00382		<u>₿ i t</u> 31 *1
Data Block (4000 ~7999)	DB04000.W00000.00~ DB07999.W16383.31	DB04000.W00000 ~ DB07999.W16383		,31) *1

This address can be specified as system data area.

*1 This is a discrete device but it can be written by only word data. When it is used for bit set or reset, AGP will write the word data that is modified from the read data before write. It has a possibility to happen the confliction between AGP and the PLC ladder program.

*2 Write disable

NOTE • Please refer to the GP-Pro EX Reference Manual for system data area.

- Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.

7 Device Code and Address Code

Use device code and address code when you select "Device Type & Address" for the address type in data displays.

Device	Device Name	Device Code (HEX)	Address Code
Input Relay	Ι	80	Word Address/16
Output Relay	0	81	Word Address/16
Internal Bit	F	82	Word Address/16
Timer Word	Т	60	Word Address
Counter Word	С	61	Word Address
Data Block	DB	00	(Data Block Number x 0x10000) + Word Address
Register DWord	RD	01	Word Address

8 Error Messages

Error messages are displayed on the screen of Display as follows: "No. : Device Name: Error Message (Error Occurrence Area)". Each description is shown below.

Item	Description	
No.	Error No.	
Device Name	Name of External Device where error occurs. Device name is a title of External Device set with GP-Pro EX. (Initial value [PLC1])	
Error Message	Displays messages related to the error which occurs.	
	Displays IP address or device address of External Device where error occurs, or error codes received from External Device.	
Error Occurrence Area	 NOTE IP address is displayed such as "IP address (Decimal): MAC address (Hex)". Device address is displayed such as "Address: Device address". Received error codes are displayed such as "Decimal [Hex]". 	

Display Examples of Error Messages

"RHAA035:PLC1: Error has been responded for device write command (Error Code: 2 [02H])"

NOTE • Please refer to the manual of External Device for more detail of received error codes.

Error Code Peculiar to External Device

The error code peculiar to External Device is as follows.

Error Code	Description	Comment
0x01	NAK	If a command from Display is not acceptable for PCD because of such reasons as exceeding its address range, unconfigured DB, this will be returned. No more information will be provided from PCDs.
0x02	NAK because of password	The PCD is locked against data communication. It must be first unlocked by the programming software.
0x03	NAK because the port is configured with the reduced protocol	This error code will be issued only when the programming software tries to access PCD while it is communicating in the data communication mode.
0x04	NAK because the port is occupied for programming	The port is not configured for data mode. The External Device has to be re-configured with the ladder application.