JW Series Computer Link Ethernet Driver

1	System Configuration	3
2	Selection of External Device	5
3	Example of Communication Setting	6
4	Setup Items	10
5	Supported Device	14
6	Device Code and Address Code	20
7	Error Messages	23

PREFACE

This manual describes how to connect the Display and the External Device (target PLC). In this manual, the connection procedure will be described by following the below sections:

1 System Configuration "1 System Configuration" (page 3) This section shows the types of External Devices which can be connected and SIO type. 2 Selection of External Device "2 Selection of External Device" (page 5) Select a model (series) of the External Device to be connected and connection method. 3 **Example of Communication Settings** "3 Example of Communication Setting" (page This section shows setting examples for 6) communicating between the Display and the External Device. Setup Items 4 "4 Setup Items" (page 10) This section describes communication setup items on the Display. Set communication settings of the Display with GP-Pro EX or in off-line mode. Operation

1 System Configuration


The system configuration in the case when the External Device of SHARP MS Corporation and the Display are connected is shown.

Series Name	CPU	Link I/F*1	SIO Type	Setting Example
JW	311CU 312CU 321CU 322CU 331CU	JW-25TCM JW-255CM	Ethernet (UDP)	Setting Example 1 (page 6)
	332CU 341CU 342CU 352CU 362CU		Ethernet (TCP)	Setting Example 2 (page 8)


^{*1} Available with the Ethernet units compatible with JW300."300" is labeled on the front of JW300-compatible units. For more information, contact the manufacturer of the External Device.

■ Connection Configuration

[1:1 Connection]




[1:n Connection]




^{*1} You can connect up to 32 units of External Device for UDP, and 16 units of External Device for TCP at the same time.

[n:1 Connection]





[n:m Connection]



*1 You can connect up to 32 units of External Device for UDP, and 16 units of External Device for TCP at the same time.

2 Selection of External Device





Setup Items	Setup Description			
Maker	Select the maker of the External Device to be connected. Select "SHARP MS Corporation".			
Select a model (series) of the External Device to be connected and connection Select "JW Series Computer Link Ethernet". Check the External Device which can be connected in "JW Series Computer Ethernet" in system configuration. "1 System Configuration" (page 3)				
Use System Area	 Check this option when you synchronize the system data area of the Display and the (memory) of the External Device. When synchronized, you can use the ladder progrethe External Device to switch the display or display the window on the Display. Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)" This can be also set with GP-Pro EX or in off-line mode of the Display. Cf. GP-Pro EX Reference Manual "5.14.6 Setting Guide of [System Setting Window] ■ Setting Guide of [Main Unit Settings] ■ System Area Setting 			
	Cf. Maintenance/Troubleshooting "2.14.1 Settings common to all Display models ◆System Area Settings"			
Port	Select the port of the Display to be connected to the External Device from "Ethernet (UDP)" and "Ethernet (TCP)".			

3 Example of Communication Setting


Examples of communication settings of the Display and the External Device, recommended by Digital Electronics Corp., are shown.

3.1 Setting Example 1

■ Settings of GP-Pro EX

Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.



◆ Device Setting

To display the setting screen, click [[Setting]] of the External Device you want to set from [Device-Specific Settings] of [Device/PLC Settings].



Settings of External Device

Use the ladder software (JW-300SP) for the communication settings of the Ethernet unit.

To set the Ethernet unit No., use the unit No. switch on the back of the unit.

Please refer to the manual of the External Device for more details on the settings.

Settings of Ethernet Module

1. Set the unit No. using the unit No. switch on the back of the Ethernet unit. You can select from 0 to 7.

IMPORTANT • Be sure not to duplicate unit Nos. between different units.

- 2. Start up the ladder software.
- 3. To transfer the communication settings from the ladder software to the External Device, follow these steps:

 From the [Online] menu, select [Communication Settings] to display the [Communication Settings] dialog box.

Select [PLC(PG)] and then click the [Detail Settings] button to display the [PLC Device Parameter Settings] dialog box. In this dialog box, set the communication settings.

4. Create a new project. In the [Device Selection] dialog box displayed when you create the project, select the External Device to use.

In the confirmation dialog box displayed when you complete the project, click [Yes] to read out the unit configuration of the External Device.

- The read out unit configuration is displayed.Enter the Ethernet unit No. in [Unit No.SW] of [Option Unit].
- 6. Right-click [Option Unit], select [Additional Change] [Option Unit] from the displayed menu, and then select the External Device to use.

When you select the External Device, the parameter settings dialog box appears. Set the communication settings of the Ethernet unit.

· IP Address

Setup Items	tems Setup Description	
IP Address	Enter the IP address of the External Device. (ex. 192.168.0.1)	
Subnet Mask	Enter the subnet mask of the External Device.	

Connection Settings

Setup Items	Setup Description
No.	0
Open Method	UDP
Source Port No.	1024
Port Setting	DCML

7. From the [Online] menu, select [PLC Transfer] - [Write] to transfer the communication settings to the External Device.

◆ Notes


- Check with the network administrator about the IP address.
- Be sure not to duplicate IP addresses on the same network.

3.2 Setting Example 2

■ Settings of GP-Pro EX

◆ Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.



Device Setting

To display the setting screen, click [[Setting]] of the External Device you want to set from [Device-Specific Settings] of [Device/PLC Settings].



■ Settings of External Device

Use the ladder software (JW-300SP) for the communication settings of the Ethernet unit.

To set the Ethernet unit No., use the unit No. switch on the back of the unit.

Please refer to the manual of the External Device for more details on the settings.

◆ Settings of Ethernet Module

1. Set the unit No. using the unit No. switch on the back of the Ethernet unit. You can select from 0 to 7.

Be sure not to duplicate unit Nos. between different units.

- 2. Start up the ladder software.
- 3. To transfer the communication settings from the ladder software to the External Device, follow these steps: From the [Online] menu, select [Communication Settings] to display the [Communication Settings] dialog box. Select [PLC(PG)] and then click the [Detail Settings] button to display the [PLC Device Parameter Settings] dialog box. In this dialog box, set the communication settings.
- 4. Create a new project. In the [Device Selection] dialog box displayed when you create the project, select the External Device to use.

In the confirmation dialog box displayed when you complete the project, click [Yes] to read out the unit configuration of the External Device.

The read out unit configuration is displayed.
 Enter the Ethernet unit No. in [Unit No.SW] of [Option Unit].

6. Right-click [Option Unit], select [Additional Change] - [Option Unit] from the displayed menu, and then select the External Device to use.

When you select the External Device, the parameter settings dialog box appears. Set the communication settings of the Ethernet unit.

IP Address

Setup Items	Setup Description		
IP Address	Enter the IP address of the External Device. (ex. 192.168.0.1)		
Subnet Mask	Enter the subnet mask of the External Device.		

Connection Settings

Setup Items	Setup Description
No.	0
Open Method	TCP_Passive
Source Port No.	1024
Port Setting	DCML

7. From the [Online] menu, select [PLC Transfer] - [Write] to transfer the communication settings to the External Device.

◆ Notes

- Check with the network administrator about the IP address.
- Be sure not to duplicate IP addresses on the same network.

4 Setup Items

Set communication settings of the Display with GP-Pro Ex or in off-line mode of the Display.


The setting of each parameter must be identical to that of External Device.

"3 Example of Communication Setting" (page 6)

4.1 Setup Items in GP-Pro EX

■ Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.



Setup Items	Setup Description		
Port No.	Use an integer from "1024 to 65535" to enter the port No. of the Display. If you check [Auto], the port No. will be automatically set.		
Timeout Use an integer from "1 to 127" to enter the time (s) for which the Display was response from the External Device.			
Retry	In case of no response from the External Device, use an integer from "0 to 255" to enter how many times the Display retransmits the command.		
Wait To Send	Use an integer from "0 to 255" to enter standby time (ms) for the Display from receiving packets to transmitting next commands.		

■ Device Setting

To display the setting screen, click [[Setting]] of the External Device you want to set from [Device-Specific Settings] of [Device/PLC Settings].

When connecting multiple External Devices, you can click from [Device-Specific Settings] of [Device/PLC Settings] to add the External Device which is available to set.



Setup Items	Setup Description		
Series	Select a model of the External Device.		
IP Address	Set the IP address of the External Device. MEMO Check with the network administrator about the IP address. Be sure not to duplicate IP addresses.		
Port No.	Use an integer from "1024 to 65535" to enter the port No. of the External Device.		


4.2 Settings in Off-Line Mode



- Please refer to Maintenance/Troubleshooting for more information on how to enter off-line mode or about operation.
- Cf. Maintenance/Troubleshooting "2.2 Offline Mode"

■ Communication Settings


To display the setting screen, touch [Device/PLC Settings] from [Peripheral Equipment Settings] in the off-line mode. Touch the External Device you want to set from the displayed list.



Setup Items	Setup Description		
Port No. Set the Port No. of the Display. Select either "Fixed" or "Auto". If you select [Fixed], use an integer from "1024 to enter the port No. of the Display. If you select [Auto], the port No. will be autoassigned regardless of the entered value.			
Timeout	Use an integer from "1 to 127" to enter the time (s) for which the Display waits for the response from the External Device.		
Retry	In case of no response from the External Device, use an integer from "0 to 255" to enter how many times the Display retransmits the command.		
Wait To Send	Use an integer from "0 to 255" to enter standby time (ms) for the Display from receiving packets to transmitting next commands.		

■ Device Setting

To display the setting screen, touch [Device/PLC Settings] from [Peripheral Equipment Settings]. Touch the External Device you want to set from the displayed list, and touch [Device Settings].



Setup Items	Setup Description		
Device/PLC Name Select the External Device to set. Device name is a title of the External Dev Pro EX. (Initial value[PLC1])			
Series Displays a model of the External Device.			
IP Address	Set the IP address of the External Device. MEMO Check with the network administrator about the IP address. Be sure not to duplicate IP addresses.		
Port No.	Use an integer from "1024 to 65535" to enter the port No. of the External Device.		

5 Supported Device

Range of supported device address is shown in the table below.

5.1 JW-31x Series

: This address can be specified as system data area.

Device	Bit Address	Word Address	32 bit	Remarks
Relay	000000 - 075777	A00000 - A07576		<u>÷ 2]</u>
Timer (Contact) Counter (Contact)	T00000 - T01777	-		
	C00000 - C01777	-		
Timer/Counter (Current Value)	-	B00000 - B03776		<u>÷ 2</u>]
Timer/Counter (Current Value)	-	TC00000 - TC01777		
	-	09000 - 09776		
Register	-	19000 - 19776		
(09, 19, 29, 39, 49, 59, 69,				<u>₅, 15)</u> ÷2)
79, 89, 99)	-	89000 - 89776		<u>÷ 2</u>)
	-	99000 - 99776		
	-	E0000 - E0776		
Register	-	E1000 - E1776	[L/H]	
(E0, E1, E2, E3, E4, E5,				<u>₿; 15</u>]
E6, E7)	-	E6000 - E6776		<u>÷ 2</u>]
	-	E7000 - E7776		
	-	109000 - 109776		
	-	119000 - 119776		
Register (109 to 389)				<u> </u>
,	-	379000 - 379776		<u>÷ 2</u>]
	-	389000 - 389776		
Register Z	-	Z000 - Z377]	<u>в і 1</u> 5)
File Register	-	-		
System Memory (#)	-	SYS0000 - SYS2776		÷ 2

^{*1} Write disable

МЕМО

- Please refer to the GP-Pro EX Reference Manual for system data area.
- Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.

"Manual Symbols and Terminology"

5.2 JW-32x Series

: This address can be specified as system data area.

Device	Bit Address	Word Address	32 bit	Remarks
Relay	000000 - 153777	A00000 - A15376		<u>÷ 2</u>]
Timer (Contact)	T00000 - T03777	-		
Counter (Contact)	C00000 - C03777	-		
Timer/Counter (Current Value)	-	B00000 - B07776		<u>÷ 2)</u>
Timer/Counter (Current Value)	-	TC00000 - TC03777		
	-	09000 - 09776	ì	
Register	-	19000 - 19776		
(09, 19, 29, 39, 49, 59, 69,				<u> </u>
79, 89, 99)	-	89000 - 89776		<u>÷ 2</u>]
	-	99000 - 99776		
	-	E0000 - E0776		
Pagistar	-	E1000 - E1776	[L/H]	
Register (E0, E1, E2, E3, E4, E5, E6, E7)				<u>₿ ; ,15</u>]
	-	E6000 - E6776		<u>÷</u> 2]
	-	E7000 - E7776		
Register (109 to 389)	-	109000 - 109776		
	-	119000 - 119776		
				<u>₿;,15</u>]
	-	379000 - 379776		<u>÷ 2</u>]
	-	389000 - 389776		
Register Z	-	Z000 - Z377		_{в і 1} 15)
File Register	-	1-00000000 - 1-00077776		<u>□ 15</u>]
System Memory (#)	-	SYS0000 - SYS2776		÷ 2)

^{*1} Write disable

МЕМО

- Please refer to the GP-Pro EX Reference Manual for system data area.
- Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.

"Manual Symbols and Terminology"

5.3 JW-33x/34x/35x/36x Series

: This address can be specified as system data area.

Device	Bit Address	Word Address	32 bit	Remarks
Relay	000000 - 543777	A00000 - A54376		<u>÷</u> 2]
Timer (Contact)	T00000 - T17777	-		
Counter (Contact)	C00000 - C17777	-		
Timer/Counter (Current Value)	-	B00000 - B37776		<u>÷ 2]</u>
Timer/Counter (Current Value)	-	TC00000 - TC17777		
	-	09000 - 09776		
Register	-	19000 - 19776		
(09, 19, 29, 39, 49, 59, 69,				<u> </u>
79, 89, 99)	-	89000 - 89776		<u>÷ 2</u>]
	-	99000 - 99776		
	-	E0000 - E0776	 	
Register	-	E1000 - E1776		
(E0, E1, E2, E3, E4, E5,				<u>₿;,15</u>]
E6, E7)	-	E6000 - E6776	∏ ΓL/H)	<u>÷ 2</u>]
	-	E7000 - E7776		
	-	109000 - 109776		
	-	119000 - 119776		
Register (109 to 389)				<u> </u>
, , ,	-	379000 - 379776		<u>÷ 2</u>]
	-	389000 - 389776		
Register Z	-	Z000 - Z377		<u>в і т</u> 15
File Register	-	1-00000000 - 1-00377776		JW-33x Series B 15
	-	1-00000000 - 1-01777776		JW-34x Series $\frac{15}{15}$ \div 2
	-	1-00000000 - 1-07777776		JW-35x Series $\frac{15}{15} \div 2$
	-	1-00000000 - 1-37777776		JW-36x Series $\frac{15}{2}$ $\frac{2}{2}$
System Memory (#)	-	SYS0000 - SYS2776		÷2

^{*1} Write disable

МЕМО

- Please refer to the GP-Pro EX Reference Manual for system data area.
- Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.

"Manual Symbols and Terminology"

6 Device Code and Address Code

Use device code and address code when you select "Device Type & Address" for the address type in data displays.

Device	Device Name	Device Code (HEX)	Address Code
Relay	A	0080	Value of word address divided by 2
Timer/Counter (Current Value)	В	0061	Value of word address divided by 2
Timer/Counter (Current Value)	TC	0060	Word Address
Register (09)	09	0000	Value of word address divided by 2
Register (19)	19	0001	Value of word address divided by 2
Register (29)	29	0002	Value of word address divided by 2
Register (39)	39	0003	Value of word address divided by 2
Register (49)	49	0004	Value of word address divided by 2
Register (59)	59	0005	Value of word address divided by 2
Register (69)	69	0006	Value of word address divided by 2
Register (79)	79	0007	Value of word address divided by 2
Register (89)	89	0008	Value of word address divided by 2
Register (99)	99	0009	Value of word address divided by 2
Register (E0)	E0	000a	Value of word address divided by 2
Register (E1)	E1	000Ь	Value of word address divided by 2
Register (E2)	E2	000c	Value of word address divided by 2
Register (E3)	E3	000d	Value of word address divided by 2
Register (E4)	E4	000e	Value of word address divided by 2

Device	Device Name	Device Code (HEX)	Address Code
Register (E5)	E5	000f	Value of word address divided by 2
Register (E6)	E6	0010	Value of word address divided by 2
Register (E7)	E7	0011	Value of word address divided by 2
Register (109)	109	0040	Value of word address divided by 2
Register (119)	119	0041	Value of word address divided by 2
Register (129)	129	0042	Value of word address divided by 2
Register (139)	139	0043	Value of word address divided by 2
Register (149)	149	0044	Value of word address divided by 2
Register (159)	159	0045	Value of word address divided by 2
Register (169)	169	0046	Value of word address divided by 2
Register (179)	179	0047	Value of word address divided by 2
Register (189)	189	0048	Value of word address divided by 2
Register (199)	199	0049	Value of word address divided by 2
Register (209)	209	004a	Value of word address divided by 2
Register (219)	219	004b	Value of word address divided by 2
Register (229)	229	004c	Value of word address divided by 2
Register (239)	239	004d	Value of word address divided by 2
Register (249)	249	004e	Value of word address divided by 2
Register (259)	259	004f	Value of word address divided by 2
Register (269)	269	0050	Value of word address divided by 2

Device	Device Name	Device Code (HEX)	Address Code
Register (279)	279	0051	Value of word address divided by 2
Register (289)	289	0052	Value of word address divided by 2
Register (299)	299	0053	Value of word address divided by 2
Register (309)	309	0054	Value of word address divided by 2
Register (319)	319	0055	Value of word address divided by 2
Register (329)	329	0056	Value of word address divided by 2
Register (339)	339	0057	Value of word address divided by 2
Register (349)	349	0058	Value of word address divided by 2
Register (359)	359	0059	Value of word address divided by 2
Register (369)	369	005a	Value of word address divided by 2
Register (379)	379	005b	Value of word address divided by 2
Register (389)	389	005c	Value of word address divided by 2
Register Z	Z	0037	Word Address
File Register	1-	0039	Value of word address divided by 2
System Memory (#)	SYS	0062	Value of word address divided by 2

7 Error Messages

Error messages are displayed on the Display screen as follows: "No. : Device Name: Error Message(Error Occurrence Area)". Each description is shown below.

Item	Description
No.	Error No.
Device Name	Name of the External Device where error occurs. Device name is a title of the External Device set with GP-Pro EX. ((Initial value [PLC1])
Error Message	Displays messages related to the error which occurs.
Error Occurrence Area	Displays IP address or device address of the External Device where error occurs, or error codes received from the External Device. MEMO • IP address is displayed such as "IP address (Decimal):MAC address (Hex)". • Device address is displayed such as "Address: Device address".
	Received error codes are displayed such as "Decimal[Hex]".

Display Examples of Error Messages

"RHAA035: PLC1: Error has been responded for device write command (Error Code: 2[02H])"



- Please refer to the manual of the External Device for more detail of received error codes.
- Please refer to "If the error is displayed (Error Code List)" in "Maintenance/Troubleshooting Guide" for more detail of the error messages common to the driver.