Pro-face



Device/PLC Connection Manuals



About the Device/PLC Connection Manuals

Prior to reading these manuals and setting up your device, be sure to read the "Important: Prior to reading the Device/PLC Connection manual" information. Also, be sure to download the "Preface for Trademark Rights, List of Units Supported, How to Read Manuals and Documentation Conventions" PDF file. Furthermore, be sure to keep all manual-related data in a safe, easy-to-find location.

Shinko Technos

Maximum Number of Consecutive Device Address

The following lists the maximum number of consecutive addresses that can be read by each PLC. Refer to these tables to utilize *Block Transfer*.



A.1

When the device is setup using the methods below, the Data Communication Speed declines by the number of times the device is read.

- When consecutive addresses exceed the maximum data number range
- When an address is designated for division
- When device types are different

To speed up data communication, plan the tag layout in screen units, as consecutive devices. (Includes the Alarm and Trend screens.)

Controllers

<C/FC/FIR/GC/FCL/PC-900 Series>

Device	Max. No. of Consecutive Address	
DataItems	1 Word	
Setting Value Memory 1 to 7	1 Word	
Channel 1 to 20	1 Word *1	

*1 Although only a single word can be read at a time from a single controller, up to 20 channels can be read simulataneously.

A.2 Device Codes and Address Codes

Device codes and address codes are used to specify indirect addresses for the E-tags or K-tags.

The word addresses of data to be displayed are coded and stored in the word address specified by the E-tags and K-tags. (Code storage is done either by the PLC, or with T-tag and K-tags)

Contorollers

<C/FC/FIR/GC/FCL/PC-900 Series>

	Device	Word Address	Device Code (HEX)	Address Code
		0001 ~	8000	Word Address - 1
		0401 ~	8200	Word Address -0x401
		0801 ~	8400	Word Address -0x801
		0C01 ~	8600	Word Address -0xC01
		1001 ~	8800	Word Address -0x1001
		1401 ~	8A00	Word Address -0x1401
		1801 ~	8C00	Word Address -0x1801
		1C01 ~	8E00	Word Address -0x1C01
		2001 ~	9000	Word Address -0x2001
		2401 ~	9200	Word Address -0x2401
		2801 ~	9400	Word Address -0x2801
		2C01 ~	9600	Word Address -0x2C01
		3001 ~	9800	Word Address -0x3001
	Data Items	3401 ~	9A00	Word Address -0x3401
		3801 ~	9C00	Word Address -0x3801
		3C01 ~	9E00	Word Address -0x3C01
		4001 ~	A000	Word Address -0x4001
		4401 ~	A200	Word Address -0x4401
		4801 ~	A400	Word Address -0x4801
		4C01 ~	A600	Word Address -0x4C01
		5001 ~	A800	Word Address -0x5001
		5401 ~	AA00	Word Address -0x5401
		5801 ~	AC00	Word Address -0x5801
		5C01 ~	AE00	Word Address -0x5C01
		6001 ~	B000	Word Address -0x6001
		6401 ~	B200	Word Address -0x6401
		6801 ~	B400	Word Address -0x6801
		6C01 ~	B400 B600	Word Address -0x6C0
	•	7001 ~	B800	Word Address -0x7001
Word		7401 ~	BA00	Word Address -0x7401
		7401 ~	BA00 BC00	Word Address -0x7401 Word Address -0x7801
)evice		7601 ~ 7C01 ~	BE00	Word Address -0x760
	Sotting Value Momery 1	1\$0001 ~	C000	Word Address -0x7C0
	Setting Value Memory 1	2\$0001 ~	C200	Word Address -1
	Setting Value Memory 2	3\$0001 ~	C400	Word Address -1
	Setting Value Memory 3	4\$0001 ~	C400 C600	Word Address -1
	Setting Value Memory 4		C800	
	Setting Value Memory 5	<u>5\$0001 ~</u>		Word Address -1
	Setting ValueMemory 6	<u>6\$0001 ~</u>	CA00	Word Address -1
	Setting Value Memory 7	7\$0001 ~	CC00	Word Address -1
	Channel 1	1CH01 ~	D000	Word Address -1
	Channel 2	2CH01 ~	D200	Word Address -1
	Channel 3	3CH01 ~	D400	Word Address -1
	Channel 4	4CH01 ~	D600	Word Address -1
	Channel 5	5CH01 ~	D800	Word Address -1
	Channel 6	6CH01 ~	DA00	Word Address -1
	Channel 7	7CH01 ~	DC00	Word Address -1
	Channel 8	8CH01 ~	DE00	Word Address -1
	Channel 9	9CH01 ~	E000	Word Address -1
	Channel 10	10CH01 ~	E200	Word Address -1
	Channel 11	<u>11CH01 ~</u>	E400	Word Address -1
	Channel 12	12CH01 ~	E600	Word Address -1
	Channel 13	13CH01 ~	E800	Word Address -1
	Channel 14	14CH01 ~	EA00	Word Address -1
	Channel 15	15CH01 ~	EC00	Word Address -1
	Channel 16	16CH01 ~	EE00	Word Address -1
	Channel 17	17CH01 ~	F000	Word Address -1
	Channel 18	18CH01 ~	F200	Word Address -1
	Channel 19	19CH01 ~	F400	Word Address -1
		20CH01 ~	F600	Word Address -1
	Channel 20	200HUT~	F 000	Word Address - I

GP-PRO/PBIII for Device Connection Manual