

# **Pro-face**



# **Preface**

Thank you for purchasing Pro-face's PRO-iO2 module. The PRO-iO2 is an easy-to-use logic relay control module that contains a variety of useful features. Also, the PRO-iO2 Editor software lets you easily modify logic program functions (Calendar, timer, counter, input/output), making this module useful in fields as diverse as Factory Automation (Machine assembly, etc.), Building Automation (Electric power control, air conditioning, etc.) as well as in agriculture, amusement parks, and others.

Please read this manual carefully as it explains, step by step, how to use the PRO-iO2 module correctly and safely. Also, be sure to read this manual to fully understand the PRO-iO2 module's features and correct installation procedures.

#### <Notice>

- It is forbidden to copy the contents of this manual, in whole or in part, except for the user's personal use, without the express permission of Digital Electronics Corporation of Japan.
- 2) The information provided in this manual is subject to change without notice.
- 3) This manual has been written with care and attention to detail. However, should you find any errors or omissions, please contact Digital Electronics Corporation and inform them of your findings.
- 4) Please be aware that Digital Electronics Corporation shall not be held liable by the user for any damages, losses, or third party claims arising from any use of this product.

All Company/Manufacturer names used in this manual are the registered trademarks of the respective companies.

© 2005 Digital Electronics Corporation

# **Table of Contents**

	Preface 1				
	Table of Contents				
	Essential Safety Precautions4				
	Documentation Conventions7				
	PRO	-iO2 Mo	dule Model Numbers 8		
	Exter	nsion Mo	dule Model Numbers9		
	PRO-	-iO2 Edit	or10		
	Mode	el Numbe	er Identification10		
	Optio	onal Item	ns		
	UL/c	-UL App	lication Notes		
	CE M	<b>larking</b>	Notes		
<u> </u>	1	. 4 0			
Cna	apter	1 Spe	ecifications		
	1.1	General	l Specifications1-1		
		1.1.1	Electrical (Power)		
		1.1.2	Environmental		
		1.1.3	Structural		
		1.1.4	DC Input (DR*-***BD)		
		1.1.5	AC Input (DR*-***FU)		
		1.1.6	Analog Comparator Input		
		1.1.7	Relay Output		
	1.2	Part Na	mes and Functions1-9		
	1.3	Externa	al View and Dimensions 1-12		
Ch	antor	2 Inet	allation and Wiring		
Olli					
	2.1		tion2-1		
		2.1.1	Direct Installation (To a panel)		
		2.1.2	DIN Rail Installation		
	2.2				
		2.2.1	DC Power Module		
		2.2.2	AC Power Module		
		2.2.3	Relay Output Wiring		
		2.2.4	Analog Connection (DR*-B1*1BD)2-10		
		2.2.5	Analog Connection (DR*-*2*1BD)		
		2.2.6	Sensor Connection		

#### **Chapter 3 PRO-iO2 Operation** 3.1 Basic Operation and Commands ......3-1 3.1.1 3.1.2 3.1.3 3.2 LCD Display and Menu Screen ......3-5 3.3 Initial Settings ......3-8 3.4 3.4.1 3.4.2 3.4.3 3.4.4 3.4.5 3.4.6 3.4.7 3.4.8 3.4.9 3.4.10 3.4.11 3.4.12 3.4.13 Chapter 4 Backup 4.1 PRO-iO2 Memory Pack......4-1 4.2 Memory Backup during a Power Outage ......4-3 4.2.1 4.2.2 Primary Battery .......4-3 **Chapter 5 Error Messages** 5.1

# **Essential Safety Precautions**

This manual includes procedures that must be followed to operate the PRO-iO2 unit correctly and safely. Be sure to read this manual and any related materials thoroughly to understand the correct operation and functions of this unit.

#### ■ Safety Icons

Throughout this manual the following icons are provided next to PRO-iO2 operation procedures requiring special attention, and provide essential safety information. These icons indicate the following levels of danger:



A hazardous situation that will result in serious injury or even death if instructions are not followed.



A potentially hazardous situation that could result in serious injury or even death if instructions are not followed.



A potentially hazardous situation that could result in minor injury or equipment damage if instructions are not followed.

# **!** DANGER

- An emergency stop circuit and an interlock circuit should be constructed outside of this unit. Constructing these circuits inside this unit may cause a runaway situation, system failure, or an accident due to unit failure.
- A breakdown or malfunction in the output relay can lead to the output signal remaining ON or OFF. To prevent a unit malfunction, be sure to install an external circuit or device that will monitor the signal status and guarantee system operation safety.
- Systems using this unit should be designed so that output signals which would cause a serious accident are monitored from outside the unit.

# **DANGER**

 This unit is designed to be a general-purpose device for general industries and is neither designed nor produced to be used with equipment or systems in potentially lifethreatening conditions. Be sure to contact your local PROiO2 distributor if you are considering using this unit for special purposes, including nuclear power control devices, electric power devices, aerospace equipment, medical life support equipment, or transportation vehicles.

# **NWARNING**

- Whenever installing or dismantling wiring, or conducting maintenance or inspections, be sure to disconnect this unit's power cord to prevent the possibility of an electric shock or fire.
- Do not disassemble or redesign this unit, since it may lead to an electric shock or fire.
- Do not use this unit in an environment that contains flammable gases, since an explosion may occur.
- Do not use this unit in an environment that is not specified in either the Installation Guide or this manual. Otherwise, an electric shock, malfunction or other failure may occur.
- Because of the possibility of an electric shock or malfunction, do not touch any power terminals while the unit is operating.

# **ACAUTION**

- Communication cables or I/O signal lines must be wired separately from the main circuit (high-voltage, high-current line), high-frequency lines such as inverter lines, and power lines. Otherwise, a malfunction may occur due to noise.
- Be sure to install this unit according to directions in the Installation Guide and this manual. Improper installation may cause the unit to malfunction or fail.

# **CAUTION**

- Be sure to wire this unit according to directions in the Installation Guide and this manual. Improper wiring may cause the unit to malfunction or fail.
- Do not allow foreign substances, including chips, wire pieces, water or liquids to enter inside this unit's case. Otherwise, a malfunction, failure, electric shock, or fire may occur.
- Be sure this unit is operated only by personnel trained in control system programming and design.
- Do not touch this unit with wet hands or wipe it with a wet cloth. Doing so may cause an electric shock or a fire.
- Be sure to install a fuse, breaker etc. in each of the power, input and output circuits. Failure to do so can lead to a fire if an overload occurs.
- Power and voltage specifications vary depending on the PRO-iO2 unit's model type. Be sure to read the directions in the Installation Guide and this manual before turning this unit's power ON.
- When disposing of this unit, be sure to do so according to your country's standards for industrial waste disposal.

#### ■ To Prevent PRO-iO2 Module Damage

- Do not operate this module either in direct sunlight or excessively dusty or dirty environments.
- Because this module is a precision instrument, do not store or use it in locations where excessive shocks or vibration may occur.
- Do not cover this module's ventilation holes, or operate it in an environment that may cause it to overheat.
- Do not operate this module in locations where sudden temperature changes can cause condensation to form inside the module.
- Do not use paint thinner or organic solvents to clean this module.

# **Documentation Conventions**

The list below describes the documentation conventions used in this manual.

Symbol	Meaning
Important	Indicates important information or procedures that must be followed for correct and risk-free software/device operation.
Note:	Provides useful or important supplemental information.
*1	Indicates useful or important supplemental information.
<b>▼</b> Reference <b>▲</b>	Refers to useful or important supplemental information.

# **PRO-iO2 Module Model Numbers**


The features of each PRO-iO2 module (I/O points, LCD screen, etc.) will vary depending on the model. Also, certain modules can be connected to I/O extension modules.

Model	Power Supply	No.of I/O	LCD Display	I/O Extension Module
Number	Power Suppry	Points	Screen	I/O Exterision would
DR2-B121BD	24VDC	8/4	Yes	Not connectable
DR2-B201BD	24VDC	12/8	Yes	Not connectable
DR2-D101BD	24VDC	38142	No	Not connectable
DR2-D201BD	24VDC	12/8	No	Not connectable
DR2-B121FU	100VAC to 240VAC	8/4	Yes	Not connectable
DR2-B201FU	100VAC to 240VAC	12/8	Yes	Not connectable
DR2-D101FU	100VAC to 240VAC	6/4	No	Not connectable
DR2-D201FU	100VAC to 240VAC	12/8	No	Not connectable
DR3-B101BD	24VDC	6/4	Yes	Connectable
DR3-B261BD	24VDC	16/10	Yes	Connectable
DR3-B101FU	100VAC to 240VAC	6/4	Yes	Connectable
DR3-B261FU	100VAC to 240VAC	16/10	Yes	Connectable



- Even though LCD display-equipped PRO-iO2 modules can be programmed using only the screen display, the easy-to-use PRO-iO2 Editor software (sold separately) is recommended for programming.
- Prior to downloading your logic program to the PRO-iO2 unit you can test and debug logic programs via the PRO-iO2 Editor's simulation feature.

#### To identify Model Numbers:



# **Extension Module Model Numbers**

#### ■ PRO-iO2 I/O Extension Module Models

The PRO-iO2 I/O extension module's number of input/output points varies depending on the model number.

For how to identify the model of your PRO-iO2 module, refer to the following section on "Model Identification"

Model Number	Voltage	No. of Input/Output Points
DR3-XT61BD	24VDC	4/2
DR3-XT141BD	24VDC	8/6
DR3-XT61FU	100VAC to 240VAC	4/2
DR3-XT141FU	100VAC to 240VAC	8/6

#### ■ When Connecting Modules



 Be sure to follow the connection instructions given in the module's Installation Guide and in the User Manual. Connecting modules with incompatible electrical specifications may lead to a module malfunction or breakdown.

When connecting a main module to an extension module, be sure the extension module's model number is DR3-\*\*\*\*\* and has the same power supply voltage rating (AC or DC) as the main module.

The figures given below are the number of input/output points available when the I/O extension module is connected to the PRO-iO2 main module.

Model	DR3-XT61BD	DR3-XT141BD	DR3-XT61FU	DR3-XT141FU
DR2-B121BD	-	-	-	-
DR2-B201BD	-	-	-	-
DR2-D101BD	-	-	-	-
DR2-D201BD	-	-	-	-
DR2-B121FU	-	-	-	-
DR2-B201FU	-	-	-	-
DR2-D101FU	-	-	-	-
DR2-D201FU	-	-	-	-
DR3-B101BD	10/6	14/10	-	-
DR3-B261BD	20/12	24/16	-	-
DR3-B101FU	-	-	10/6	14/10
DR3-B261FU	-	-	20/12	24/16



Only one extension I/O module can be connected.

Two or more modules cannot be connected at the same time.

# PRO-iO2 Editor

PRO-iO2 Editor is a Windows®-based, easy-to-use software that has the following features:


- 2 edit modes:
  - Ladder Logic
  - Electrical Circuit Diagram Method
- Logic program simulation feature
- Use a PC to monitor PRO-iO2 module operation
- Transfer circuit data from the PC to the PRO-iO2 module, or vice-versa
- Program Validation Check
- Creation of Display Messages

For PRO-iO2 Editor details,

▼ Reference \_ "PRO-iO2 Editor Operation Manual"

# **Model Number Identification**

The model number of a PRO-iO2 module can be identified using the marking on the side panel of the PRO-iO2 unit (see below).



# **Optional Items**

The following tables describe PRO-iO2 related software and optional items. Please note that all optional items are sold separately.

#### **■** Editor Software

Name	Model	Description
PRO-iO2 Editor	DR2-SFT01	For logic program development

#### **■** Options

Name	Model Number	Description
PRO-iO2 Data	DR2-CBL01	Connects a PRO-iO2 module to the PC to transfer logic
Transfer Cable		programs.
PRO-iO2		Used with DR*-B***** models to backup (save) logic
Memory Pack	DR2-MEM01	programs. Can copy logic programs to other
WelliolyFack		DR*-B*****-type PRO-iO2 modules.
	DR3-XT61BD	24 VDC extension I/O module, equipped with 4 input and
		2 output points.
	DR3-XT141BD	24 VDC extension I/O module, equipped with 8 input and
PRO-iO2 I/O		6 output points.
Extention module	DR3-XT61FU	100VAC to 240 VAC extension I/O module, equipped with
		4 Input and 2 Output points.
	DR3-XT141FU	100VAC to 240 VAC extension I/O module, equipped with
		8 Input and 6 Output points.

#### ■ Usage Environment PRO-iO2 Editor **Development Environment** \_ PRO-iO2 **Data Transfer Cable** PRO-iO2 **Memory Pack PRO-iO2 Module** 000000000 PRO-iO2 I/O Extension module 000000 00 00 00 00

# **UL/c-UL Application Notes**

Modules DR2-B121BD, DR2-B201BD, DR2-D101BD, DR2-D201BD, DR2-B121FU, DR2-B201FU, DR2-D101FU, DR2-D201FU, DR3-B101BD, DR3-B261BD, DR3-B101FU, DR3-B261FU, DR3-XT61BD, DR3-XT141BD, DR3-XT61FU and DR3-XT141FU are UL/c-UL listed products.

UL File No. E220851

```
DR2-B121BD
               (UL Registration Model No.:DR2-B121BD)
               (UL Registration Model No.:DR2-B201BD)
DR2-B201BD
               (UL Registration Model No.:DR2-D101BD)
DR2-D101BD
DR2-D201BD
               (UL Registration Model No.:DR2-D201BD)
DR2-B121FU
               (UL Registration Model No.:DR2-B121FU)
DR2-B201FU
               (UL Registration Model No. :DR2-B201FU)
               (UL Registration Model No.: DR2-D101FU)
DR2-D101FU
               (UL Registration Model No. :DR2-D201FU)
DR2-D201FU
DR3-B101BD
               (UL Registration Model No.: DR3-B101BD)
DR3-B261BD
               (UL Registration Model No.:DR3-B261BD)
DR3-B101FU
               (UL Registration Model No.:DR3-B101FU)
               (UL Registration Model No.:DR3-B261FU)
DR3-B261FU
               (UL Registration Model No.:DR3-XT61BD)
DR3-XT61BD
               (UL Registration Model No. :DR3-XT141BD)
DR3-XT141BD
               (UL Registration Model No. :DR3-XT61FU)
DR3-XT61FU
DR3-XT141FU (UL Registration Model No.:DR3-XT141FU)
```

The PRO-iO2 module and PRO-iO2 extension I/O module conform to the following standards.

- UL508 Electrical Control Systems for Industry
- CAN/CSA-C22.2, No.142-M1987 (c-UL listed) Electrical Control Systems for Industry

#### <Notes>

Note the following points when applying for UL certification of equipment on which a PRO-iO2 module or PRO-iO2 extension I/O module is installed.

- The PRO-iO2 module is designed to be used only when installed in other equipment.
- If the module is installed in an area with no air conditioning system, be sure to install it in a vertical panel using a DIN rail or mounting holes.

Also, be sure the module is installed so it is at least 100 mm away from any adjacent structures or devices. If these requirements are not met, the heat generated by the module's internal components may cause the module to fail to meet UL standard requirements.

- The power supply connected to the module must be a UL/c-UL approved Class 2 power supply module or Class 2 transformer\*1.
  - When a PRO-iO2 module under load is operated with a single power supply, the amount of current consumption and full-load current of the I/O modules must be within the rated load of a Class 2 power supply module or a Class 2 power supply transformer.
  - Be aware that the number of points which can be turned ON simultaneously may be limited, depending on the amount of load and the load current value.
- \*1 Class 2 power supplies and Class 2 transformers should not exceed an output of 30V, and at 8A or less, should not exceed 100VA. (National Electrical Code)

# **CE Marking Notes**

Modules DR2-B121BD, DR2-B201BD, DR2-D101BD, DR2-D201BD, DR2-B121FU, DR2-B201FU, DR2-D101FU, DR2-D201FU, DR3-B101BD, DR3-B261BD, DR3-B101FU, DR3-B261FU, DR3-XT61BD, DR3-XT141BD, DR3-XT61FU and DR3-XT141FU are CE marked products that conform to EMC directives EN55011 Class B, EN61000-6-2 and EN61131-2.

# Memo

# Chapter 1 Specifications

- 1. General Specifications
- 2. Part Names and Functions
- 3. External View and Dimensions

This chapter describes the general specifications, part names, and external view of the PRO-iO2 module.

# 1.1 General Specifications

#### 1.1.1 Electrical (Power)

#### **■** DR\*-\*\*\*BD (DC Power)

	24VD0		
Allowable Voltage Range	19.2VDC to 30VDC		
Allowable Voltage Drop	1ms or le	ess	
	DR2-*1*1BD	3W	
	DR2-*201BD	6W	
Dawas Camarum tian	DR3-B101BD	3W	
Power Consumption	(With I/O Extension Module)	8W	
	DR3-B261BD	6W	
	(With I/O Extension Module)	10W	
In-Rush Current	30A or less		
Insulation Endurance	1500VAC 5mA (Between output termin	for 1 minute nals and DIN Rail)	
Insulation Resistance	100MΩ or higher at 500VDC (Between output terminals and DIN Rail)		

#### ■ DR\*-\*\*\*FU (AC Power)

Rated Voltage	100VAC to 240VAC		
Allowable Voltage Range	85VAC to 264VAC		
Rated Frequency	50Hz/60	0Hz	
Allowable Frequency Range	47Hz to 6	3Hz	
Allowable Voltage Drop	10ms or	less	
	DR2-*1*1FU	7VA	
	DR2-*201FU	11VA	
D. C.	DR3-B101FU	7VA	
Power Consumption	(With I/O Extension Module)	12VA	
	DR3-B261FU	12VA	
	(With I/O Extension Module)	17VA	
In-Rush Current	30A or less		
Insulation Endurance	1500VAC 5mA (Between output termir		
Insulation Resistance	100MΩ or higher at 500VDC (Between output terminals and DIN Rail)		

# **PRO-iO2 Specifications**

## 1.1.2 Environmental

Ambient Operating Temperature	0°C to 55°C	
Storage Temperature	-25°C to +70°C	
Ambient Operating	95%RH or less (No condensation)	
Humidity	Wet bulb temperature: 39°C or less	
Ctoro ao Humidita	95%RH or less (No condensation)	
Storage Humidity	Wet bulb temperature: 39°C or less	
Pollution Level	Level 2	
Atmospheric Pressure	800hPa to 1114hPa	
(Operating Altitude)	(At 2000m or less)	
	IEC60068-2-6 Compliant	
	10Hz to 57Hz 0.075mm	
Vibration Endurance	57Hz to 150Hz 9.8m/s <sup>2</sup>	
	X, Y, Z directions 10 times each (80 minutes)	
01 - 1 5 - 1	IEC60068-2-27 Compliant	
Shock Endurance	(147m/s <sup>2</sup> , 3 times in X, Y, and Z directions)	
Electrostatic Discharge	Contact discharge 6kV	
Immunity	(IEC61000-4-2 level 3)	
Electric Field Endurance	IEC61000-4-3 level 3	
First Transient Endurance	IEC61000-4-4 level 3	
Surge Endurance IEC61000-4-5 level 3		

## 1.1.3 Structural


Ratings	IP20		
Cooling Method	Natural air circulation		
	DR2-B121** : 250g or less		
	DR2-B201** : 380g or less		
	DR2-D101** : 220g or less		
	DR2-D201** : 350g or less		
Weight	DR3-B101**: 250g or less		
	DR3-B261** : 400g or less		
	DR3-XT61**: 125g or less		
	DR3-XT141**: 220g or less		
	DR*-*1*1**		
	W71.2[2.80] x D90.0[3.54] x H57.4[2.26] mm[in.]		
	DR*-*2*1**		
External Dimensions	W124.6[4.91] x D90.0[3.54] x H57.4[2.26] mm[in.]		
External Dimensions	DR3-XT61**		
	W35.5[1.40] x D90.0[3.54] x H54.0[2.13] mm[in.]		
	DR3-XT141**		
	W72.0[2.83] x D90.0[3.54] x H54.0[2.13] mm[in.]		

#### 1.1.4 DC Input (DR\*-\*\*\*BD)

Model Nun	nber	I1 to IA, IH to IR	IB to IG
Input Volt	age	24VDC	
Rated Cur	rent	4mA	
Input Imped	lance	7.4kΩ (at ON)	12kΩ (at ON)
		6 Points (DR*-*1	01BD)
		8 Points (DR2-B1	21BD)
No of Innut	Dainta	12 Points (DR2-×2	201BD)
No. of Input	Points	16 Points (DR3-B2	261BD)
		4 Points (DR3-XT	61BD)
		8 Points (DR3-XT141BD)	
	ON Voltage	15VDC or more	15VDC or more
Operating Voltage		(2.20mA or more)	(1.20mA or more)
Operating voltage	OFF Voltage	5VDC or less	5VDC or less
		(0.75mA or less)	(0.45mA or less)
Input Delay	$OFF \to ON$	0.3ms (FAST) / 3ms (SLOW)*1	3ms (Fixed)
(Letters in parentheses indicate filter setting)	$ON \to OFF$	0.5ms (FAST) / 5ms (SLOW)*1	5ms (Fixed)
Maximum Frequency* <sup>2</sup>		1kHz	-
Input Signal Display		via LCD (Models DR*-B**** only)	
Insulation Method		No insulation between input points, and between	
modiation w		input points and power supply	

<sup>\*1</sup> The delay time varies depending on the input filter setting. This setting is common for all points.

#### ■ DR\*-\*\*\*BD Input Circuit (DC Input)




<sup>\*2</sup> The terminals used for the high-speed counter are I1 (up counter) and I2 (down counter).

# **PRO-iO2 Specifications**

# 1.1.5 AC Input (DR\*-\*\*\*FU)

Input Voltage		100VAC to 240VAC	
Rated Frequency		50/60Hz	
Rated Current		0.6mA	
Input Impedance		350kΩ	
No. of Input Points		6 Points (DR*-*101FU)	
		8 Points (DR2-B121FU)	
		12 Points (DR2-*201FU)	
		16 Points (DR3-B261FU)	
		4 Points (DR3-XT61FU)	
		8 Points (DR3-XT141FU)	
Operating Voltage	ON Voltage	79VAC or more (0.1750mA or more)	
Operating Voltage	OFF Voltage	40VAC or less (0.05mA or less)	
Input Delay	$OFF \to ON$	50ms	
iliput Delay	$ON \rightarrow OFF$	50ms	
Input Signal Display		via LCD (Models DR*-B**** only)	
Insulation Method		No insulation between input points,	
		and between input points and power supply	

## ■ DR\*-\*\*\*FU Input Circuit (AC Input)




## 1.1.6 Analog Comparator Input

	DR2-D201BD	2 (IB,IC)	
No. of Input Channels	DR*-B1*1BD	4 (IB,IC,ID,IE)	
	DR*-B2*1BD	6 (IB,IC,ID,IE,IF,IG)	
Input Voltage Range	0V to 10V		
Resolution	8 bits		
Accuracy	Full-scale value ±5% (at 25°C)		
Accuracy	Full-scale value ±6.2% (at 55°C)*1		
Absolute Max Input	30VDC (Voltage)		
Input Filter	None		
Conversion Time	Unit cycle time		
Input Impedance	12kΩ		
Inculation Mathead	No insulation between analog input points,		
Insulation Method	and between analog input section and power supply		
Cable Length	10 m max. (Shielded cable)		

<sup>\*1</sup> This accuracy may not be possible if there is a large amount of noise.

#### ■ Analog Input Circuit




#### 1.1.7 Relay Output

Output		Q1 to Q8, QB to QE	Q9, QA, QF, QG	
Rated Outp	ut Voltage	5VDC to 30VDC, 24VAC to 250VAC		
		4 Points (DR*-*1*1**)		
		8 Points (DR2-*201**)		
No. of Out	put Points	10 Points (DR3-B261**)		
		2 Points (DR3-XT61**)		
		6 Points (DR3-XT141**)		
Load Current		8A/1 Point	5A/1 Point	
Common		Independent Common*1		
Mechanical Lifetime		10 million operations		
Electrical Lifetime		100,000 operations at contact rated load		
Min. Open/Close Load		12V, 10mA		
Built-in Fuse		None		
Voltage Endurance		4kV (IEC60947-1, IEC60664-1)		
Output Signal Display		via LCD (Models DR*-B**** only)		
Short Circuit Protection		None		
Overvoltage and Overcurrent Protection		None		
Output Dolov	$OFF \to ON$	10ms or less		
Output Delay	$ON \rightarrow OFF$	5ms c	or less	

<sup>\*1</sup> For DR3-B261\*\*, Q8, Q9, and QA share a single common terminal.


For DR3-XT141\*\*, each of QB-QC, QD-QE, and QF-QG uses a single common terminal respectively.

#### ■ Relay Output Circuit




- Relay Durability Curves
- ♦ For a load current of 8A (Q1 to Q8, QB to QE)






# **PRO-iO2 Specifications**

◆ For a load current of 5A (Q9, QA, QF, QG)





#### 1.2 Part Names and Functions

This section describes the names and functions of each part of the PRO-iO2 module (DR\*-B\*\*\*\*\*).

(1) Module attachment tab (Retracting type)

Used to fasten the main module to the panel with a screw.

- (2) **Power terminals**
- (3) LCD display screen
- (4) **Input terminals**\*1

Depending on the model, PRO-iO2 modules have 6, 8, 12 or 16 input terminals.

(5) Connectors for PRO-iO2 Data Transfer Cable (DR2-CBL01) and PRO-iO2 Memory Pack (DR2-MEM01)




Determines each setting or displays the menu screen.

(7) **Shift button** 

While this button is held down and any of the Menu/Ok button and Z keys is pressed, a specified function is executed.

The specified functions are displayed at the bottom of the screen when the Shift button is pressed.



Used to move the cursor position. It can also function as a contact's open/close button when creating/modifying a logic programs.

(9) **DIN Rail detachment hook** 

Used when detaching the main module from a DIN rail.

(10) **Relay output terminals** 

Depending on the model, the PRO-iO2 Modules have 4, 8, or 10 output terminals.

(11) I/O Extension module interface connector\*2

Used to connect the PRO-iO2 module with an I/O extension module (DR3-XT\*\*\*\*).

\*1 The input terminals which can be used for the high-speed counter and analog comparator functions vary depending on the model. For details,

#### **▼Reference ~** "1.1 General Specifications"


When the high-speed counter or analog comparator function is not used, these terminals can be used as standard input terminals. Note that their input specifications are different from other terminals. For details,

**▼Reference ~** "1.1 General Specifications"

\*2 For the models to which an I/O extension unit can be connected:

▼Reference 

"About PRO-iO2 I/O Extension Module"



1-9

#### **PRO-iO2 Specifications**

This section describes the names and functions of each part of the PRO-iO2 module (DR\*-D\*\*\*\*).

#### (1) Module attachment tab (Retracting type)

Used to fasten the main module to the panel with a screw.

#### (2) **Power terminals**

#### (3) **Input terminals**\*1

Depending on the model, PRO-iO2 modules have 6 or 12 input terminals.

# (4) Connectors for PRO-iO2 Data Transfer Cable (DR2-CBL01)

#### (5) U/Run LED

RUN : Flashes slowly (3 times/sec.)

STOP : Lights

Error \*2: Flashes quickly (5 times/sec.)

#### (6) DIN Rail detachment hook

Used when detaching the main module from a DIN rail.

#### (7) Relay output terminals


Depending on the model, the PRO-iO2 Modules have 4 or 8 output terminals.

#### ▼ Reference \_ "1.1 General Specifications"

When the high-speed counter or analog comparator function is not used, these terminals can be used as standard input terminals. Note that their input specifications are different from other terminals. For details,

#### ▼ Reference ▲ "1.1 General Specifications"

\*2 For details about errors, **\rightarrow Reference \rightarrow "5. Error Messages"** 



<sup>\*1</sup> The input terminals which can be used for the high-speed counter and analog comparator functions vary depending on the model. For details,

#### **PRO-iO2 Specifications**

This section describes the names and functions of each part of the PRO-iO2 I/O extension module (DR3-XT\*\*\*\*).

#### Module attachment tab (Retracting type) (1)

Used to fasten the module directly to the panel with a screw.

#### Input terminals\*1 (2)

Depending on the model, the I/O extension modules have 4 or 8 input terminals.

#### (3) Relay output terminals

Depending on the model, the I/O extension modules have 2 or 6 output terminals.

#### **DIN Rail detachment hook** (4)


Used when detaching the main module from a DIN Rail.

#### Guide pin (5)

Used as a guide when the I/O extension modules are connected to the main module (PRO-iO2).

#### (6) Main module connector

Connected to the main module (PRO-iO2).



H I K L N P Q R

Outputs
QB.\_QE: Relay 8A and QF\_QG: Relay 5A **666 666** 

000

\*I The input terminals which can be used for the high-speed counter and analog comparator functions vary depending on the model. For details,

#### **▼Reference ~** "1.1 General Specifications"


When the high-speed counter or analog comparator function is not used, these terminals can be used as standard input terminals. Note that their input specifications are different from other terminals. For details,

▼ Reference ✓ "1.1 General Specifications"

## 1.3 External View and Dimensions

This section provides the external view and dimensions of the PRO-iO2 module.

Unit: mm [in.]



\*1 DR2-D\*\*\*\* modules are not equipped with these operation buttons.

External dimensions for "a" and "b" vary depending on the model, as shown below:


	DR*-*1***	DR*-*2***
а	71.2 mm [2.80 in.]	124.6 mm [4.91 in.]
b	59.9 mm [2.36 in.]	113.3 mm [4.46 in.]



When attaching the PRO-iO2 module to a panel, extend the module's attachment tabs. When attaching the PRO-iO2 module to a DIN rail, retract the module's attachment tabs.

#### **PRO-iO2 Specifications**

The following provides the external view and dimensions of the PRO-iO2 I/O extension module.



External dimensions for "a" and "b" vary depending on the model, as shown below:

	DR3-XT141**	DR3-XT61**
а	72.0 mm [2.83 in.]	35.5 mm [1.40 in.]
b	60.0 mm [2.36 in.]	25.0 mm [0.98 in.]



When attaching the PRO-iO2 I/O extension module to a panel, extend the module's attachment tabs. When attaching the PRO-iO2 I/O extension module to a DIN rail, retract the module's attachment tabs.

# Memo

- 1. Installation
- 2. Wiring

# Chapter

# 2 Installation and Wiring

This chapter describes the installation and wiring procedures for the PRO-iO2 module and PRO-iO2 I/O extension module.

#### 2.1 Installation

This section describes the procedures and precautions for installing the PRO-iO2 module and PRO-iO2 I/O extension module.

# **WARNING**

Prior to installing the PRO-iO2 module or the PRO-iO2 I/O extension module, be sure to disconnect them from the power supply to prevent an electric shock.

#### 2.1.1 Panel Installation


#### ■ Installing the PRO-iO2 Module

Use the dimensions given below when drilling attachment holes in a panel, and secure the module in place using M4 attachment screws. The required screw torque is 1N•m.


When installing the module in a direction other than vertical (i.e. horizontal), be sure to install a cooling fan.

The dimensions in parentheses are for the  $DR^*-*2^{****}$  model.

Unit: mm[in.]



#### **■** Module Orientation



■ Installation Procedure (with PRO-iO2 I/O Extension Module)


# **MARNING**

Prior to connecting the I/O extension module, be sure to disconnect the power to the main module (PRO-iO2). Otherwise, a malfunction or breakdown may occur.


# **A** CAUTION

Since the connector cover can pop open, insert the tip of a flat-blade screwdriver into the groove as shown below, and lift the cover slowly to remove it.

1. Remove the PRO-iO2 module's right-side protective cover and connect the two



2. Drill attachment holes in the panel as shown below and secure the module in place using M4 attachment screws. Required torque is 1N•m.



Dimensions for "a" and "b" in the above diagram will vary depending on the model, as shown in the following table.


	PRO-iO2		I/O Extension Module	
	DR3-B101**	DR3-B261**	DR3-XT61**	DR3-XT141**
а	59.9 <sup>+0.2</sup> <sub>-0.2</sub> mm [2.36 <sup>+0.01</sup> <sub>-0.01</sub> in.]	113.3 <sup>+0.2</sup> mm [4.46 <sup>+0.01</sup> in.]	-	-
b	-	-	25.0 <sup>+0.2</sup> <sub>-0.2</sub> mm [0.98 <sup>+0.01</sup> <sub>-0.01</sub> in.]	60.0 <sup>+0.2</sup> mm [2.36 <sup>+0.01</sup> in.]

#### 2.1.2 DIN Rail Installation

#### ■ PRO-iO2 Module

Check that the module's DIN rail hook is raised (up) and the module is held securely in place.


Unit: mm [in.]






When attaching the PRO-iO2 module to a panel, extend the unit's attachment tabs and attach the unit to the panel using attachment screws. When attaching the PRO-iO2 module to a DIN rail, retract the module's attachment tabs.

#### ■ DIN Rail Module Orientations





■ Installation Procedure (with PRO-iO2 I/O Extension Module)


# **⚠** WARNING

Prior to connecting the I/O extension module, be sure to disconnect the power to the main module (PRO-iO2). Otherwise, a malfunction or breakdown may occur.


# **N** CAUTION

Since the connector cover can pop open, insert the tip of a flat-blade screwdriver into the groove as shown below, and lift the cover slowly to remove it.

1. Remove the PRO-iO2 module's right-side protective cover .



- 2. Attach the PRO-iO2 module and I/O extension module separately on the DIN rail.
- 3. Slide the PRO-iO2 module and I/O extension module together to connect them.



# 2.2 Wiring

# **MARNING**

Prior to installing the PRO-iO2 module or the PRO-iO2 I/O extension module, be sure to disconnect them from the power supply to prevent an electric shock.

#### ■ Wire types

The following types of wires can be used:

Wire Type	Pin-type Terminal		Lay wire	Simple	Wires
mm <sup>2</sup>	0.25 to 2.5	0.25 to 0.75	0.2 to 2.5	0.2 to 2.5	0.2 to 1.5
AWG*1	24 to 14	24 to 18	25 to 14	25 to 14	25 to 16

<sup>\*1</sup> AWG stands for "American Wire Gauge" and indicates conductor thickness.




- Strip the wire's plastic covering to expose approximately 6.8mm [0.3in] of wire.
- When using a lay wire, Pro-face recommends you install a bladetype or pin-type terminal connector.
- The torque required to secure a wire to a terminal is 0.5 N·m.

#### 2.2.1 DC Power Module

The following PRO-iO2 modules use DC power:

DR2-B121BD	DR3-B101BD
DR2-B201BD	DR3-B261BD
DR2-D101BD	(DR3-XT61BD)
DR2-D201BD	(DR3-XT141BD)

Be sure to wire the PRO-iO2 modules using the following wiring diagrams.



\*1 1A Fuse (Fast-break type)

#### 2.2.2 AC Power Module


The following 8 PRO-iO2 modules use AC power:

DR2-B121FU DR3-B101FU
DR2-B201FU DR3-B261FU
DR2-D101FU (DR3-XT61FU)
DR2-D201FU (DR3-XT141FU)

# **WARNING**

Be sure to connect the L (Live, not grounded) terminal to the power supply's non-earthed terminal, and the N (Neutral, grounded) terminal to the power supply's earthed terminal. When a power supply fault occurs (AC line and earth line short), the fuse connected to the L terminal will break and stop the flow of power.

Be sure to perform PRO-iO2 module wiring as shown below.




\*1 1A Fuse (Fast-break type)


2-8 PRO-iO2 User Manual

# 2.2.3 Relay Output Wiring

When operating devices with inductive loads, such as magnets and valves, be sure to use a diode or a varistor for DC power module, and a surge killer or a varistor for AC power module.

Also, to protect the power supply and output, Pro-face recommends you connect a fuse.







- With DR3-B261\*\* modules, Q8, Q9, and QA share a single common terminal.
- With the DR3-XT141 module, QB-QC, QD-QE, and QF-QG use a single common terminal.
- \*1 Fuse (Up to 16A) or circuit breaker.
- \*2 When opening / closing the inductance load, be sure to connect a diode, surge killer, etc. parallel to the load.
- \*3 Surge killer.

# 2.2.4 Analog Connection (DR\*-B1\*1BD)

Wire the following two modules as shown below.

DR2-B121BD (Input channels: IB, IC, ID, IE)
DR3-B101BD (Input channels: IB, IC, ID, IE)

# Analog Output Device \*1 - I1 I2 I3 I4 IB IC ID IE - OOOOOOOO

\*1 1A Fuse (Fast-break type)



- Do not use negative voltages for the analog inputs. Doing so can damage the internal circuit.
- The maximum length of the cable connected to an analog device is 10 m.

2-10 PRO-iO2 User Manual

# 2.2.5 Analog Connection (DR\*-\*2\*1BD)

Wire the following three modules as shown below.

DR2-D201BD (Input channels: IB, IC)

DR2-B201BD (Input channels: IB, IC, ID, IE, IF, IG)

DR3-B261BD (Input channels: IB, IC, ID, IE, IF, IG)

# 24VDC + I1 I2 I3 I4 / ID IE IF IG - -


\*1 1A Fuse (Fast-break type)



- Do not use negative voltages for the analog inputs. Doing so can damage the internal circuit.
- The maximum length of the cable connected to an analog device is 10 m.

#### 2.2.6 Sensor Connection

The PNP output sensor connection diagram is as follows.



\*1 1A Fuse (Fast-break type)



When connecting directly to this unit's input circuit, be sure to use a PNP output-type sensor. You cannot connect directly using a 2-wire type sensor or a NPN-type sensor.

2-12 PRO-iO2 User Manual


#### **■** Example of NPN-type Sensor Connection

A PRO-iO2 module and NPN-type sensor can be connected using a resistor via external wiring as shown in the following circuit diagram. Connect the devices as illustrated below, and reverse the input logic in the logic program before starting operation.

Resistors required for wiring are included in the DR\*-\*\*\*BD package for your convenience. Use 2.0-k $\Omega$  resistors for normal input terminals (I1 to IA), and use 6.2-k $\Omega$  resistors for analog input dual-purpose terminals (IB to IG). All of the supplied resistors may not be used depending on the model of the PRO-iO2 module.

The circuit diagram examples below show how to connect a sensor to input terminals I3 and IB of the PRO-iO2 module.


# ◆ Connecting to a normal input terminal (I1 to IA):





- The above circuit's input logic is reversed from the PNP.
- When an NPN sensor is connected, use an external resistance of  $2.0k\Omega$  and 1W or more.

# ◆ Connecting to an analog input dual-purpose terminal (IB to IG):






- The above circuit's input logic is reversed from the PNP.
- When an NPN sensor is connected, use an external resistance of  $6.2k\Omega$  and 1/4W or more.

# **Installation and Wiring**

Resistors required for wiring are included in the DR3-XT\*\*\*BD package for your convenience. Use a 3.9-k $\Omega$  resistor for a normal input terminal. It is not necessary to use all of the supplied resistors, depending on your PRO-iO2 model number.

The circuit diagram example below shows how to connect a sensor to input terminal IH of the PRO-iO2 module.

# **◆** Connecting to an input terminal (IH to IR):





- The above circuit's input logic is reversed from the PNP.
- When an NPN sensor is connected, use an external resistance of  $3.9k\Omega$  and 1/2W or more.

2-14 PRO-iO2 User Manual

#### 1. Basic Operation and Commands

- 2. LCD Display and Menu Screen
- 3. Initial Settings
- 4. Logic Program Editing

# 3 PRO-iO2 Operation

#### **♦ Logic Program Creation**

Chapter

PRO-iO2 Module Program Creation

✓ Reference ✓ "CHAPTER 3 Operating the PRO-iO2 Module"


PRO-iO2 Editor Software Program Creation

✓ Reference ✓ "PRO-iO2 Editor Operation Manual"

# 3.1 Basic Operation and Commands

#### 3.1.1 Basic Operation

Initial Settings and Logic Program Editing are performed via the PRO-iO2 module front face's operation keys. The function of each key is explained below:



Z1/Z2/Z3/Z4 keys : Used to move the cursor, select an option, or return to the

previous rung (Z1 key)

Menu/Ok button : Used to confirm the selection

Shift button : Pressing the Z keys or Menu/Ok button while holding down

the Shift button will insert an instruction or rung.

The functions pre-assigned to the Z keys are displayed at

the bottom of screen.

# 3.1.2 Contacts / Coils

#### **■** Contacts

Symbol	Number	No. of Contacts	Description
Ι	I1 to I∗	*1	a contact (Bit input)
i	i1 to i∗	*1	b contact (Bit input)
Z*2	Z1 to Z4	4	a contact (Z key)
z*2	z1 to z4	4	b contact (Z key)
M	M1 to MV	28	a contact (Auxiliary relay)
m	m1 to mV	28	b contact (Auxiliary relay)
Q	Q1 to Q*	*1	a contact (Bit output)
q	q1 to q*	*1	b contact (Bit output)
T	T1 to TG	16	a contact (Timer)
t	t1 to tG	16	b contact (Timer)
С	C1 to CG	16	a contact (Counter)
С	c1 to cG	16	b contact (Counter)
K*3	K1	1	a contact (High-Speed Counter)
k*3	k1	1	b contact (High-Speed Counter)
V	V1 to V8	8	a contact (Counter Comparator)
٧	v1 to v8	8	b contact (Counter Comparator)
A*4	A1 to A8	16	a contact (Analog Comparator)
a*4	a1 to a8	16	b contact (Analog Comparator)
H*2	H1 to H8	8	a contact (Calender)
h*2	h1 to h8	8	b contact (Calender)
W*2	W1	1	a contact (Summer Time)
w*2	w1	1	b contact (Summer Time)

<sup>\*1</sup> The number of points varies depending on the model type.

**▼Reference** "PRO-iO2 module Models"

For the number of points with an I/O extension module being connected:

Reference "About PRO-iO2 I/O Extension Module"

- \*2 Applies only to a  $DR^*-B^{*****}$  module. Not applicable for a  $DR^*-D^{*****}$  module.
- \*3 Applies only to a DR\*-\*\*\*\*BD module. Not applicable for a DR\*-\*\*\*\*FU module.
- \*4 Applies only to a DR\*-B\*\*\*BD and DR2-D201BD. Not applicable for a DR2-D101BD or DR\*-\*\*\*FU module.

3-2 PRO-iO2 User Manual

#### **■** Coils

Sym	bol	Number	No. of Contacts	Description
		[ Q1 to [Q*	*1	Normal coil
Q	J	_Q1 to _Q∗	*1	Reverse when condition is true (Rising)
ų ų	S	SQ1 to SQ*	*1	Set coil
	R	RQ1 to RQ*	*1	Reset coil
		[M1 to [MV	28	Normal coil
M		∫M1 to ∫MV	28	Reverse when condition is true (Rising)
IVI	S	SM1 to SMV	28	Set coil
	R	RM1 to RMV	28	Reset coil
Т	TT	TT1 to TTG	16	Timer start coil
'	TR	RT1 to RTG	16	Timer reset coil
	CC	CC1 to CCG	16	Counter coil
С	RC	RC1 to RCG	16	Counter reset coil
	DC	DC1 to DCG	16	Count direction designation coil
K*2	TK	TK1	1	High-speed counter coil
, n	RK	RK1	1	High-speed counter reset coil
X*3	TX	TX1 to TXG	16	Text show coil
^ -	RX	RX1 to RXG	16	Text hide coil
L*3	TL	TL1	1	Turns ON LCD backlight

<sup>\*1</sup> The number of points varies depending on the model type.

# **▼Reference** "PRO-iO2 module Models"

For the number of points with an I/O extension module being connected:


# Reference ... "About PRO-iO2 I/O Extension Module"

- \*2 Applies only to a DR\*-\*\*\*BD module. Not applicable for a DR\*-\*\*\*FU module.
- \*3 Applies only to a  $DR^*-B^{*****}$  module. Not applicable for a  $DR^*-D^{*****}$  module.

# 3.1.3 Maximum Number of Program Lines

The maximum number of program lines is 120, and each line can have five contacts (maximum) and one coil.


The following diagram shows a sample program consisting of three rungs (lines). (Up to 120 similar rungs can be created.)




3-4 PRO-iO2 User Manual

# 3.2 LCD Display and Menu Screen

The PRO-iO2 Display screen displays the RUN/STOP status and time data as shown in the illustration below. Press the Menu/Ok button to display the Menu screen, allowing you to set the following parameters. Press the Z1 key to return to the previous Display screen.



The menu options from "PROGRAMMING" through "CHANGE SUMM/WINT" on the Menu screen can be selected or scrolled through using the Z2 and Z3 keys. After selecting the desired option, press the Menu/Ok button to enter the menu. To exit from the menu, press the Z1 key or press the Menu/Ok button again.



#### ■ Menu Screen

PROGRAMMING : Logic program monitoring can be performed in RUN

mode. Logic program creation/update can be performed in

STOP mode.

In RUN mode, "MONITORING" is displayed.

PARAMETER : Timer and Counter parameters can be changed even in

RUN mode.

RUN/STOP : Selects whether to run or stop the PRO-iO2 module.

CONFIGURATION : Designates the following settings (This function is dis-

abled in RUN mode.):

PASSWORD : Designates the password needed to access the logic

program. Press the Menu/Ok button to enable the setting, select a password using the Z1 to Z4 keys, and

press the Menu/Ok button again to confirm the

password. To cancel the setting, hold down the Shift button and then press the Menu/Ok button.

Note that parameters can be modified even when a

password is set.

Deleting the password will require the same password to be entered again. A valid password can be any four

digit number (0000 to 9999).

FILT : Designates the input filter time. The module is

designed only for a DC input filter. Select either SLOW (3ms to 5ms), or FAST (0.3ms to 0.5ms).

Zx=Keys : Designates whether the Z1 to Z4 keys on the panel's

front face will be used in the logic program. Selecting "Yes" designates these keys can be used for

input.

CYCLE & WATCHDOG: The WATCHDOG operates based on the

setting selected from the following options when the scan time of the logic program exceeds the time specified in the CYCLE setting (1 x 10 ms

to 9 x 10 ms).

INACTIVE : Normal operation mode

ALARM : Displays an alarm status. The alarm number for

"Cycle time overflow" can be checked with the

FAULT menu.

ERROR : Stops the program (STOP mode). The alarm

number for "Cycle time overrun" can be

checked with the FAULT menu.

3-6 PRO-iO2 User Manual

CLEAR PROG : Selects if the logic program is to be deleted or not.

(This function is disabled in RUN mode.)

TRANSFER : Transfers a logic program to or from the memory pack.

 $PRO-iO \rightarrow MEMORY$ :

From the PRO-iO2 module to the

memory pack

MEMORY → PRO-iO

From the memory pack to the PRO-iO2

module

VERSION : Identifies the model and the version of the PRO-iO2

module.

FAULT : Allows users to check the alarm number of the current

error or to cancel the error.

CHANGE D/H : Designates the year, month, day, and time. CAL corrects

the time deviation for the week (-31 secs to +31 secs).

CHANGE SUMM/WINT : Sets the summer time and winter time from the

following options:

USA, GB, EUROPE, NO (no setting), and OTHER

ZONE (manual setting)



SUMM represents summer daylight saving time and WINT represents winter daylight saving time. Use this setting only in countries that have adopted daylight saving time. In countries that have not adopted daylight saving time, be sure to select NO (no setting).

The Summer Time contact (W1) remains ON during the specified summer time period.


# 3.3 Initial Settings

When turning on the PRO-iO2 for the first time, make sure to set the current time.


#### ■ Setting the Current Time


Press the Menu/Ok button while the time and RUN/STOP status are being displayed. The screen switches to the Menu screen.

Use the Z2 key to scroll through the Menu screen and to select the "CHANGE D/H" menu option, and then press the Menu/Ok button to change the time setting.



Set up the year, month, date, day of the week, and time as shown below.





3-8 PRO-iO2 User Manual


# 3.4 Creating a Logic Program

Press the Menu/Ok button while the time data and RUN/STOP status are displayed on the Display screen, and the Menu screen appears. Select "PROGRAM-MING" using the Z2 and Z3 keys, and press the Menu/Ok button to enable writing of the logic program.

If the logic program is running, stop the program.

#### ■ Screen configuration

As shown in the illustration below, a rung (a line connecting two instructions) consists of up to five contacts and one coil.



#### ■ List of functions assigned to the Shift button

As described in the table below, a rung (line) or branch can be inserted by pressing one of the operation buttons and the Shift button simultaneously.

When the cursor is in the contact/instruction insertion area:


Operation button	Displayed symbol	Description
Z1key(◀)	ins.	Inserts a rung (line).
Z2key(▼)	_	Scrolls the instruction in the minus direction.
Z3key(▲)	+	Scrolls the instruction in the plus direction.
Z4key(►)	Param	Sets the parameters for each instruction.
Menu/Ok button	Del.	Deletes an instruction or a line.

When the cursor is in the branch insertion area:

Operation button Displayed symbol		Description
Z1key(◀)	<b>←</b>	
Z2key(▼)	<b>\</b>	Extends the rung (line) or inserts a branch in
Z3key(▲)	1	each direction.
Z4key(►)	$\rightarrow$	
Menu/Ok button	Del.	Deletes a rung (line) or a branch.

#### 3.4.1 Bit Input (Symbol: I)

A bit input can only be used as a contact.




Display format	Function	Description	
I + Number	a contact	Contacts for an external input	
i + Number	b contact	Contacts for an external input	


#### ■ Operating procedure

This section describes the procedure for creating an AND circuit that consists of a-contact and b-contact bit inputs as shown above.


Press the Shift button when the cursor is in the contact/instruction insertion area (square cursor).
 The [+] and [-] scroll symbols are displayed on the bottom of the screen, allowing you to insert an instruction.



 Press the Z3 key ([+] button) once while holding down the Shift button. An I1 bit input is inserted.
 Release the Shift button and press the Z4 key three times to move the cursor to the next insertion point for a contact.



 Press the Z3 key twice while holding down the Shift button. An i1 bit input is inserted.
 Release the Shift button and press the Z4 key once to move the cursor to the contact number area.




- 4. Press the Z3 key once while holding down the Shift button. The contact number changes to "2", and i2 is inserted.
- 5. Press the Z4 key once to move the cursor to the branch area. Press the Z4 key while holding down the Shift button to insert a line.

3-10 PRO-iO2 User Manual

# 3.4.2 Bit Output (Symbol: Q)

A bit output can be used as a contact or a coil.



When used as a contact:

Display format	Function	Description	
Q + Number	a contact	Contacts for an external output	
q + Number	b contact	Contacts for an external output	


When used as a coil:

Display format	Description
[Q + Number	Outputs only when the contact connected to this coil is closed.
∫Q + Number	A pulse output. The output turns on when the rising edge is detected as
	the status of the input changes.
SQ + Number	A Set coil. The output turns on when the contact connected to the coil is
	closed, and remains on regardless of the status of the contact.
RQ + Number	A Reset coil. The coil turns off when the contact connected to the coil is
	closed, and remains off regardless of the status of the contact.

#### ■ Latch function upon power failure

The Latch function saves the conditions set for a given function block in the event of a power failure, and retrieves the conditions when recovering from the power failure. The following section describes the setting procedure.

1. Place the cursor on the desired device symbol, and press the Z4 key (Param) while holding down the Shift button.



2. Place the cursor on the "lightning" icon on the right edge, and invert the display of the icon using the Z2 or Z3 key.



When latched When unlatched






#### ■ Operating procedure

This section describes the procedure for creating a self-holding circuit for the bit outputs.


1. Insert I1 (bit input) and then insert the remainder of the rung, up to the coil insertion area.

**▼Reference 3.4.1** Bit Input (Symbol: I)"




2. Press the Z3 key ([+] button) once while holding down the Shift button. An [M1 auxiliary coil is inserted.

Release the Shift button and then move the cursor to the M position.



3. Press the Z3 key ([+] button) once while holding down the Shift button. Q1 (bit output) is inserted. Release the Shift button and then move the cursor to the left edge of LINE 2 using the Z1 and Z2 keys.







To convert the settings of a rising edge detector coil, set coil, or reset coil, move the cursor to "[" and press the Z3 key ([+] button) or Z2 key ([-] button) while holding down the Shift button.

4. Press the Z3 key ([+] button) seven times while holding down the Shift button. A Q1 bit output is inserted.

Release the Shift button and then move the cursor to the branch insertion area using the Z4 key.



5. Press the Z3 key once while holding down the Shift button. A branch is inserted.



3-12 PRO-iO2 User Manual


#### 3.4.3 Z Keys (Symbol: Z)

The Z keys refer to the four keys on the front panel of the PRO-iO2 module. Depending on the setting, the Z keys function as push buttons which can be used as contacts within a program.



To use the Z keys as contacts, the appropriate setting should be configured (CONFIGURATION/Zx=Keys) on the Menu screen of the PRO-iO2 module.

**▼Reference** ★ "3.2 LCD Display and Menu Screen"




Display format	Function	Description
Z + Number	a contact	A contact for the four buttons on the front panel of the
z + Number	b contact	PRO-iO2 module.

#### **■** Operating procedure

This section describes the procedure for creating a circuit in which the Q1 bit output is turned on by pressing the Z1 key and turned off by pressing the Z2 key, as shown in the illustration above.


 Place the cursor on the contact/instruction insertion area (square cursor) and press the Shift button, and then press the Z3 key three times. The contact for the Z1 key is inserted.

Release the Shift button and press the Z4 key three times to move the cursor to the next contact insertion area.




2. Press the Z3 key ([+] button) four times while holding down the Shift button. The b-contact for the Z1 key is inserted.


Release the Shift button and press the Z4 key once to move the cursor to the contact number area.



3. Press the Z3 key once while holding down the Shift button. The contact number changes to "2", and z2 is inserted.




4. Press the Z4 key once to move the cursor to the branch insertion area. Press the Z4 key while holding down the Shift button to insert a rung.



5. This creates a self-holding circuit for bit output Q1.


**▼Reference ∴** "3.4.2 Bit Output (Symbol: Q)"



3-14 PRO-iO2 User Manual

# 3.4.4 Auxiliary Coils (Symbol: M)

An auxiliary coil can be used as a contact or a coil.



When used as a contact:

Display format	Function	Description
M + Number	a-contact	Also called internal relays or internal auxiliary relays. These
m + Number	b-contact	contacts can only be used within a program.


When used as a coil:

Display format	y format Description	
□M + Number	Outputs only when the connected contact is closed.	
∫M + Number	A pulse output. The output turns on when the rising edge is detected as the status of the input changes.	
SM + Number	A Set coil. The output turns on when the contact connected to the coil is closed, and remains on regardless of the status of the contact.	
RM + Number	A Reset coil. The coil turns off when the contact connected to the coil is closed, and remains off regardless of the status of the contact.	


#### ■ Latch function upon power failure

The Latch function saves the conditions set for a given function block in the event of a power failure, and retrieves the conditions when recovering from the power failure. The following section describes the setting procedure.

1. Place the cursor on the desired device symbol, and press the Z4 key (Param) while holding down the Shift button.



2. Place the cursor on the "lightning" icon on the right edge, and invert the display of the icon using the Z2 or Z3 key.




When latched When unlatched

#### ■ Operating procedure

This section describes the procedure for creating a self-holding circuit for the auxiliary coil.


1. Insert an I1 bit input and insert rungs up to the coil insertion area.

**▼Reference 3.4.1** Bit Input (Symbol: I)"



2. Press the Z3 key ([+] button) once while holding down the Shift button. An [M1 auxiliary coil is inserted.

Release the Shift button and then move the cursor to the left edge of LINE 2 using the Z1 and Z2 keys.







To convert the settings of a rising edge detector coil, set coil, or reset coil, move the cursor to "[" and press the Z3 key ([+] button) or Z2 key ([-] button) while holding down the Shift button.

3. Press the Z3 key ([+] button) five times while holding down the Shift button. An M1 auxiliary output is inserted.

Release the Shift button and then move the cursor to the branch insertion area using the Z4 key.




4. Press the Z3 key once while holding down the Shift button. A branch is inserted.



3-16 PRO-iO2 User Manual

# 3.4.5 Timer (Symbol: T)

A timer can be used as a contact or a coil.



When used as a contact:

Display format	Function	Description
T + Number	a contact	Operation of a contact varies depending on the parameter
t + Number	b contact	settings of the timer. Refer to the description below.

When used as a coil:


Display format	Description
	Turning this coil from OFF to ON or from ON to OFF will start the counting
TT + Number	operation of the timer. The counting type varies depending on the timer
	function described below.
RT + Number	Turning this coil from OFF to ON will reset the current value of the timer.

#### **■** Overview

This section describes the following items required when using a timer.

- Parameter display screen
- Latch function upon power failure
- Timer operations
- Operating procedure

#### ■ Parameter display screen



- (1) Timer input
- (2) Timer reset input
- (3) Timer contact
- (4) Parameter Lock function
- (5) Preset timer
- (6) Preset time
- (7) Latch (upon power failure)
- (8) Timer type

Display	Description
S	The following five types of time modules are available for the preset value.
	s (second): 00.01 seconds to 99.99 seconds
	S (second): 000.1 seconds to 999.9 seconds
	M:S (minute: second): 00 minutes 01 second to 99 minutes 59 seconds
	H:M (hour: minute): 00 hours 01 minute to 99 hours 59 minutes
	H (hour): 01 hour to 9999 hours
2	Enabling this option allows you to lock the preset value of the timer function. When the
	lock is activated, the preset value will not be displayed on the PARAMETER menu.
Tort	Used as a contact, and represents a timer output. The action of this contact varies
	depending on the timer type you have selected.
5	Enabling this option allows you to retain the preset value of the timer in the event of a
	power failure.




- The Timer for the PRO-iO2 module will have a margin of error of "preset value x 1%± scan time x 2". The "scan time" refers to the "CYCLE" value that is set in the CYCLE& WATCHDOG setting in the CONFIGURATION menu.
- Be sure to adjust the settings so that the preset value is at least twice the value of the scan time. Otherwise, timer processing will be inaccurate.

#### ■ Latch function upon power failure


The Latch function saves the conditions set for a given function block in the event of a power failure, and retrieves the conditions when recovering from the power failure. The following section describes the setting procedure.


1. Place the cursor on the desired device symbol, and press the Z4 key (Param) while holding down the Shift button.



3-18 PRO-iO2 User Manual


2. Place the cursor on the "lightning" icon on the right edge, and invert the display of the icon using the Z2 or Z3 key.






#### **■** Timer operations

This section describes the operations of each of the 11 types of timers using the following sample circuit.




# **◆** Feature A : ON Delay Timer

The Calculation bit turns ON when I1 is turned ON. The timer activates when the Calculation bit turns ON, and T1 is turned ON when the timer count reaches the preset value. (Timer value is reset if I1 turns OFF, or if reset signal (I2) turns ON while the Timer is activated.)



# **♦** Feature a : Trigger ON Delay Timer (ON/OFF via pulse)

The Calculation bit turns ON when I1 is turned ON. The timer activates when the Calculation bit turns ON, and T1 is turned ON when the timer count reaches the preset value. (The Calculation bit will not be turned OFF until it is reset.)




\*1 The timer calculation value is less than the timer preset value.

\*2 The calculation bit is an internal processing bit and cannot be displayed externally.


#### **♦** Feature C: OFF Delay Timer

The T1 turns ON when I1 is turned ON. The Calculation bit turns ON when I1 changes from ON to OFF, and T1 turns OFF when the timer count reaches the preset value. (Timer value is reset if I1 turns ON while the Timer is activated.)




#### ◆ Feature B: ON Pulse Timer

The Calculation bit and T1 turn ON when I1 is turned ON. The timer activates when the Calculation bit turns ON, and T1 is turned OFF when the timer count reaches the preset value. (Timer value is reset when counting starts.)



#### **◆** Feature W: OFF Pulse Timer

The Calculation bit and T1 turn ON when I1 changes from ON to OFF. The timer activates when the Calculation bit turns ON, and T1 is turned OFF when the timer count reaches the preset value. (Timer value is reset when counting starts.)




\*1 The calculation bit is an internal processing bit and cannot be displayed externally.

3-20 PRO-iO2 User Manual


#### **♦** Feature D: Blinking Relay

The Calculation bit turns ON when I1 is turned ON. T1 turns ON/OFF repeatedly at the interval of the preset value while the Calculation bit is ON. (Timer value is reset if I1 turns OFF, or if reset signal (I2) turns ON while the Timer is activated.)




#### ◆ Feature d: Blinking Timer (ON/OFF)

The Calculation bit turns ON when I1 is turned ON. T1 turns ON/OFF repeatedly at the interval of the preset value while the Calculation bit is ON. (The Calculation bit will not be turned OFF until it is reset.)



#### **♦** Feature T: Accumulation Timer

The Calculation bit remains ON while I1 is ON. While the Calculation bit is ON, time accumulates. T1 is turned ON when the accumulated time reaches the preset value. (The value of T1 will not be turned OFF until it is reset.)




<sup>\*1</sup> The timer calculation value is less than the timer preset value.

<sup>\*2</sup> The calculation bit is an internal processing bit and cannot be displayed externally.


#### **♦** Feature AC: ON/OFF Delay Timer

The Calculation bit turns ON when I1 is turned ON. T1 turns ON after tA has elapsed and turns OFF after tB has elapsed after the Calculation bit is turned ON. (Timer value is reset if I1 turns OFF, or if reset signal (I2) turns ON while the Timer is




#### ◆ Feature L: Asymmetrical Blinking Relay

The Calculation bit turns ON when I1 is turned ON.T1 turns ON/OFF repeatedly at the interval of the preset value (tA, tB) while the Calculation bit is ON. (The Calculation bit is turned OFF if I1 turns OFF, or if reset signal (I2) turns ON while the Timer is activated.)



#### ◆ Feature I: Asymmetrical Blinking Timer (ON/OFF)

The Calculation bit turns ON when I1 is turned ON. T1 turns ON/OFF repeatedly at the interval of the preset value (tA, tB) while the Calculation bit is ON. (The Calculation bit will not be turned OFF until it is reset.)




\*1 The timer calculation value is less than the timer preset value.

\*2 The calculation bit is an internal processing bit and cannot be displayed externally.

3-22 PRO-iO2 User Manual

#### **■** Operating procedure

This section describes the procedure for creating a delay circuit as illustrated on the screen below.




Timer type : ON Delay Timer (A)
Preset value : 1 minute 30 seconds

Latch : Disabled Parameter Lock : Disabled


1. Insert an I1 bit input and insert rungs up to the coil insertion area.

**▼Reference ~** "3.4.1 Bit Input (Symbol: I)"




2. Press the Z3 key ([+] button) once while holding down the Shift button. An [M1 auxiliary coil is inserted.

Release the Shift button and move the cursor to the M position.




3. Press the Z3 key ([+] button) twice while holding down the Shift button. A TT1 timer coil is inserted.

Place the cursor on the TT1 timer coil and press the Z4 key (Param) while holding down the Shift button.




4. Press the Z4 key ([→] button) three times. The time module of the preset value "s" flashes.

Press the Z3 key ([+] button) three times. "M: S" (minute: second) is displayed.



Time module of the preset value

5. Press the Z4 key ([→] button) twice. The time of the preset value, "t=00.00", flashes. Set the value to 01:30 using the Z2 key ([-] button) and Z3 key ([+] button), and then press the Menu/Ok button. Move the cursor to the left edge of LINE 2 using the Z1 and Z2 keys.






Press and hold the Z2 or Z3 key to change the time setting in increments of 10 seconds, 1 minute, or 1 hour.


6. Insert an I2 bit input and insert rungs up to the coil insertion area.

**▼Reference** "3.4.1 Bit Input (Symbol: I)"



7. Press the Z3 key once ([+] button) while holding down the Shift button. An [M1 auxiliary coil is inserted.


Release the Shift button and move the cursor to the M position.



8. Press the Z3 key ([+] button) twice while holding down the Shift button. A TT1 timer coil is inserted.

Press the Z1 key ( $[\leftarrow]$  button) once to place the cursor on the T (the first letter of TT1). Press the Z3 key ([+] button) while holding down the Shift button. An RT1 reset coil is inserted.


Move the cursor to the left edge of LINE 3 using the Z1 and Z2 keys.



9. Press the Z3 key ([+] button) nine times while holding down the Shift button. A T1 timer contact is inserted.

Extend the rung and insert a Q1 bit output.


**▼Reference** "3.4.2 Bit Output (Symbol: Q)"



3-24 PRO-iO2 User Manual

# 3.4.6 Counter (Symbol: C)

A Counter can be used as a contact or a coil.



#### When used as a contact:

Display format	Function	Description
C + Number	a-contact	The contact turns ON/OFF when the Counter reaches
c + Number	b-contact	the preset value.

#### When used as a coil:


Display format	Description
CC + Number	Turning this coil from OFF to ON or from ON to OFF will start the counting operation. The Counter increments/decrements by 1 according to the count direction designated by the DC coil.  The range of Counter operation is between 0 and 32767. The count operation stops when the current value reaches 0 (in FROM mode) or +32767 (in TO mode).
DC + Number	Designates the count direction by turning ON or OFF this coil. The default is a count-up operation.  OFF: Count-up (TO)  ON: Count-down (FROM)
RC + Number	Turning this coil from OFF to ON will reset the current value of the Counter.  TO mode: Resets the value to 0.  FROM mode: Resets the value to the preset value.

#### **■** Overview

This section describes the following items required when using a Counter.

- Parameter display screen
- Latch function upon power failure
- Count operations
- Operating procedure

#### ■ Parameter display screen




- (1) Counter input
- (2) Counter reset input
- (3) Counter contact
- (4) Parameter Lock function
- (5) Count direction
- (6) Counter Mode TO/FROM
- (7) Preset value
- (8) Latch (upon power failure)

Display	Description
	The Counter has the following two modes.
	TO: The count direction that starts from 0 and counts to the preset value.
_	The Counter output turns ON when the current value becomes
'	equal to the preset value.
	FROM: The count direction that starts from the preset value and counts to 0.
	The Counter output turns ON when the current value becomes 0.
Р	Represents the preset value. The value can be set within the range of 0 to
Ρ	32767.
	Enabling this option allows you to lock the preset value of the Counter function.
<b>2</b>	When the lock is activated, the preset value will not be displayed on the
	PARAMETER menu.
Corc	Used as a contact, and represents a Counter output.
_	Enabling this option allows you to retain the preset value of the Counter in the
2	event of a power failure.


#### ■ Latch function upon power failure

The Latch function saves the conditions set for a given function block in the event of a power failure, and retrieves the conditions when recovering from the power failure. The following section describes the setting procedure.

1. Place the cursor on the desired device symbol, and press the Z4 key (Param) while holding down the Shift button.



2. Place the cursor on the "lightning" icon on the right edge, and invert the display of the icon using the Z2 or Z3 key.






3-26 PRO-iO2 User Manual


# **■** Count operation

In the following operation example, the counter's condition is "normally ON".

#### TO mode




#### FROM mode



#### ■ Operating procedure

This section describes the procedure for creating a circuit illustrated in the screen below that counts I2 inputs and outputs a Q1 bit output when the preset value is reached.




Count direction : I2 input signal
Count direction : I1 input signal
Reset : I3 input signal

Preset value : 500
Latch : Disabled
Parameter Lock : Disabled


1. Insert an I1 bit input and insert rungs up to the coil insertion area.

▼ Reference \_ "3.4.1 Bit Input (Symbol: I)"



2. Press the Z3 key ([+] button) once while holding down the Shift button. An [M1 auxiliary coil is inserted.

Release the Shift button and move the cursor to the M position.




3. Press the Z3 key ([+] button) three times while holding down the Shift button.

A CC1 Counter coil is inserted.


Press the Z1 key ( $[\leftarrow]$  button) once to place the cursor on the C (the first letter of CC1). Press the Z3 key ([+] button) while holding down the Shift button. A DC1 Count direction coil is inserted.

Move the cursor to the left edge of LINE2 using the Z1 and Z2 keys.



4. Insert an I2 bit input and insert rungs up to the coil insertion area.


Follow the procedure in Step 2 to insert an [M1 auxiliary coil and move the cursor to the M position.



3-28 PRO-iO2 User Manual

5. Press the Z3 key ([+] button) three times while holding down the Shift button. A CC1 Counter coil is inserted.


Place the cursor on the CC1 Counter coil and press the Z4 key (Param) while holding down the Shift button.



6. Press the Z4 key ( $[\rightarrow]$  button) four times. The preset value flashes.

Set the preset value to P=500 using the Z2 key ([-] button) and Z3 key ([+] button), and then press the Menu/Ok button.

Move the cursor to the left edge of LINE 3 using the Z1 and Z2 keys.






Press and hold the Z2 or Z3 key to change the preset value setting in increments of 10 or 100.

7. Insert an I3 bit input and insert rungs up to the coil insertion area.


Follow the procedure in Step 2 to insert an [M1 auxiliary coil and move the cursor to the M position.



8. Press the Z3 key ([+] button) three times while holding down the Shift button. A CC1 Counter coil is inserted.

Press the Z1 key ([←] button) once to place the cursor on the C (the first letter of CC1). Press the Z3 key ([+] button) twice while holding down the Shift button. An RC1 reset coil is inserted.


Move the cursor to the left edge of LINE 4 using the Z1 and Z2 keys.



9. Press the Z3 key ([+] button) 11 times while holding down the Shift button. A C1 counter contact is inserted.

Extend the rung and then insert a Q1 bit output.


 $\nearrow$ Reference  $\checkmark$  "3.4.2 Bit Output (Symbol: Q)"



#### 3.4.7 High-speed Counter (Symbol: K)

A High-speed Counter can be used as a contact or a coil. A pulse with a frequency of up to 1 kHz can be counted using a High-speed Counter.

The High-speed Counter input counts up with the pulse of input I1 (rising edge), and counts down with the pulse of input I2 (rising edge).



#### When used as a contact:

Display format	Function	Description
K1	a-contact	The contact turns ON/OFF when the High-speed Counter
k1	b-contact	reaches the preset value.

#### When used as a coil:

Display format	Description
TK1	Turning this coil from OFF to ON or from ON to OFF will start the counting operation. The current value of the Counter becomes 0 when it exceeds the upper limit 65535, and becomes 65535 when it exceeds the lower limit (0).
RK1	Turning this coil from OFF to ON will reset the current value of the Counter.  TO mode: Resets the value to 0.  FROM mode: Resets the value to the preset value.


#### Overview

This section describes the following items required when using a Counter.

- Parameter display screen
- Latch function upon power failure
- Count operations
   Linear Counter (TO mode and FROM mode)
   Ring Counter (TO mode and FROM mode)
- Operating procedure

3-30 PRO-iO2 User Manual

#### ■ Parameter display screen




- (1) Counter input
- (2) Cycle type
  UNIQUE: Linear counter
  REPETITIVE: Ring counter
- (3) Pulse width
- (4) Parameter Lock function
- (5) Count direction
- (6) Counter Mode TO/FROM
- (7) Preset value
- (8) Latch (upon power failure)

Display	Description		
	The cycle type can	be selected from the following two options.	
UNIQUE or	UNIQUE: (Linear Counter)	In the "TO" mode, the Counter counts up (I1 input) or counts down (I2 input) starting from the initial value 0, and the Counter output turns ON when the current value becomes equal to the preset value. In the "FROM" mode, the Counter counts up (I1 input) or counts down (I2 input) starting from the state of initial value=preset value, and the Counter output turns ON when the current value becomes 0.	
REPETITIVE	REPETITIVE: (Ring Counter)	In the "TO" mode, the Counter counts up (I1 input) or counts down (I2 input) starting from the initial value 0, and the Counter output turns ON for the duration designated by the output time. At this timing, the current value is initialized to 0.  In the "FROM" mode, the Counter counts up (I1 input) or counts down (I2 input) starting from the state of initial value=preset value, and the Counter output turns ON for the duration designated by the output time. At this timing, the current value is initialized to the preset value.	
1	Displayed when REPETITIVE is selected, and indicates the duration in which the Counter output is turned ON. The setting can be made in the range of 1 to 32767 (x 100 ms).		
Р	Represents the pre	set value. The value can be set within the range of 0 to 32767.	
	The counter mode can be selected from the following two options:  TO: The count direction that starts from 0 and counts to the preset value.  The Counter output turns ON when the current value becomes equal the preset value.  FROM: The count direction that starts from the preset value and counts to 0.  The Counter output turns ON when the current value becomes 0.		
Т			
2	Enabling this option allows you to lock the preset value of the Counter function. When the lock is activated, the preset value will not be displayed on the PARAMETER menu.		
K1 or k1	Used as a contact,	Used as a contact, and represents a Counter output.	
5	Enabling this option allows you to retain the preset value of the Counter in the event of a power failure.		

#### ■ Latch function upon power failure

The Latch function saves the conditions set for a given function block in the event of a power failure, and retrieves the conditions when recovering from the power failure. The following section describes the setting procedure.

1. Place the cursor on the desired device symbol, and press the Z4 key (Param) while holding down the Shift button.



2. Place the cursor on the "lightning" icon on the right edge, and invert the display of the icon using the Z2 or Z3 key.




When latched When unlatched






#### **■** Count operation

**Linear Counter (TO mode)** 




**Linear Counter (FROM mode)** 




3-32 PRO-iO2 User Manual

#### **Ring Counter (TO mode)**




#### **Ring Counter (FROM mode)**



#### ■ Operating procedure

This section describes a circuit as illustrated in the screen below that counts the I1 input (counting-up) and I2 input (counting-down), and outputs the Q1 bit output when the preset value is reached.




**Count operation : Linear Counter (TO mode)** 

Reset : I3 input signal

Preset value : 1500
Latch : Disabled
Parameter Lock : Disabled


1. Create an OR circuit for bit inputs I1 and I2, and insert rungs up to the coil insertion area.

**Reference** "3.4.1 Bit Input (Symbol: I)" and "3.4.2 Bit Output (Symbol: Q)"




2. Press the Z3 key ([+] button) once while holding down the Shift button. An [M1 auxiliary coil is inserted.

Release the Shift button and move the cursor to the M position.



3. Press the Z3 key ([+] button) four times while holding down the Shift button. A TK1 Highspeed Counter coil is inserted.


Place the cursor on the TK1 High-speed Counter coil and press the Z4 key (Param) while holding down the Shift button.



4. Press the Z4 key ([→] button) four times and the preset value flashes.

Set the preset value to P=1500 using the Z2 key ([-] button) and Z3 key ([+] button), and then press the Menu/OK button.

Move the cursor to the left edge of LINE3 using the Z1 and Z2 keys.






Press and hold the Z2 or Z3 key to change the preset time in increments of 10 or 100.

3-34 PRO-iO2 User Manual

5. Insert an I3 bit input and insert rungs up to the coil insertion area.


Follow the procedure in Step 2 to insert an [M1 auxiliary coil and move the cursor to the M position.



6. Press the Z3 key ([+] button) four times while holding down the Shift button. A TK1 High-speed Counter coil is inserted.

Press the Z1 key ([ $\leftarrow$ ] button) once to place the cursor on the T (the first letter of "TK1"). Press the Z3 key ([+] button) while holding down the Shift button to insert an RK1 reset coil.


Move the cursor to the left edge of LINE4 using the Z1 and Z2 keys.



7. Press the Z3 key ([+] button) 13 times while holding down the Shift button. A K1 Counter contact is inserted.

Extend the rung and insert a Q1 bit output.

 $\nearrow$  Reference  $\checkmark$  "3.4.2 Bit Output (Symbol: Q)"



#### 3.4.8 Counter Comparator (Symbol: V)

A Counter Comparator can only be used as a contact. A Counter Comparator is used to compare the measured counter value with the internal reference value. It is also used to compare two measured counter values. For details:

**▼Reference** "PRO-iO2 Editor Operation Manual"



- When using the Counter Comparator function, it is necessary to configure the parameters using the PRO-iO2 Editor. The parameters cannot be set on the PRO-iO2 module.
- The Counter Comparator does not support a negative value. The Counter Comparator function may not operate properly when values are set such that the sum of the count value and offset value becomes a negative value.

#### <Example>


When making settings such as "Cx-5>Cy", make sure to designate the settings as "Cx>Cy+5".

Display format	Function	Description
V + Number	a contact	The contact turns ON/OFF when the comparison formula is
v + Number	b contact	satisfied.

3-36 PRO-iO2 User Manual

#### 3.4.9 Analog Comparator (Symbol: A)

An Analog Comparator can only be used as a contact. An Analog Comparator is used to compare a measured analog value with an internal preset value. It is also used to compare two measured analog values.




Display format	Function	Description
A + Number	a contact	The contact turns ON/OFF when the comparison formula is
a + Number	b contact	satisfied.

An Analog Comparator is used for the following operations.

- Comparing a measured analog value with an internal preset value.
- Comparing two measured analog values.
- Comparing two measured analog values with the hysteresis value.

#### ■ Parameter display screen



- (1) Analog Comparator input
- (2) Comparison formula
- (3) Preset value
- (4) Parameter Lock
- (5) Terminals to be compared


#### **♦** Comparison formula

Type of comparator	Description		
x1 > x2	The contact turns ON when the formula "x1 > x2" is true.		
x1 ≥ x2	The contact turns ON when the formula " $x1 \ge x2$ " is true.		
x1 = x2	The contact turns ON when the formula "x1 = x2" is true.		
x1 ≠ x2	The contact turns ON when the formula " $x1 \neq x2$ " is true.		
x1 ≤ x2	The contact turns ON when the formula " $x1 \le x2$ " is true.		
x1 < x2	The contact turns ON when the formula "x1 < x2" is true.		
x1- H ≤ x2 ≤ x1+ H	The contact turns ON when the formula "x1- H $\leq$ x2 $\leq$ x1+ H" is true.		

3-38 PRO-iO2 User Manual

#### ■ Operating procedure

This section describes the procedure for creating a circuit as illustrated in the screen below that measures the Ib analog input, and outputs a Q1 bit output when the value is below the preset value of 5 V.



Analog input terminal: Ib


Comparison operator :  $x1 \le x2$ 

Ib  $\leq$  R (R = 5.0)


**Preset value** : 5.0

**Parameter Lock** : Disabled

1. Press the Z3 key ([+] button) 17 times while holding down the Shift button. The A1 Analog Comparator contact is inserted.




2. Place the cursor on the A1 Analog Comparator and press the Z4 key (Param) while holding down the Shift button.




3. Press the Z4 key ( $[\rightarrow]$  button) once. The comparison operator No. flashes.

Set the comparison operator No. to "5  $(x1 \le x2)$ " using the Z2 key ([-] button) and Z3 key ([+] button).




4. Press the Z4 key ( $[\rightarrow]$  button) twice. The parameter of x1 flashes.

Set the parameter to "Ib" using the Z3 key ([+] button).



5. Press the Z4 key ( $[\rightarrow]$  button) once. The parameter of x2 flashes.


Set the parameter to "R" (preset value) using the Z3 key ([+] button).



Parameter of x2

6. Press the Z4 key ( $[\rightarrow]$  button) once. The parameter of R (preset value) flashes.

Set the parameter to "R=5.0" using the Z2 key ([-] button) and Z3 key ([+] button), and then press the Menu/Ok button.






Press and hold the  ${\bf Z2}$  or  ${\bf Z3}$  key to change the preset value setting in increments of 10.

7. Insert rungs up to the coil insertion area and insert a Q1 bit output.


**▼Reference** "3.4.2 Bit Output (Symbol: Q)"



3-40 PRO-iO2 User Manual

#### 3.4.10 Calendar (Symbol: H)

A Calendar can only be used as a contact. A Calendar is used to activate the contact at a preprogrammed time on the day of the week. It is also capable of controlling the output status for four channels (A, B, C, and D).




Display format	Function	Description
H + Number	a contact	The contact turns ON/OFF for the specified period of time.
h + Number	b contact	

#### ■ Outline of the operation

The Calendar contact turns ON during the following period of time when the parameters are set up as described below.

Channel A: Monday to Friday (9:00 to 17:30)

Channel C: Saturday to Sunday (12:00 to 15:30)








Specify the ON/OFF Time setting in the range between 0:00 and 23:59. To turn ON the contact from 21:00 to 5:00, adjust the settings so that the contact will be OFF from 21:00 to 5:00, and then assign a "b contact" to the Calendar contact you placed in the program.

#### ■ Parameter display screen



- (1) Calendar contact
- (2) Channel
- (3) Date selection
- (4) Parameter Lock
- (5) Start time (Hour: Minute)
- (6) Finish time (Hour: Minute)

Display	Description		
Α	Designate the channel. The output status can be controlled for four channels (A, B, C, and D).		
DW	Designated the day of the week. Select "—" (hyphen) for the day on which the operation will be deactivated.  0: Monday 1: Tuesday 2: Wednesday 3: Thursday 4: Friday 5: Saturday 6: Sunday		
2	Use this option to lock the parameters of the Calendar. When the lock is activated, the preset value will not be displayed on the PARAMETER menu.		
H: M ON	Designate the start time of the operation in "hour: minute" (00:00 to 23:59) format.		
H: M OFF	Designate the finish time of the operation in "hour: minute" (00:00 to 23: 59) format.		



When the ON time settings for two channels overlap each other, the channel with the later time setting will not operate.

#### <Example>

When Channel A is set to turn ON from 10:00 to 12:00, and Channel B is set to turn ON from 11:00 to 13:00, the contact will be turned ON only from 10:00 to 12:00. When making such a setting, be sure to set it so that the contact will be turned ON from 10:00 to 13:00 by one channel.


• The same time cannot be entered for both the ON and OFF times of the same channel.

3-42 PRO-iO2 User Manual

#### ■ Operating procedure

This section describes the procedure for creating a circuit that outputs the Q1 bit output during the following period of time.

Channel A : Monday to Friday (9:00 to 17:00)



Channel : A


Date selection: Monday to Friday

Start time : 9:00 Finish time : 17:00 Parameter Lock : Disabled


Q1 turns ON.

O0 01 02 03 04 05 06 07 08 09 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 Mon.
Tue.
Wed.
Thu.
Fri.
Sat.
Sun.


1. Press the Z3 key ([+] button) 19 times while holding down the Shift button. An H1 Calendar contact is inserted.



2. Place the cursor on the H1 Calendar contact and press the Z4 key (Param) while holding down the Shift button.




Press the Z4 key ([→] button) three times. The hyphen for the date selection flashes.
 As shown in the illustration on the right, change the settings from "–" (hyphens) to "0" (Monday) through "4" (Friday) using the Z3 and Z4 key.
 Leave the settings of "5" (Saturday) and "6" (Sunday) unchanged "–" (hyphens).



Select the day of the week

4. Press the Z4 key ( $[\rightarrow]$  button) once. The start time flashes.

Change the setting to "9:00" using the Z2 key ([–] button) and Z3 key ([+] button).




Specify the start time.



Press and hold the Z2 or Z3 key to change the preset value setting in increments of 10.

5. Press the Z4 key ( $[\rightarrow]$  button) once. The finish time flashes.


Change the setting to "17:00" using the Z2 key ([–] button) and Z3 key ([+] button), and then press the Menu/OK button.



Specify the finish time.

6. Insert rungs up to the coil insertion area and insert a Q1 bit output.

**▼Reference** "3.4.2 Bit Output (Symbol: Q)"



3-44 PRO-iO2 User Manual


#### 3.4.11 Text Block (Symbol: TX)

A Text block can only be used as a coil. A Text block is used to display text (alphabets and numerals) on the screen on the PRO-iO2 module, and display values for a Timer or Counter. For details,

▼Reference "PRO-iO2 Editor Operation Manual"



When using the Text block function, it is necessary to configure the parameters via the PRO-iO2 Editor. The parameters cannot be set on the PRO-iO2 module.




Display format	Description
TX + Number	Turning this coil from OFF to ON will display text on the PRO-iO2 module's screen.
RX + Number	Turning this coil from OFF to ON will reset the text display and return the screen to the normal display.

#### 3.4.12 LCD Backlight (Symbol: TL)

The LCD Backlight can only be used as a coil. This function is used to turn on the backlight of the PRO-iO2 module's screen.




Pressing the operation button on the PRO-iO2 module will turn on the backlight for 30 seconds regardless of the ON/OFF status of the LCD Backlight coil.



Display format	Description
TL1	Turning this coil from OFF to ON will turn on the backlight of the screen of
161	the PRO-iO2 module.


#### ■ Operating procedure

This section describes the procedure for creating a circuit as illustrated in the following screen, in which the backlight of the PRO-iO2 module's screen turns on when the I1 bit input is turned ON.



1. Insert an I1 bit input and insert rungs up to the coil insertion area.


▼Reference \_ "3.4.1 Bit Input (Symbol: I)"




3-46 PRO-iO2 User Manual

2. Press the Z3 key ([+] button) once while holding down the Shift button. An [M1 auxiliary coil is inserted.

Release the Shift button and move the cursor to the M position.



3. Press the Z3 key ([+] button) six times while holding down the Shift button. A TL1 LCD Backlight coil is inserted.




#### 3.4.13 Summertime (Symbol: W)

A Summertime function can only be used as a contact. A Summertime contact turns on during the period of summer daylight savings time.



When using a Summertime contact, it is necessary to select the time zone on the Menu Screen of the PRO-iO2 module (CONFIGURATION/ CHANGE SUMM/WINT).


▼Reference \_ "3.2 LCD Display and Menu Screen"




Display format	Function	Description
W + Number	a contact	The contact turns ON during the period of summer daylight
w + Number	b contact	savings time.

#### ■ Operating procedure

This section describes the procedure for creating a circuit as illustrated in the following screen. In this screen the W1 Summertime contact turns ON and the Q1 bit output truns ON during the period of summer daylight savings time.




1. Press the Z2 key ([-] button) twice while holding down the Shift button. A W1 Summertime contact is inserted.



2. Insert rungs up to the coil insertion area and then insert a Q1 bit output.

▼Reference "3.4.2 Bit Output (Symbol: Q)"



3-48 PRO-iO2 User Manual



- 1. PRO-iO2 Memory Pack
- 2. Memory Backup upon a Power Interruption

This section describes the procedure for making backup data for the PRO-iO2.

# 4.1 PRO-iO2 Memory Pack

This section describes the special Memory Pack unit for the PRO-iO2 (DR2-MEM01) that is used to store logic programs you have created. The PRO-iO2 Memory Pack is available as an option.



The PRO-iO2 Memory Pack can be used only with the DR\*-B\*\*\*\*\*. With the DR2-D\*\*\*\*\*, backup data and logic programs cannot be transferred using the PRO-iO2 Memory Pack.

# **ACAUTION**

When handling the PRO-iO2 Memory Pack, avoid the following. Otherwise, the recorded data will be lost or a malfunction will result.

- Do not drop the PRO-iO2 Memory Pack unit, or subject it to excessive vibration.
- Do not soak the product in water or moisten the product with water.
- Do not touch the connector terminals. Doing so can cause an electric shock.
- Do not disassemble or remodel the PRO-iO2 Memory Pack.

#### Backup (PRO-iO2 Memory Pack)

You can transfer logic programs from the PRO-iO2 memory pack to the PRO-iO2 module and vice-versa, via the PRO-iO2 module **Transfer** menu.

For menu screen.

▼Reference 

"3.2 LCD Display and Menu Screen"


Select from one of the following program transfer directions:

#### 1. **PRO-iO** $\rightarrow$ **Memory**

From the PRO-iO2 module to the PRO-iO2 memory pack.

#### 2. **Memory** $\rightarrow$ **PRO-iO** :

From the PRO-iO2 memory pack to the PRO-iO2 module.





Be sure to disconnect power to the PRO-iO2 module when installing mportant the PRO-iO2 Memory Pack.



- Logic programs saved on the PRO-iO2 Memory Pack can be transferred from a DR\*-B\*\*\*\* to another DR\*-B\*\*\*\* module.
- The PRO-iO2 Memory Pack is an Electrically Erasable Programmable Read Only Memory (EEPROM). You can write data to the Memory Pack approximately 100,000 times.

#### ■ Backup Items

The following items will be saved in the PRO-iO2 Memory Pack:

- Logic Program
- Password
- Scan Time and Watchdog Settings
- Input Filter Time
- If the "Use the Z Keys as contacts" setting is enabled/disabled.
- Data saved when power is switched OFF. (Timer's current value and counter's current value cannot be saved.)

4-2 PRO-iO2 User Manual

# 4.2 Memory Backup during a Power Outage

#### **4.2.1 Memory**

The PRO-iO2 module uses EEPROM memory, which stores the following data items.

#### ■ Backup Items

- Logic Program
- RUN/STOP status of the Module
- Password
- Scan Time and Watchdog Settings
- Input Filter Time
- If the "Use the Z Keys as contacts" setting is enabled/disabled. (Excluding the DR2-D\*\*\*\*.)
- The Latched data (Data retained at power failure)



• The Latched data includes the following items. Refer to the corresponding page for the setup procedure.

M: Auxiliary relay: \( \subseteq \text{Reference} \( \subseteq \) "3.4.4 Auxiliary Coils"

Q: Bit Output: \( \sum\_{Reference} \) "3.4.2 Bit Output"

T: Timer: ▼ Reference ▲ "3.4.5 Timer"

C: Counter: \(\sum\_{Reference}\) "3.4.6 Counter"

K: High-speed Counter: \( \square Reference \( \square \) "3.4.7 High-speed Counter"

#### 4.2.2 Primary Battery

The PRO-iO2 module is equipped with an internal primary battery. The internal primary battery is used for operating the clock if there is a power failure.

(DR2-D\*\*\*\* is not equipped with an internal primary battery.)

The service life of the primary battery is approximately 10 years (at 25°C). The primary battery cannot be replaced.

#### ■ Backup Items

Current Time: The current time clock also includes the year, month, date, and day of the week.

# Memo

4-4 PRO-iO2 User Manual

#### 1. Error Messages

# Chapter 5 Error Messages

This chapter describes the error messages displayed on the PRO-iO2 module.

# **5.1** Error Messages

# **■** Messages

One of the following messages will be displayed when an inappropriate operation is performed on the PRO-iO2 module.

Message	Cause	Solution
NO PARAMETER	The PARAMET function was accessed when no parameter existed.	Confirm that the element's parameter values can be set.
TRANSF.ERR	Connection to the PC was broken during data transfer.	Check the connection between the PRO-iO2 module and the PC.
TRANSFER ERR: NO MEMORY	The Memory Pack was not set up correctly when transferring the program.	Confirm that the Memory Pack has been correctly set up.
TRANSFER ERR: CONFIG INCOMPAT	The properties of the program to be transferred are incompatible with the PRO-iO2 specifications. (e.g. The Calendar function is used in the program although the destination PRO-iO2 module does not support the Calendar function.)	Check the type of program you are transferring to the PRO-iO2 module. Be sure to select a program that is compatible with the PRO-iO2 specifications.
TRANSFER ERR: VERSION INCOMPAT	The firmware version of the PRO-iO2 modules is incompatible.	Select the [Module/Firmware Update] command on the PRO-iO2 Editor to upgrade the version.
Outputs are displayed blinking on the main screen	Short-circuit or overload has been generated by some output.	Remove the short-circuit cause or overload from the output, and turn the PRO-iO2 module OFF to cancel the screen's blinking display. Then, put the PRO-iO2 module in RUN mode again.

# **Error Messages**

#### **■** Errors

The following list describes the troubleshooting procedure for each Error No. displayed by selecting [Menu/FAULT].

No.	Cause	Solution
00	No error is detected.	
01	Error in transferring data to the Memory Pack.	Check that the Memory Pack is loaded properly.
02	Error in writing data to the clock.	Set the time again by selecting the [Menu/CHANGE D/H] command.
50, 52, 58	Firmware or logic program is destroyed.	Transfer the firmware and logic program again. The firmware can be transferred by selecting the [Module/Firmware Update] command on the PRO-iO2 Editor.
51	The scan time is shorter than the execution time of the logic program.	When it is necessary to precisely sample the inputs/outputs on the program, specify a longer scan time. When precise sampling is not required, select the [Menu/CYCLE & WAT CHDOG] command, and set the parameter to INACT IVE (disabled).
54	Error between the I/O extension modules	An error is detected in the connection between the PRO-iO2 module and I/O extension module. Turn off the power supply, and reconnect the extension module with the PRO-iO2 module again.
59	At the start of RUN mode: The program is incompatible with the connected PRO-iO2 module. The program cannot be switched to the RUN mode.	Check the model number of the PRO-iO2 to which the extension module is connected.
61	At the start of RUN mode: The program is incompatible with the connected I/O extension module.	Check the model number of the PRO-iO2 to which the extension module is connected.
62	The versions do not agree when a logic program is read from the Memory Pack.	Check the version information again by selecting the [Menu/VERSION] command.
63	The settings are incompatible with the hardware settings when a logic program is read from the Memory Pack.	Check the hardware information again by selecting the [Menu/CONFIGURATION] command.

5-2 PRO-iO2 User Manual