Restoring Backup Device Data


22.1	Try to Restoring Backup Device Data	22-2
22.2	Setting Guide	22-4

22.1 Try to Restoring Backup Device Data


You can restore the backup device data to the source device.




- Restoring is available for the sequential device data.
- For the details of device data backup, please refer to "21 Saving Device Data Backup".
- 1 Click [Restore Device] from [Tool] on the menu bar.



2 Set all items in the "Device Restore" screen and click the [Restore] button.



The "now" screen is displayed, indicating the processing status of restoration.



NOTE

• The set contents in the "Device Restore" screen are incorrect, the following message appears:


Message	Required action
You cannot designate a bit- type symbol to data restoration other than in the BIT format	If you designated a BIT symbol in the [Device Address] field, you cannot restore data in formats other than BIT. Reset the symbol other than in "BIT" in the [Device Address] field, and then restore.
You cannot designate a symbol other than in BIT to data restoration in the BIT format.	If you designated a symbol in formats other than BIT in the [Device Address] field, you cannot restore BIT data. Reset the BIT symbol in the [Device Address] field, and then restore.
The designated file is incorrect.	If you designate a Bit backup data file by 'Pro-Server' of the older version (V4.0) in the [File Name] field, you cannot restore it. Reset other file in the [File Name] field, and then restore.
The amount of data to restore is incorrect.	Please set up restore devices only up to the maximum limit and run restore again. The amount of data you can restore is different depending on the device data type, and so on.
Device address is not valid. Or designed access type is not supported.	Set up an accessible device address or symbol and run restore again.

When the saving process has been completed successfully, the message of "Device restore was successfully completed." appears.

Click the [OK] button to finish the process.



22.2 Setting Guide



Setting item	Setting content	Setting content				
File Name		Set the file name where the device data is backed up. Click the [Browse] button or enter the file name directly to select the file.				
		If you designate a file in the [File Name] field, the following table showing formats corresponding to files will appear.				
	File format	Data format	Write format	Display		
		Bit	-	Bit		
		8 bits	-	8 bits		
	BIN	16 bits	-	16 bits		
	DIIN	32 bits	-	32 bits		
		64 bits	-	64 bits		
		String	-	Text		
		Bit	-	Bit		
			Unsigned decimal	8 bits unsigned decimal		
Format		8 bits	Signed decimal	8 bits signed decimal		
			Hexadecimal	8 bits hexadecimal		
			Unsigned decimal	16 bits unsigned decimal		
		16 bits	Signed decimal	16 bits signed decimal		
	CSV		Hexadecimal	16 bits hexadecimal		
			Unsigned decimal	32 bits unsigned decimal		
		32 bits	Signed decimal	32 bits signed decimal		
			Hexadecimal	32 bits hexadecimal		
			Unsigned decimal	64 bits unsigned decimal		
		64 bits	Signed decimal	64 bits signed decimal		
			Hexadecimal	64 bits hexadecimal		
		String	-	Text		
		String	-	Text		

Setting item	Setting content			
Node Name	Select the node name of restoring destination. NOTE • [MEMO] The list indicates the nodes registered in the network project file under loading.			
Device/PLC	Select the Device/PLC of restoring destination.			
Device Address	Enter the device address (or symbol) to start the restoration. By default, the leading addres saved in the file is displayed when you set the file name.			
Restore Number	Enter the number of restoration data. By default, the number of data saved in the file is displayed when you set the file name.			